

Pulse Releases - Three Levels

Table 7-11 Master Water Control Plan for Lake Okeechobee

Day of Pulse	Level I		Level II		Level III	
	St. Lucie S-80 (cfs)	Caloos. S-77 (cfs)	St. Lucie S-80 (cfs)	Caloos. S-77 (cfs)	St. Lucie S-80 (cfs)	Caloos. S-77 (cfs)
1	1200	1000	1500	1500	1800	2000
2	1600	2800	2000	4200	2400	5500
3	1400	3300	1800	5000	2100	6500
4	1000	2400	1200	3800	1500	5000
5	700	2000	900	3000	1000	4000
6	600	1500	700	2200	900	3000
7	400	1200	500	1500	600	2000
8	400	800	500	800	600	1000
9	0	500	400	500	400	500
10	0	500	0	500	400	500
Average Flow	730	1600	950	2300	1170	3000
Volume (Ac-Ft)	14,480	31,736	18,843	45,621	23,207	59,505
*Equivalent Depth (ft)	0.03	0.07	0.04	0.10	0.05	0.13

*Volume-Depth conversion based on average lake surface area of 467000 acres