Application of the Lake Okeechobee Regulation Schedule (LORS2008) on 8/13/2018 (ENSO Neutral Condition)

Lake Okeechobee Net Inflow Outlook:

The Lake Okeechobee Net Inflow Outlook has been computed using 4 methods: Croley's method¹, the SFWMD empirical method², a sub-sampling of Neutral years³ and a sub-sampling of warm years of the Atlantic Multi-decadal Oscillation (AMO) in combination with La Nina ENSO years⁴. The results for Croley's method and the SFWMD empirical method are based on the <u>CPC Outlook</u>.

Table of the Lake Okeechobee Net Inflow Outlooks in feet of equivalent depth. All methods are updated on a weekly basis with observed net inflow for the current month.

Season	Cı Me	roley's ethod ^{1*}	SF En Me	FWMD npirical ethod ²	Sub-sa ENS	ampling of O Years ³	Sub-sampling of AMO Warm + ENSO Years ⁴		
	Value (ft)	Condition	Value (ft)	Condition	Value (ft)	Condition	Value (ft)	Condition	
Current (Aug-Jan)	N/A	N/A	1.89	Wet	2.65	Very Wet	1.57	Wet	
Multi Seasonal (Aug-Apr)	N/A	N/A	2.25	Normal	3.23	Wet	1.26	Normal	

*Croley's Method Not Produced For This Report

See <u>Seasonal</u> and <u>Multi-Seasonal</u> tables for the classification of Lake Okeechobee Outlooks.

The recommended methods and values for estimating the Lake Okeechobee Net Inflow Outlook are shaded and should be used in the LORS2008 Release Guidance Flow Charts.

**Sub-sampling is a weighted average of ENSO conditions based on the ENSO forecast used.

Tributary Hydrologic Conditions Graph:

6852 cfs 14-day running average for Lake Okeechobee Net Inflow through 8/12/2018. According to the classification in <u>Tributary Hydrologic Conditions</u> table, this condition is Very Wet.

1.55 for Palmer Index on 8/11/2018.

According to the classification in <u>Tributary Hydrologic Conditions</u> table, this condition is Wet.

The wetter of the two conditions above is Very Wet.

LORS2008 Classification Tables:

Lake Okeechobee Stage on 8/13/2018

Lake Okeechobee Stage: 14.52 feet

USACE Report for Lake Okeechobee

Lake Okeechobee Stage Hydrograph

Lake Okeechobe	ee Management	Bottom Elevation	Current
Zone/	Band	(feet, NGVD)	Lake Stage
High Lake Manag	amont Pond	16.24	
		10.34	
Operational Band	High sub-band	15.93	
	Intermediate sub-band	15.51	
	Low sub-band	13.68	← 14.52
Base Flow sub-ba	nd	12.60	
Beneficial Use sub	o-band	11.99	
Water Shortage M	anagement Band		

Part C of LORS2008: Discharge to WCA's

Release Guidance Flow Chart Outcome: Up to maximum practicable releases to the WCAs if desirable or with minimum everglades impacts; otherwise no releases.

Part D of LORS2008: Discharge to Tidewater

Release Guidance Flow Chart Outcome: S-77 Up to 4000 cfs & S-80 Up to 1800 cfs.

Back to Lake Okeechobee Operations Main Page

Back to U.S. Army Corps of Engineers Homepage

LORS2008 Implementation on 8/13/2018 (ENSO Neutral Condition):

Water Supply Risk Evaluation

Status for week ending 8/13/2018:

District wide, Raindar rainfall was 1.82 inches for the week. Lake stage on 8/13/2018 was 14.52 ft, NGVD, up 0.16 ft from last week.

The updated June 2018 SFWMM Dynamic Position Analysis percentile graph for

Lake Okeechobee show that the current lake stage is in the Low Flow Sub-Band.

The 2008 LORS Tributary Hydrologic Condition (THC) is classified as **Very Wet**. The PDSI indicates wet conditions and the LONIN is very wet. The THC classification is based on the wetter of the two <u>indices</u>.

Area	Indicator	Value	Color Coded Scoring Scheme
	Projected LOK Stage for the next two months	Low Flow Sub Band	L
	Palmer Index for LOK Tributary Conditions	1.55 (Normal to Extremely Wet)	L
	CPC Presipitation Outlook	1 month: Above Normal	L
LOK	CPC Precipitation Outlook	3 months: Normal	L
	LOK Seasonal Net Inflow Outlook ENSO Years	2.65 ft (Normal to Extremely Wet)	L
	LOK Multi-Seasonal Net Inflow Outlook ENSO Conditions	3.23 ft (Wet)	L
	WCA 1: Station Average (Site 1-7, Site 1-8T, Site 1-9)	Above Line 1 (16.35 ft)	L
WCAs	WCA 2A: Site 2-17	Above Line 1 (13.43 ft)	L
	WCA-3A: 3 Station Average (Site 63, 64 and 65)	Above Line 1 (10.53 ft)	L
	Service Area 1	Year-Round Irrigation Rule in effect	L
LEC	Service Area 2	Year-Round Irrigation Rule in effect	L
	Service Area 3	Year-Round Irrigation Rule in effect	L

Note: The water supply risk classification based on the Palmer index, as well as the LOK seasonal and multi-seasonal net inflow outlooks use slightly different classification intervals than those used by the 2008-LORS.

Back to Lake Okeechobee Operations Main Page Back to U.S. Army Corps of Engineers Lake Okeechobee Homepage

Lake Okeechobee SFWMM Aug 2018 Position Analysis



(See assumptions on the Position Analysis Results website)



Palmer Index



Mon Aug 13 14:31:48 EDT 2018

Flow (cfs)

2008 LORS

Part C: Establish Allowable Lake Okeechobee Releases to the Water Conservation Areas

2008 LORS

Part D: Establish Allowable Lake Okeechobee Releases to Tide (Estuaries)

Lake Okeechobee Water Level History and Projected Stages

SFWMD-HESM Position Analysis

U. S. Army Corps of Engineers, Jacksonville District Lake Okeechobee and Vicinity Report ** Preliminary Data - Subject to Revision **

Data Ending 2400 hours 12 AUG 2018

Okeechobee Lake Regulation Elevation Last Year 2YRS Ago (ft-NGVD) (ft-NGVD) (ft-NGVD) *Okeechobee Lake Elevation 14.52 13.22 14.78 (Official Elv) Bottom of High Lake Mngmt= 16.34 Top of Water Short Mngmt= 11.99 Currently in Operational Management Band

Simulated Average LORS2008 [1965-2000] 12.89 Difference from Average LORS2008 1.63

12AUG (1965-2007) Period of Record Average13.93Difference from POR Average0.59

Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations

++Navigation Depth (Based on 2007 Channel Condition Survey) Route 1 ÷ 8.46' ++Navigation Depth (Based on 2008 Channel Condition Survey) Route 2 ÷ 6.66' Bridge Clearance = 50.06'

4 Interior and 4 Edge Okeechobee Lake Average (Avg-Daily values):

L001 L005 L006 LZ40 S4 S352 S308 S133 14.56 -NR- 14.49 14.47 14.42 14.66 14.48 14.53

*Combination	Okeechobee	Avg-Daily	Lake	Average	=	14.52	
						(*See	Note)

Okeechobee Inflo	ws (cfs):				
S65E	0	S65EX1	4848	Fisheating Cr	355
S154	0	S191	0	S135 Pumps	112
S84	96	S133 Pumps	108	S2 Pumps	0
S84X	745	S127 Pumps	59	S3 Pumps	0
S71	44	S129 Pumps	62	S4 Pumps	0
S72	41	S131 Pumps	0	C5	0
Total Inflows:	6470				
Okeechobee Outfl	ows (cfs):				
S135 Culverts	0	S354	216	S77	1425
S127 Culverts	0	S351	1138	S308	2
S129 Culverts	0	S352	276		
S131 Culverts	0	L8 Canal Pt	-31		
Total Outflows:	3025				

****S77 structure flow is being used to compute Total Outflow.
****S308 structure flow is being used to compute Total Outflow.

Okeechobee Pan Evaporation (inches):

S77 0.10 S308 0.47 Average Pan Evap x 0.75 Pan Coefficient = 0.21" = 0.02' Lake Average Precipitation using NEXRAD: = 0.37" = 0.03' Evaporation - Precipitation: = -0.16" = -0.01' Evaporation - Precipitation using Lake Area of 730 square miles is equal to 3067 cfs into the lake. Lake Okeechobee (Change in Storage) Flow is 4235 cfs or 8400 AC-FT

	Headwater	Tailwater		Gate Positions						
	Elevation	Elevation	Disch	#1	#2	#3	#4	#5	#6 #7	#8
	(ft-msl)	(ft-msl)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft) (ft)	(ft)
) see n	ote at	bott	om				
North East Sh	nore									
S133 Pumps:	13.31	14.58	108	6	19	50	31	0	(cfs)	
S193:										
S191:	18.86	14.56	0	0.0	0.0	0.0				
S135 Pumps:	13.27	14.47	112	25	31	25	38		(cfs)	
S135 Culver	rts:		0	0.0	0.0					
North West St	ore									
S65E:	21.08	14.50	Ø	0.0	0.0	0.0	0.0	-0.0	0.0	
565EX1 ·	21.00	14 50	4848	0.0	0.0	0.0	0.0	0.0	0.0	
S127 Pumps	13.31	14.50	59	24	25	Ø	Ø	0	(cfs)	
S127 Culver	nt:	11150	0	0.0		Ũ	Ũ	Ũ	((()))	
011/ 00110			· ·							
S129 Pumps	12.90	14.51	62	43	19	0			(cfs)	
S129 Culver	rt:		0	0.0		Ū			(0.0)	
			-							
S131 Pumps:	12.87	14.54	0	0	0				(cfs)	
S131 Culver	rt:		0							
Fisheating	Creek									
nr Palmda	ale	32.26	355							
nr Lakepo	ort									
C5:		- NR -	0	-NR	RNR	RNI	R –			
South Shore										
S4 Pumps:	11.54	14.40	0	0	0	0			(cfs)	
S169:	14.44	11.55	0	0.0	0.0	0.0				
S310:	14.35		10							
S3 Pumps:	10.15	14.41	0	0	0	0			(cfs)	
S354:	14.41	10.15	216	0.3	0.4					
S2 Pumps:	10.15	14.39	0	0	0	0	0		(cfs)	
S351:	14.39	10.15	1138	1.4	1.4	1.5				
S352:	14.71	10.47	276	0.6	0.7					
C10A:	- NR -	14.77		8.0	8.0	8	.0 (0.0	0.0	
L8 Canal P	Γ	14.60	-31							

S351: 10.15 14.39 1138 -NR--NR--NR--NR--NR-S352: 10.47 14.71 276 -NR--NR--NR--NR-10.15 14.41 216 -NR--NR--NR-S354: Caloosahatchee River (S77, S78, S79) S47B: 13.60 12.02 0.0 0.0 S47D: 11.25 11.25 3 6.5 S77: Spillway and Sector Flow: ***** 11.14 0.0 3.0 3.0 0.0 14.39 Flow Due to Lockages+: 3 S77 Below USGS Flow Gage 1328 S78: Spillway and Sector Flow: 11.03 3.29 1620 0.0 2.5 2.5 0.0 9 Flow Due to Lockages+: S79: Spillway and Sector Flow: 2.0 2.0 2.0 2.0 2.0 2.0 0.5 0.0 3.31 1.12 3221 Flow Due to Lockages+: 4 Percent of flow from S77 44% Chloride 48 (ppm) St. Lucie Canal (S308, S80) S308: Spillway and Sector Flow: 14.55 0.00 0.0 0.0 0.0 0.0 13.44 Flow Due to Lockages+: 2 S308 Below USGS Flow Gage 91 18.97 S153: 13.31 44 0.1 0.0 580: Spillway and Sector Flow: 13.75 1.28 541 0.0 0.0 0.0 0.0 0.0 0.0 0.0 Flow Due to Lockages+: 21 Percent of flow from S308 0% (mg/ml) **** Steele Point Top Salinity Steele Point Bottom Salinity (mg/ml) **** Speedy Point Top Salinity (mg/ml) 7964 Speedy Point Bottom Salinity (mg/ml) **** + Flow Due to lockages is computed utilizing average daily headwater and tailwater along with total number of lockages for the day to calculate

a volume which is then converted to an average discharge in cfs.

				Wir	nd
Daily Precipitation Totals	1-Day	3-Day	7-Day	Directior	n Speed
	(inches)	(inches)	(inches)	(Degø)	(mph)
S133 Pump Station:	- NR -	0.00	0.00		
S193:	- NR -	0.00	0.00	- NR -	-NR-
Okeechobee Field Station:	- NR -	0.00	0.00		

S135 Pump Station:	- NR -	0.00	0.00		
S127 Pump Station:	- NR -	0.00	0.00		
S129 Pump Station:	- NR -	0.00	0.00		
S131 Pump Station:	- NR -	0.00	0.00		
S77:	0.82	0.82	2.00	180	3
S78:	1.20	2.00	2.73	167	1
S79:	0.34	0.43	2.21	270	0
S4 Pump Station:	- NR -	0.00	0.00		
Clewiston Field Station:	- NR -	0.00	0.00		
S3 Pump Station:	- NR -	0.00	0.00		
S2 Pump Station:	- NR -	0.00	0.00		
S308:	0.01	0.05	0.22	135	7
S80:	0.00	0.00	0.00	222	2
Okeechobee Average	0.42	0.07	0.17		
(Sites S78, S79 and	S80 not in	cluded)			
Oke Nexrad Basin Avg	0.37	0.82	2.34		

Okeechobee	Lak	e Ele	vations	12	AUG	2018	14.52	Difference	from 12AUG18
12AUG18	-1	Day	=	11	AUG	2018	14.50		-0.02
12AUG18	-2	Days	=	10	AUG	2018	14.48		-0.04
12AUG18	- 3	Days	=	09	AUG	2018	14.45		-0.07
12AUG18	-4	Days	=	08	AUG	2018	14.45		-0.07
12AUG18	- 5	Days	=	07	AUG	2018	14.44		-0.08
12AUG18	-6	Days	=	06	AUG	2018	14.39		-0.13
12AUG18	-7	Days	=	05	AUG	2018	14.39		-0.13
12AUG18	-30	Days	=	13	JUL	2018	14.49		-0.03
12AUG18	-1	Year	=	12	AUG	2017	13.22		-1.30
12AUG18	-2	Year	=	12	AUG	2016	14.78		0.26

Long Term Mean 30day Avearge ET for Lake Alfred (Inches) = 4.42

				Lake	0kee	chobee	Net Infl	ow (LONIN)	
			Ave	rage Flo	w ove	er the	previous	14 days	Avg-Daily Flow
12AUG18	-	Today	=	12	AUG	2018	6700	MON	7287
12AUG18	-1	Day	=	11	AUG	2018	6424	SUN	7937
12AUG18	-2	Days	=	10	AUG	2018	6030	SAT	11906
12AUG18	- 3	Days	=	09	AUG	2018	5333	FRI	6043
12AUG18	-4	Days	=	08	AUG	2018	4985	THU	8682
12AUG18	- 5	Days	=	07	AUG	2018	4426	WED	16673
12AUG18	-6	Days	=	06	AUG	2018	3244	TUE	2590
12AUG18	-7	Days	=	05	AUG	2018	3695	MON	1888
12AUG18	-8	Days	=	04	AUG	2018	3585	SUN	4399
12AUG18	-9	Days	=	03	AUG	2018	3281	SAT	3103
12AUG18	-10	Days	=	02	AUG	2018	3144	FRI	5965
12AUG18	-11	Days	=	01	AUG	2018	3602	THU	6033
12AUG18	-12	Days	=	31	JUL	2018	3632	WED	2886
12AUG18	-13	Days	=	30	JUL	2018	3654	TUE	8403
					S	65E			
				Average	۶lo	w over	previous	14 days	Avg-Daily Flow
12AUG18		Toda	y=	12	AUG	2018	0	MON	0
12AUG18	-1	Day	=	11	AUG	2018	0	SUN	0
12AUG18	-2	Days	=	10	AUG	2018	0	SAT	0

12AUG18	-3 Days =	09	AUG 2018	0	FRI		0
12AUG18	-4 Days =	08	AUG 2018	0	THU	i	0
12AUG18	-5 Davs =	07	AUG 2018	0	WED	i	0
12AUG18	-6 Davs =	06	AUG 2018	0	TUF	i	0
124UG18	-7 Days =	05		â	MON	ł	0
12/0610	-8 Days $-$	01	AUG 2010	0	SUM	- 1	0
1240018	-0 Days -	04	AUG 2018	0			0
12AUG18	-9 Days =	03	AUG 2018	0			0
12AUG18	-10 Days =	02	AUG 2018	0			Ø
12AUG18	-11 Days =	01	AUG 2018	0	THU	ļ	Ø
12AUG18	-12 Days =	31	JUL 2018	0	WED	ļ	0
12AUG18	-13 Days =	30	JUL 2018	0	TUE		0
			S65EX1				
		Average	Flow over	previous	14 days	Ι	Avg-Daily Flow
12AUG18	Todav=	12	AUG 2018	4729	MON	'	4848
12AUG18	-1 Day =	11	AUG 2018	4597	SUN		4863
1240610	-2 Dave -	10	ΔIIG 2010	4JJ7 4/2/	ςΔT		4005 Δ <u>8</u> 17
1240010	-2 Days -	10	AUG 2010	4494	EDT		
		69	AUC 2010	4202	T.I.I.		4/07 4700
12AUG18	-4 Days =	80	AUG 2018	40/3	THU		4/83
12AUG18	-5 Days =	67	AUG 2018	3885	WED		4832
12AUG18	-6 Days =	06	AUG 2018	3698	TUE		4961
12AUG18	-7 Days =	05	AUG 2018	3506	MON		5011
12AUG18	-8 Days =	04	AUG 2018	3318	SUN		5003
12AUG18	-9 Days =	03	AUG 2018	3139	SAT		5022
12AUG18	-10 Days =	02	AUG 2018	2966	FRI		4780
12AUG18	-11 Davs =	01	AUG 2018	2820	THU		4559
12AUG18	-12 Days =	31	JUI 2018	2710	WFD		4168
124UG18	-13 Days =	30	2018	2628	TUF		3764
		20					
Lake Okeech	obee Outle	ts Last 14	Days				
	5-77	Relow S-77	5-78	5-7	79		
	Discharge	Discharge	Dischar	oge Discha	arge		
					ΛΛΛΙ Ο Ρ<		
	(AC ET)	(ALL-DAT)					
	(AC-FI)	(AC-FI)	(AC-FI) (AC-1	101		
2 AUG 2018	2823	2633	322	.9 64	+24		
1 AUG 2018	3 2778	2662	-NR	- 62	244		
LØ AUG 2018	3098	3290	-NR	- 60	947		
09 AUG 2018	3886	4110	353	65 65	543		
08 AUG 2018	3827	3089	311	.5 56	943		
07 AUG 2018	3444	2637	205	i9 48	347		
06 AUG 2018	8 1228	1575	206	53 55	504		
5 AUG 2018	1186	1567	208	60 60	940		
04 AUG 2018	1170	1419	208	1 6 ³	377		
AUG 2018	1191	1256	237	'3 6 ³	387		
AUG 2010	2 100	056	205	2 01 2 7	778		
22 AUG 2010		01/	כשכ	1 // 1 01 01	500		
2018 2018 2018 21 2010	כ נ	914	208		שכנ		
OT JUL 2018	5	697	314	-/ 9:	190		
KA IIII 7018	5 4	/88	307	3 106	167		

			S-310	S-351	S-352	S-354	L8 Canal Pt
			Discharge	Discharge	Discharge	Discharge	Discharge
			(ALL DAY)				
	DATE	=	(AC-FT)	(AC-FT)	(AC-FT)	(AC-FT)	(AC-FT)
12	AUG	2018	20	2256	460	436	-62
11	AUG	2018	-13	2233	293	1053	-16
10	AUG	2018	12	2423	781	1717	-6

09	AUG	2018	54	2429	831	1666	-7
08	AUG	2018	110	2376	0	904	10
07	AUG	2018	70	1985	0	559	3
06	AUG	2018	10	1144	0	1430	6
05	AUG	2018	-14	938	0	1422	0
04	AUG	2018	-88	1116	0	1352	3
03	AUG	2018	-49	1328	0	462	7
02	AUG	2018	-41	2682	0	833	6
01	AUG	2018	-98	2272	0	1618	2
31	JUL	2018	-91	980	0	1178	-1
30	JUL	2018	-163	711	0	1168	1

			S-308	Below S-308	S-80
			Discharge	Discharge	Discharge
			(ALL DAY)	(ALL-DAY)	(ALL-DAY)
	DATE	=	(AC-FT)	(AC-FT)	(AC-FT)
12	AUG	2018	3	180	1048
11	AUG	2018	666	701	2127
10	AUG	2018	2403	2488	3087
09	AUG	2018	2706	2548	3387
08	AUG	2018	4435	4004	3789
07	AUG	2018	2930	3128	3555
06	AUG	2018	1102	1418	1762
05	AUG	2018	1	281	27
04	AUG	2018	713	949	713
03	AUG	2018	3024	3096	2671
02	AUG	2018	3644	3846	3128
01	AUG	2018	3650	4052	3905
31	JUL	2018	3264	3740	3852
30	JUL	2018	2038	2003	2211

*** NOTE: Discharge (ALL DAY) is computed using Spillway, Sector Gate and Lockages Discharges from 0015 hrs to 2400 hrs.

(I) - Flows preceeded by "I" signify an instantaneous flow computed from the single value reported for the day

* On 11 May 1999, Lake Okeechobee Elevation was switched from Instantaneous 2400 value to an average-daily lake average. On 14 Mar 2001, due to the isolation of various gages within the standard 10 stations, the average of the interior 4 station gages was used as the Lake Okeechobee Elevation. On 05 November 2010, Lake Okeechobee Elevation was switched to a 9 gage mix of interior and edge gages to obtain a more reliable representation of the lake level. On 09 May 2011, Lake Okeechobee Elevation was switched to a 8 gage mix of interior and edge gages to obtain a more reliable representation of the lake level. On 09 May 2011, Lake Okeechobee Elevation was switched to a 8 gage mix of interior and edge gages to obtain a more reliable representation of the lake level due to isolation of S135 from low lake levels. Today Lake Okechobee elevation is determined from the 4 Int & 4 Edge stations
++ For more information see the Jacksonville District Navigation website at http://www.saj.usace.army.mil/
\$ For information regarding Lake Okeechobee Service Area water restrictions

\$ For information regarding Lake Okeechobee Service Area water restrictions
please refer to www.sfwmd.gov

Report Generated 13AUG2018 @ 14:15 ** Preliminary Data - Subject to Revision **

Classification Tables

Supplemental Tables used in conjunction with the LORS2008 Release

Guidance Flow Charts

• Class Limits for Tributary Hydrologic Conditions

Table K-2 in the Lake Okeechobee Water Control Plan

<u>6-15 Day Precipitation Outlook Categories</u>

Table ?? in the Lake Okeechobee Water Control Plan

<u>Classification of Lake Okeechobee Net Inflow for Seasonal</u>

<u>Outlook</u>

 Table K-3 in the Lake Okeechobee Water Control Plan

• Classification of Lake Okeechobee Net Inflow for Multi-

Seasonal Outlook

 Table K-4 in the Lake Okeechobee Water Control Plan

Back to Lake Okeechobee Operations Main Page

Back to U.S. Army Corps of Engineers Lake Okeechobee Operations Homepage

Tributary Hydrologic	Palmer Index	2-wk Mean L.O. Net	
Classification*	Class Limits Inflow Class Lin		
Very Wet	3.0 or greater	Greater >= 6000 cfs	
Wet	1.5 to 2.99	2500 - 5999 cfs	
Near Normal	-1.49 to 1.49	500 - 2499 cfs	
Dry	-2.99 to -1.5	-5000 – 500 cfs	
Very Dry	-3.0 or less	Less than -5000 cfs	

* use the wettest of the two indicators

Classification of Lake Okeechobee Net Inflow Seasonal Outlook*

Lake Net Inflow Prediction	Equivalent Depth**	Lake Okeechobee	
[million acre-feet]	[feet]	Net Inflow	
		Seasonal Outlook	
> 0.93	> 2.0	Very Wet	
0.71 to 0.93	1.51 to 2.0	Wet	
0.35 to 0.70	0.75 to 1.5	Normal	
< 0.35	< 0.75	Dry	

**Volume-depth conversion based on average lake surface area of 467,000 acres

Classification of Lake Okeechobee Net Inflow Multi-Seasonal Outlook*

Lake Net Inflow Prediction	Equivalent Depth**	Lake Okeechobee Net Inflow	
[million acre-feet]	[feet]		
		Multi-Seasonal Outlook	
> 2.0	> 4.3	Very Wet	
1.18 to 2.0	2.51 to 4.3	Wet	
0.5 to 1.17	1.1 to 2.5	Normal	
< 0.5	< 1.1	Dry	

**Volume-depth conversion based on average lake surface area of 467,000 acres

6-15 Day Precipitation Outlook Categories*

6-15 Day Precipitation Outlook Categories	WSE Decision Tree Categories
Above Normal	Wet to Very Wet
Normal	Normal
Below Normal	Dry

* Corresponds to Table 7-6 in the Lake Okeechobee Water Control Plan

Under Construction