

Application of the Lake Okeechobee Regulation Schedule (LORS2008) on 9/3/2018 (ENSO Neutral Condition)

Lake Okeechobee Net Inflow Outlook:

The Lake Okeechobee Net Inflow Outlook has been computed using 4 methods: Croley's method¹, the SFWMD empirical method², a sub-sampling of Neutral years³ and a sub-sampling of warm years of the Atlantic Multi-decadal Oscillation (AMO) in combination with La Nina ENSO years⁴. The results for Croley's method and the SFWMD empirical method are based on the [CPC Outlook](#).

Table of the Lake Okeechobee Net Inflow Outlooks in feet of equivalent depth. All methods are updated on a weekly basis with observed net inflow for the current month.

Season	Croley's Method ^{1*}		SFWMD Empirical Method ²		Sub-sampling of ENSO Years ³		Sub-sampling of AMO Warm + ENSO Years ⁴	
	Value (ft)	Condition	Value (ft)	Condition	Value (ft)	Condition	Value (ft)	Condition
Current (Sep-Feb)	N/A	N/A	1.88	Wet	3.09	Very Wet	1.85	Wet
Multi Seasonal (Sep-Apr)	N/A	N/A	2.17	Normal	3.92	Wet	1.53	Normal

*Croley's Method Not Produced For This Report

See [Seasonal](#) and [Multi-Seasonal](#) tables for the classification of Lake Okeechobee Outlooks.

The recommended methods and values for estimating the Lake Okeechobee Net Inflow Outlook are shaded and should be used in the LORS2008 Release Guidance Flow Charts.

**Sub-sampling is a weighted average of ENSO conditions based on the ENSO forecast used.

[Tributary Hydrologic Conditions Graph:](#)

4260 cfs 14-day running average for Lake Okeechobee Net Inflow through 9/3/2018. According to the classification in [Tributary Hydrologic Conditions](#) table, this condition is Wet.

1.06 for Palmer Index on 9/1/2018.

According to the classification in [Tributary Hydrologic Conditions](#) table, this condition is Normal.

The wetter of the two conditions above is **Wet**.

[LORS2008 Classification Tables:](#)

Lake Okeechobee Stage on 9/3/2018

Lake Okeechobee Stage: **14.57 feet**

[USACE Report for Lake Okeechobee](#)

[Lake Okeechobee Stage Hydrograph](#)

Lake Okeechobee Management Zone/Band		Bottom Elevation (feet, NGVD)	Current Lake Stage
High Lake Management Band		16.44	
Operational Band	High sub-band	16.05	
	Intermediate sub-band	15.66	
	Low sub-band	13.88	← 14.57
Base Flow sub-band		12.61	
Beneficial Use sub-band		12.42	
Water Shortage Management Band			

[Part C of LORS2008: Discharge to WCA's](#)

Release Guidance Flow Chart Outcome: Up to maximum practicable releases to the WCAs if desirable or with minimum everglades impacts; otherwise no releases.

[Part D of LORS2008: Discharge to Tidewater](#)

Release Guidance Flow Chart Outcome: S-79 Up to 3000 cfs & S-80 Up to 1170 cfs.

[Back to Lake Okeechobee Operations Main Page](#)

[Back to U.S. Army Corps of Engineers Homepage](#)

LORS2008 Implementation on 9/3/2018 (ENSO Neutral Condition):

Water Supply Risk Evaluation

Status for week ending 9/03/2018:

District wide, Raindar rainfall was 1.96 inches for the week. Lake stage on 9/03/2018 was 14.57 ft, NGVD, up 0.04 ft from last week.


The updated August 2018 Mid-Month SFWMM Dynamic Position Analysis [percentile graph](#) for Lake Okeechobee show that the current lake stage is in the Low Sub-Band.

The 2008 LORS Tributary Hydrologic Condition (THC) is classified as **Wet**. The PDSI indicates normal conditions and the LONIN is wet. The THC classification is based on the wetter of the two [indices](#).

Area	Indicator	Value	Color Coded Scoring Scheme
LOK	Projected LOK Stage for the next two months	Low Sub Band	L
	Palmer Index for LOK Tributary Conditions	1.06 (Normal to Extremely Wet)	L
	CPC Precipitation Outlook	1 month: Above Normal	L
		3 months: Above Normal	L
	LOK Seasonal Net Inflow Outlook	3.09 ft	L
	ENSO Years	(Normal to Extremely Wet)	
	LOK Multi-Seasonal Net Inflow Outlook	3.92 ft (Wet)	L
ENSO Conditions			
WCAs	WCA 1: Station Average (Site 1-7, Site 1-8T, Site 1-9)	Above Line 1 (16.43 ft)	L
	WCA 2A: Site 2-17	Above Line 1 (13.26 ft)	L
	WCA-3A: 3 Station Average (Site 63, 64 and 65)	Above Line 1 (10.50 ft)	L
LEC	Service Area 1	Year-Round Irrigation Rule in effect	L
	Service Area 2	Year-Round Irrigation Rule in effect	L
	Service Area 3	Year-Round Irrigation Rule in effect	L

Note: The water supply risk classification based on the Palmer index, as well as the LOK seasonal and multi-seasonal net inflow outlooks use slightly different classification intervals than those used by the 2008-LORS.


Lake Okeechobee SFWMM Aug 2018 Mid-Month Position Analysis




(See assumptions on the Position Analysis Results website)

Tributary Basin Condition Indicators as of September 3 2018

Palmer Index



Lake Okeechobee Net Inflow (LONIN) 14-day Running Average



Tue Sep 04 09:44:44 EDT 2018

2008 LORS

Part C: Establish Allowable Lake Okeechobee Releases to the Water Conservation Areas




Figure 7-3

2008 LORS

Part D: Establish Allowable Lake Okeechobee Releases to Tide (Estuaries)

Note: This operational guidance provides essential supplementary information to be used in conjunction with other supporting documentation including text within the Water Control Plan.

When conducting Base Flow releases, flows can be distributed East and West up to 650 cfs as needed to minimize impacts or provide benefits through S-80 and S-79

Apply Meteorological Forecasts on a Weekly Basis; apply Seasonal and Multi-Seasonal Climate/Hydrologic Outlooks on a Monthly Basis





Figure 7-4

Lake Okeechobee Water Level History and Projected Stages



U. S. Army Corps of Engineers, Jacksonville District
 Lake Okeechobee and Vicinity Report
 ** Preliminary Data - Subject to Revision **

Data Ending 2400 hours 02 SEP 2018

Okeechobee Lake Regulation	Elevation	Last Year	2YRS Ago
	(ft-NGVD)	(ft-NGVD)	(ft-NGVD)
*Okeechobee Lake Elevation	14.57	13.63	14.97 (Official Elv)
Bottom of High Lake Mngmt=	16.44	Top of Water Short Mngmt=	12.42
Currently in Operational Management Band			

Simulated Average LORS2008 [1965-2000]	13.24
Difference from Average LORS2008	1.33

02SEP (1965-2007) Period of Record Average	14.25
Difference from POR Average	0.32

Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations

++Navigation Depth (Based on 2007 Channel Condition Survey) Route 1 ÷ 8.51'
 ++Navigation Depth (Based on 2008 Channel Condition Survey) Route 2 ÷ 6.71'
 Bridge Clearance = 49.74'

4 Interior and 4 Edge Okeechobee Lake Average (Avg-Daily values):

L001	L005	L006	LZ40	S4	S352	S308	S133
14.51	14.69	14.60	14.54	14.65	14.65	14.47	14.48

*Combination Okeechobee Avg-Daily Lake Average = 14.57
 (*See Note)

Okeechobee Inflows (cfs):

S65E	0	S65EX1	3356	Fisheating Cr	836
S154	0	S191	151	S135 Pumps	25
S84	585	S133 Pumps	90	S2 Pumps	0
S84X	308	S127 Pumps	0	S3 Pumps	0
S71	130	S129 Pumps	0	S4 Pumps	0
S72	0	S131 Pumps	0	C5	0
Total Inflows:	5481				

Okeechobee Outflows (cfs):

S135 Culverts	0	S354	226	S77	2305
S127 Culverts	0	S351	607	S308	-0
S129 Culverts	0	S352	271		
S131 Culverts	0	L8 Canal Pt	-2		
Total Outflows:	3407				

****S77 structure flow is being used to compute Total Outflow.
 ****S308 structure flow is being used to compute Total Outflow.

Okeechobee Pan Evaporation (inches):

S77 0.17 S308 0.00
 Average Pan Evap x 0.75 Pan Coefficient = 0.06" = 0.01'

Lake Average Precipitation using NEXRAD: = 0.31" = 0.03'

Evaporation - Precipitation: = -0.25" = -0.02'
 Evaporation - Precipitation using Lake Area of 730 square miles
 is equal to 4834 cfs into the lake.

Lake Okeechobee (Change in Storage) Flow is 0 cfs or 0 AC-FT

	Headwater Elevation (ft-msl)	Tailwater Elevation (ft-msl)	Disch (cfs)	----- Gate Positions -----							
				#1 (ft)	#2 (ft)	#3 (ft)	#4 (ft)	#5 (ft)	#6 (ft)	#7 (ft)	#8 (ft)
(I) see note at bottom											
North East Shore											
S133 Pumps:	13.32	14.46	90	31	50	12	0	0	(cfs)		
S193:											
S191:	18.43	14.46	151	0.5	0.0	0.5					
S135 Pumps:	13.34	14.46	25	0	0	0	25		(cfs)		
S135 Culverts:			0	0.0	0.0						
North West Shore											
S65E:	20.81	14.52	0	0.0	0.0	0.0	0.0	0.0	0.0		
S65EX1:	20.81	14.52	3356								
S127 Pumps:	13.39	14.52	0	0	0	0	0	0	(cfs)		
S127 Culvert:			0	0.0							
S129 Pumps:	12.90	14.65	0	0	0	0			(cfs)		
S129 Culvert:			0	0.0							
S131 Pumps:	12.87	14.70	0	0	0				(cfs)		
S131 Culvert:			0								
Fisheating Creek											
nr Palmdale		32.76	836								
nr Lakeport											
C5:		-NR-	0	-NR-	-NR-	-NR-					
South Shore											
S4 Pumps:	10.83	14.66	0	0	0	0			(cfs)		
S169:	14.66	10.81	0	0.0	0.0	0.0					
S310:	14.57		-54								
S3 Pumps:	9.97	14.64	0	0	0	0			(cfs)		
S354:	14.64	9.97	226	0.0	0.0						
S2 Pumps:	9.77	14.63	0	0	0	0	0		(cfs)		
S351:	14.63	9.77	607	0.0	0.0	0.0					
S352:	14.74	9.26	271	0.0	0.0						
C10A:	-NR-	14.19		8.0	8.0	8.0	0.0	0.0			
L8 Canal PT		14.03	-2								

S351 and S352 Temporary Pumps/S354 Spillway

S351:	9.77	14.63	607	-NR--NR--NR--NR--NR--NR-
S352:	9.26	14.74	271	-NR--NR--NR--NR-
S354:	9.97	14.64	226	-NR--NR--NR--NR-

Caloosahatchee River (S77, S78, S79)

S47B:	12.56	11.53		0.0	0.0
S47D:	10.74	10.75	-44	6.5	

S77:

Spillway and Sector Flow:							
	14.60	10.65	2304	3.0	3.0	3.0	0.0
Flow Due to Lockages+:			1				

S78:

Spillway and Sector Flow:							
	10.48	3.17	2564	0.0	2.5	3.0	2.5
Flow Due to Lockages+:			4				

S79:

Spillway and Sector Flow:											
	3.18	1.59	4073	1.0	1.0	2.0	2.0	2.0	2.0	2.0	2.0
Flow Due to Lockages+:			9								
Percent of flow from S77			57%								
Chloride (ppm)			50								

St. Lucie Canal (S308, S80)

S308:

Spillway and Sector Flow:							
	14.53	13.76	0	0.0	0.0	0.0	0.0
Flow Due to Lockages+:			-0				

S153:	18.75	13.59	69	0.0	0.0
-------	-------	-------	----	-----	-----

S80:

Spillway and Sector Flow:								
	13.67	0.51	482	0.0	2.5	0.0	0.0	2.5
Flow Due to Lockages+:			14					
Percent of flow from S308			0%					

Steele Point Top Salinity (mg/ml) ****
 Steele Point Bottom Salinity (mg/ml) ****

Speedy Point Top Salinity (mg/ml) 3616
 Speedy Point Bottom Salinity (mg/ml) 4110

+ Flow Due to lockages is computed utilizing average daily headwater and tailwater along with total number of lockages for the day to calculate a volume which is then converted to an average discharge in cfs.

Daily Precipitation Totals	1-Day (inches)	3-Day (inches)	7-Day (inches)	----- Wind ----- Direction Speed (DegØ) (mph)
S133 Pump Station:	-NR-	0.00	0.00	
S193:	-NR-	0.00	0.00	-NR- -NR-
Okeechobee Field Station:	-NR-	0.00	0.00	
S135 Pump Station:	-NR-	0.00	0.00	
S127 Pump Station:	-NR-	0.00	0.00	
S129 Pump Station:	-NR-	0.00	0.00	

S131 Pump Station:	-NR-	0.00	0.00		
S77:	13.03	13.03	13.14	37	4
S78:	0.90	0.90	1.76	72	1
S79:	-12.38	-12.26	-11.71	270	0
S4 Pump Station:	-NR-	0.00	0.00		
Clewiston Field Station:	-NR-	0.00	0.00		
S3 Pump Station:	-NR-	0.00	0.00		
S2 Pump Station:	-NR-	0.00	0.00		
S308:	1.14	1.14	1.39	70	5
S80:	0.00	0.00	0.00	150	2
Okeechobee Average (Sites S78, S79 and S80 not included)	7.09	1.09	1.12		

Oke Nexrad Basin Avg	0.31	0.38	1.75		
----------------------	------	------	------	--	--

Okeechobee Lake Elevations	02 SEP 2018	14.57	Difference from 02SEP18
02SEP18 -1 Day =	01 SEP 2018	14.57	0.00
02SEP18 -2 Days =	31 AUG 2018	14.58	0.01
02SEP18 -3 Days =	30 AUG 2018	14.60	0.03
02SEP18 -4 Days =	29 AUG 2018	14.60	0.03
02SEP18 -5 Days =	28 AUG 2018	14.58	0.01
02SEP18 -6 Days =	27 AUG 2018	14.54	-0.03
02SEP18 -7 Days =	26 AUG 2018	14.53	-0.04
02SEP18 -30 Days =	03 AUG 2018	14.38	-0.19
02SEP18 -1 Year =	02 SEP 2017	13.63	-0.94
02SEP18 -2 Year =	02 SEP 2016	14.97	0.40

Long Term Mean 30day Aaverage ET for Lake Alfred (Inches) = 4.30

Lake Okeechobee Net Inflow (LONIN)				
Average Flow over the previous 14 days				Avg-Daily Flow
02SEP18	Today =	02 SEP 2018	4223 MON	3408
02SEP18	-1 Day =	01 SEP 2018	4332 SUN	2063
02SEP18	-2 Days =	31 AUG 2018	4572 SAT	1069
02SEP18	-3 Days =	30 AUG 2018	4608 FRI	5586
02SEP18	-4 Days =	29 AUG 2018	4458 THU	9110
02SEP18	-5 Days =	28 AUG 2018	4033 WED	13362
02SEP18	-6 Days =	27 AUG 2018	3826 TUE	6760
02SEP18	-7 Days =	26 AUG 2018	3888 MON	3240
02SEP18	-8 Days =	25 AUG 2018	4177 SUN	1907
02SEP18	-9 Days =	24 AUG 2018	4607 SAT	3080
02SEP18	-10 Days =	23 AUG 2018	5238 FRI	2508
02SEP18	-11 Days =	22 AUG 2018	5490 THU	322
02SEP18	-12 Days =	21 AUG 2018	6087 WED	3716
02SEP18	-13 Days =	20 AUG 2018	7013 TUE	2987

S65E				
Average Flow over previous 14 days				Avg-Daily Flow
02SEP18	Today=	02 SEP 2018	4 MON	0
02SEP18	-1 Day =	01 SEP 2018	4 SUN	0
02SEP18	-2 Days =	31 AUG 2018	4 SAT	0
02SEP18	-3 Days =	30 AUG 2018	4 FRI	0
02SEP18	-4 Days =	29 AUG 2018	4 THU	51
02SEP18	-5 Days =	28 AUG 2018	0 WED	0

02SEP18	-6 Days =	27 AUG 2018	0	TUE		0
02SEP18	-7 Days =	26 AUG 2018	0	MON		0
02SEP18	-8 Days =	25 AUG 2018	0	SUN		0
02SEP18	-9 Days =	24 AUG 2018	0	SAT		0
02SEP18	-10 Days =	23 AUG 2018	0	FRI		0
02SEP18	-11 Days =	22 AUG 2018	0	THU		0
02SEP18	-12 Days =	21 AUG 2018	0	WED		0
02SEP18	-13 Days =	20 AUG 2018	0	TUE		0

S65EX1

		Average Flow over previous 14 days			Avg-Daily Flow	
02SEP18	Today=	02 SEP 2018	3056	MON		3356
02SEP18	-1 Day =	01 SEP 2018	3110	SUN		2942
02SEP18	-2 Days =	31 AUG 2018	3182	SAT		3127
02SEP18	-3 Days =	30 AUG 2018	3249	FRI		2675
02SEP18	-4 Days =	29 AUG 2018	3358	THU		2737
02SEP18	-5 Days =	28 AUG 2018	3478	WED		2725
02SEP18	-6 Days =	27 AUG 2018	3619	TUE		2640
02SEP18	-7 Days =	26 AUG 2018	3779	MON		2659
02SEP18	-8 Days =	25 AUG 2018	3935	SUN		2699
02SEP18	-9 Days =	24 AUG 2018	4090	SAT		2953
02SEP18	-10 Days =	23 AUG 2018	4223	FRI		3196
02SEP18	-11 Days =	22 AUG 2018	4337	THU		3390
02SEP18	-12 Days =	21 AUG 2018	4436	WED		3751
02SEP18	-13 Days =	20 AUG 2018	4513	TUE		3939

Lake Okeechobee Outlets Last 14 Days

DATE	S-77 Discharge (ALL DAY) (AC-FT)	Below S-77 Discharge (ALL-DAY) (AC-FT)	S-78 Discharge (ALL DAY) (AC-FT)	S-79 Discharge (ALL DAY) (AC-FT)	
02 SEP 2018	4568	4001	5090	8068	
01 SEP 2018	4611	4320	5409	9885	
31 AUG 2018	4473	4169	6278	10578	
30 AUG 2018	4355	4482	6536	11416	
29 AUG 2018	4253	4407	6598	10981	
28 AUG 2018	4165	4356	6671	10845	
27 AUG 2018	4055	4256	6734	10512	
26 AUG 2018	4102	3950	6287	10264	
25 AUG 2018	4035	3806	5913	9470	
24 AUG 2018	3442	3340	5057	9623	
23 AUG 2018	1787	1794	3115	6501	
22 AUG 2018	1891	2036	3190	6711	
21 AUG 2018	2276	2414	3210	6662	
20 AUG 2018	2173	2467	3182	6638	

DATE	S-310 Discharge (ALL DAY) (AC-FT)	S-351 Discharge (ALL DAY) (AC-FT)	S-352 Discharge (ALL DAY) (AC-FT)	S-354 Discharge (ALL DAY) (AC-FT)	L8 Canal Pt Discharge (ALL DAY) (AC-FT)
02 SEP 2018	-107	1203	486	432	-3
01 SEP 2018	-96	1651	876	125	4
31 AUG 2018	-242	1668	829	186	5
30 AUG 2018	-314	1669	650	254	1
29 AUG 2018	-300	1102	242	0	7
28 AUG 2018	-340	1561	736	0	-0

27 AUG 2018	-359	2069	589	700	-3
26 AUG 2018	-187	1999	510	894	10
25 AUG 2018	-15	1192	385	1253	9
24 AUG 2018	51	2293	740	1267	9
23 AUG 2018	99	1919	805	1273	-4
22 AUG 2018	74	1563	639	1222	3
21 AUG 2018	-33	1111	379	974	-3
20 AUG 2018	-14	783	3	1279	-2

DATE	S-308 Discharge (ALL DAY) (AC-FT)	Below S-308 Discharge (ALL-DAY) (AC-FT)	S-80 Discharge (ALL-DAY) (AC-FT)
02 SEP 2018	-0	-27	1014
01 SEP 2018	881	1037	958
31 AUG 2018	3232	3064	3548
30 AUG 2018	4054	3759	4386
29 AUG 2018	4040	4347	4994
28 AUG 2018	3050	3412	4675
27 AUG 2018	1299	1222	2269
26 AUG 2018	1736	1733	886
25 AUG 2018	623	927	3107
24 AUG 2018	2166	2175	3239
23 AUG 2018	3015	3272	3560
22 AUG 2018	3389	3740	4049
21 AUG 2018	2333	2350	3676
20 AUG 2018	1361	1666	1925

*** NOTE: Discharge (ALL DAY) is computed using Spillway, Sector Gate and Lockages Discharges from 0015 hrs to 2400 hrs.

(I) - Flows preceded by "I" signify an instantaneous flow computed from the single value reported for the day

* On 11 May 1999, Lake Okeechobee Elevation was switched from Instantaneous 2400 value to an average-daily lake average. On 14 Mar 2001, due to the isolation of various gages within the standard 10 stations, the average of the interior 4 station gages was used as the Lake Okeechobee Elevation. On 05 November 2010, Lake Okeechobee Elevation was switched to a 9 gage mix of interior and edge gages to obtain a more reliable representation of the lake level. On 09 May 2011, Lake Okeechobee Elevation was switched to a 8 gage mix of interior and edge gages to obtain a more reliable representation of the lake level due to isolation of S135 from low lake levels. Today Lake Okechobee elevation is determined from the 4 Int & 4 Edge stations


++ For more information see the Jacksonville District Navigation website at <http://www.saj.usace.army.mil/>

\$ For information regarding Lake Okeechobee Service Area water restrictions please refer to www.sfwmd.gov

Report Generated 03SEP2018 @ 23:38 ** Preliminary Data - Subject to Revision **

Lake Okeechobee

04SEP18 09:17:21



- High Lake Management
- Okeechobee Avg Elev
- Average Elev [1965-2007]
- Water Shortage Management

Classification Tables

Supplemental Tables used in conjunction with the LORS2008 Release

Guidance Flow Charts

- [Class Limits for Tributary Hydrologic Conditions](#)

Table K-2 in the Lake Okeechobee Water Control Plan

- [6-15 Day Precipitation Outlook Categories](#)

Table ?? in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Seasonal Outlook](#)

Table K-3 in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Multi-Seasonal Outlook](#)

Table K-4 in the Lake Okeechobee Water Control Plan

[Back to Lake Okeechobee Operations Main Page](#)

[Back to U.S. Army Corps of Engineers Lake Okeechobee Operations Homepage](#)

Tributary Hydrologic Classification*	Palmer Index Class Limits	2-wk Mean L.O. Net Inflow Class Limits
Very Wet	3.0 or greater	Greater \geq 6000 cfs
Wet	1.5 to 2.99	2500 - 5999 cfs
Near Normal	-1.49 to 1.49	500 - 2499 cfs
Dry	-2.99 to -1.5	-5000 – 500 cfs
Very Dry	-3.0 or less	Less than -5000 cfs

* use the wettest of the two indicators

Classification of Lake Okeechobee Net Inflow Seasonal Outlook*

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth** [feet]	Lake Okeechobee Net Inflow Seasonal Outlook
> 0.93	> 2.0	Very Wet
0.71 to 0.93	1.51 to 2.0	Wet
0.35 to 0.70	0.75 to 1.5	Normal
< 0.35	< 0.75	Dry

****Volume-depth conversion based on average lake surface area of 467,000 acres**

Classification of Lake Okeechobee Net Inflow Multi-Seasonal Outlook*

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth** [feet]	Lake Okeechobee Net Inflow Multi-Seasonal Outlook
> 2.0	> 4.3	Very Wet
1.18 to 2.0	2.51 to 4.3	Wet
0.5 to 1.17	1.1 to 2.5	Normal
< 0.5	< 1.1	Dry

****Volume-depth conversion based on average lake surface area of 467,000 acres**

6-15 Day Precipitation Outlook Categories*

6-15 Day Precipitation Outlook Categories	WSE Decision Tree Categories
Above Normal	Wet to Very Wet
Normal	Normal
Below Normal	Dry

* Corresponds to Table 7-6 in the Lake Okeechobee Water Control Plan

Under Construction