

Application of the Lake Okeechobee Regulation Schedule (LORS2008) on 05/18/2020 (ENSO Neutral Condition)

Lake Okeechobee Net Inflow Outlook:

The Lake Okeechobee Net Inflow Outlook has been computed using 4 methods: Croley's method¹, the SFWMD empirical method², a sub-sampling of Neutral years³ and a sub-sampling of warm years of the Atlantic Multi-decadal Oscillation (AMO) in combination with La Nina ENSO years⁴. The results for Croley's method and the SFWMD empirical method are based on the CPC Outlook.

Table of the Lake Okeechobee Net Inflow Outlooks in feet of equivalent depth. All methods are updated on a weekly basis with observed net inflow for the current month.

Season	Croley's Method ^{1*}		SFWMD Empirical Method ²		Sub-sampling of Neutral ENSO Years ³		Sub-sampling of AMO Warm + Neutral ENSO Years ⁴	
	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>
Current (May-Oct)	N/A	N/A	2.34	Very Wet	2.54	Very Wet	3.75	Very Wet
Multi Seasonal (May-Apr)	N/A	N/A	3.01	Wet	2.90	Wet	5.60	Very Wet

***Croley's Method Not Produced for This Report**

See Seasonal and Multi-Seasonal tables for the classification of Lake Okeechobee Outlooks.

The recommended methods and values for estimating the Lake Okeechobee Net Inflow Outlook are shaded and should be used in the LORS2008 Release Guidance Flow Charts.

****Sub-sampling is a weighted average of ENSO conditions based on the ENSO forecast used.**

Tributary Hydrologic Conditions Graph:

-2424 cfs 14-day running average for Lake Okeechobee Net Inflow through 05/18/2020. According to the classification in Tributary Hydrologic Conditions table, this condition is Dry.

-2.72 for Palmer Drought Index on 05/16/2020. According to the classification in Tributary Hydrologic Conditions table, this condition is Dry.

The wetter of the two conditions above is **Dry**.

LORS2008 Classification Tables:

Lake Okeechobee Stage on 05/18/2020

Lake Okeechobee Stage: **11.00 feet**

Lake Okeechobee Management Zone/Band		Bottom Elevation (feet, NGVD)	Current Lake Stage
High Lake Management Band		16.31	
Operational Band	High sub-band	15.75	
	Intermediate sub-band	15.11	
	Low sub-band	13.15	
Base Flow sub-band		12.60	
Beneficial Use sub-band		10.70	← 11.00 ft
Water Shortage Management Band			

Part C and Part D of LORS2008:

With Lake Okeechobee stage below the Base-Flow Sub-Band, Part C **nor** Part D of the 2008 LORS suggest releases to the WCAs or Estuaries required to manage lake stages.

Adaptive Protocol's Release Guidance: Caloosahatchee Estuary

The SFWMD's Lake Okeechobee Adaptive Protocol's Release Guidance suggests no S-77 release to the Caloosahatchee Estuary unless the Governing Board recommends otherwise.

LORS2008 Implementation on 05/18/2020 (ENSO Neutral Condition):


Status for week ending 05/18/2020:

Water Supply Risk Evaluation

Area	Indicator	Value	Color Coded Scoring Scheme
LOK	Projected LOK Stage for the next two months	Beneficial Use Sub band	M
	Palmer Index for LOK Tributary Conditions	-2.72 (Extremely Dry)	H
	CPC Precipitation Outlook	1 month: Above Normal	L
		3 months: Above Normal	L
	LOK Seasonal Net Inflow Outlook	2.54 ft	L
	ENSO Forecast (positive)	Normal to Extremely wet	
	LOK Multi-Seasonal Net Inflow Outlook	2.90 ft	M
	ENSO Forecast (positive)	Normal	
WCAs	WCA 1: Site 1-8C	Above Line 1 (15.67 ft)	L
	WCA 2A: Site S-11B	Below Line 2 (10.04 ft)	H
	WCA-3A: S-333 HW	Line 1 – Line 2 (7.62 ft on May 17, 2020)	M
LEC	Service Area 1	Year-Round Irrigation Rule in effect	L
	Service Area 2	Year-Round Irrigation Rule in effect	L
	Service Area 3	Year-Round Irrigation Rule in effect	L

Note: The water supply risk classification based on the Palmer index, as well as the LOK seasonal and multi-seasonal net inflow outlooks use slightly different classification intervals than those used by the 2008-LORS.


Lake Okeechobee SFWMM May 2020 Position Analysis




(See assumptions on the Position Analysis Results website)

Tributary Basin Condition Indicators as of May 18 2020

Palmer Index




Lake Okeechobee Net Inflow (LONIN) 14-day Running Average



Wed May 20 13:39:08 EDT 2020

Flowchart to Guide Recommendations for Lake Okeechobee Releases to the Caloosahatchee Estuary for 2008 LORS Baseflow & for Environmental Water Supply (revised 9-Aug-2012)



¹The 2008 LORS Release Guidance (Part D) can suggest baseflow releases in the Intermediate, Low, or Baseflow Subbands.

²Estuary "needs" water when the 30-day moving average salinity at I-75 bridge is projected to exceed 5 practical salinity units (psu) within 2 weeks.

³LOWSM = Lake Okeechobee Water Shortage Management.


⁴Tributary Hydrologic Condition (THC) is based on classification of Lake Okeechobee Net Inflow and Palmer Index.

⁵Can release less than the "up to" limit if lower release is sufficient to reach or sustain desired estuary salinity; cfs = cubic feet per second.

⁶After reviewing conditions in Water Conservation Areas (WCAs), Stormwater Treatment Areas (STAs), ENP, St. Lucie Estuary and Lake Okeechobee.

⁷Should this condition be reached, the Governing Board will be briefed at their next regularly scheduled meeting as part of the State of the Water Resources agenda item.

Lake Okeechobee Water Level History and Projected Stages



U. S. Army Corps of Engineers, Jacksonville District
Lake Okeechobee and Vicinity Report
** Preliminary Data - Subject to Revision **

Data Ending 2400 hours 17 MAY 2020

Okeechobee Lake Regulation	Elevation (ft-NGVD)	Last Year (ft-NGVD)	2YRS Ago (ft-NGVD)
*Okeechobee Lake Elevation	-NR-	11.25	13.29 (Official Elv)
Bottom of High Lake Mngmt=	16.31	Top of Water Short Mngmt=	10.70
Currently in Water Shortage Management Band			

Simulated Average LORS2008 [1965-2000] 12.07
Difference from Average LORS2008 -NR-

17MAY (1965-2007) Period of Record Average 13.25
Difference from POR Average -NR-

Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations

++Navigation Depth (Based on 2007 Channel Condition Survey) Route 1 ÷ -NR-'
++Navigation Depth (Based on 2008 Channel Condition Survey) Route 2 ÷ -NR-'
Bridge Clearance = 52.50'

4 Interior and 4 Edge Okeechobee Lake Average (Avg-Daily values):

L001	L005	L006	LZ40	S4	S352	S308	S133
-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	10.98	-NR-

*Combination Okeechobee Avg-Daily Lake Average = -NR-
(*See Note)

Okeechobee Inflows (cfs):

S65E	-NR-	S65EX1	-NR-	Fisheating Cr	-NR-
S154	-NR-	S191	-NR-	S135 Pumps	-NR-
S84	-NR-	S133 Pumps	-NR-	S2 Pumps	-NR-
S84X	-NR-	S127 Pumps	-NR-	S3 Pumps	-NR-
S71	-NR-	S129 Pumps	-NR-	S4 Pumps	-NR-
S72	-NR-	S131 Pumps	-NR-	C5	0

Total Inflows: No Report Due To Missing S65E Discharge Data

Okeechobee Outflows (cfs):

S135 Culverts	-NR-	S354	-NR-	S77	-NR-
S127 Culverts	-NR-	S351	-NR-	S308	-NR-
S129 Culverts	-NR-	S352	-NR-		
S131 Culverts	-NR-	L8 Canal Pt	-16		

Total Outflows: No Report Due To Missing S77 or S308 Discharge Data

****S77 below flow meter is being used to compute Total Outflow.
****S308 below flow meter is being used to compute Total Outflow.

Okeechobee Pan Evaporation (inches):

S77	0.24	S308	0.26
Average Pan Evap x 0.75 Pan Coefficient = 0.19" = 0.02'			

Lake Average Precipitation using NEXRAD: = 0.18" = 0.02'

Evaporation - Precipitation: = 0.01" = 0.00'
 Evaporation - Precipitation using Lake Area of 730 square miles
 is equal to 147 cfs out of the lake.
 Lake Okeechobee (Change in Storage) Flow is -NR- cfs or -NR- AC-FT

Headwater Tailwater		Disch	----- Gate Positions -----							
Elevation (ft-msl)	Elevation (ft-msl)		#1	#2	#3	#4	#5	#6	#7	#8
		(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)
(I) see note at bottom										
North East Shore										
S133 Pumps: _____	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	(cfs)	
S193: _____										
S191: _____	-NR-	-NR-	-NR-	-NR-	-NR-					
S135 Pumps: _____	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-			(cfs)	
S135 Culverts: _____		-NR-	-NR-	-NR-						
North West Shore										
S65E: _____	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-		
S65EX1: _____	-NR-	-NR-								
S127 Pumps: _____	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	(cfs)	
S127 Culvert: _____		-NR-	-NR-							
S129 Pumps: _____	-NR-	-NR-	-NR-	-NR-	-NR-				(cfs)	
S129 Culvert: _____		-NR-	-NR-							
S131 Pumps: _____	-NR-	-NR-	-NR-	-NR-					(cfs)	
S131 Culvert: _____		-NR-								
Fisheating Creek										
nr Palmdale	_____	-NR-								
nr Lakeport	_____									
C5: _____	-NR-	0	-NR-	-NR-	-NR-					
South Shore										
S4 Pumps: _____	-NR-	-NR-	-NR-	-NR-	-NR-				(cfs)	
S169: _____	-NR-	-NR-	-NR-	-NR-	-NR-					
S310: 10.98		-NR-								
S3 Pumps: _____	-NR-	-NR-	-NR-	-NR-	-NR-				(cfs)	
S354: -NR-	_____	-NR-	-NR-	-NR-						
S2 Pumps: _____	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-			(cfs)	
S351: -NR-	_____	-NR-	-NR-	-NR-	-NR-					
S352: _____	-NR-	-NR-	-NR-	-NR-						
C10A: -NR-	-NR-		8.0	8.0	8.0	0.0	0.0			
L8 Canal PT	10.97	-16								

S351 and S352 Temporary Pumps/S354 Spillway

S351: _____	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-		
S352: -NR-	_____	-NR-	-NR-	-NR-	-NR-	-NR-				
S354: _____	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-				

Caloosahatchee River (S77, S78, S79)

S47B: _____	-NR-		-NR-	-NR-						
S47D: _____	-NR-	-NR-	-NR-							

S77:

Spillway and Sector Preferred Flow:

10.80 10.66 -NR- 4.5 4.5 4.5 0.0
Flow Due to Lockages+: -NR-

S78:

Spillway and Sector Flow:

10.62 3.37 -NR- 0.5 0.0 0.0 1.2
Flow Due to Lockages+: -NR-

S79:

Spillway and Sector Flow:

3.50 1.50 -NR- 1.0 1.0 1.0 1.0 0.0 0.0 0.0 0.0
Flow Due to Lockages+: -NR-
Percent of flow from S77 -NR-%
Chloride (ppm) 0

St. Lucie Canal (S308, S80)

S308:

Spillway and Sector Preferred Flow:

10.91 11.00 -NR- 3.0 3.0 3.0 3.0
Flow Due to Lockages+: -NR-

S153: -NR- -NR- -NR- -NR-

S80:

Spillway and Sector Flow:

11.11 0.96 -NR- 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Flow Due to Lockages+: -NR-
Percent of flow from S308 -NR-%

Steele Point Top Salinity (mg/ml) ****

Steele Point Bottom Salinity (mg/ml) ****

Speedy Point Top Salinity (mg/ml) ****

Speedy Point Bottom Salinity (mg/ml) ****

+ Flow Due to lockages is computed utilizing average daily headwater and tailwater along with total number of lockages for the day to calculate a volume which is then converted to an average discharge in cfs.

++ Preferred flow is determined from either the spillway discharge or the below flow meter daily

	1-Day	3-Day	7-Day	Direction	Wind
Daily Precipitation Totals	(inches)	(inches)	(inches)	(DegØ)	Speed (mph)
S133 Pump Station:	-NR-	0.00	0.00		
S193:	-NR-	0.00	0.00	-NR-	-NR-
Okeechobee Field Station:	-NR-	0.00	0.00		
S135 Pump Station:	-NR-	0.00	0.00		
S127 Pump Station:	-NR-	0.00	0.00		
S129 Pump Station:	-NR-	0.00	0.00		
S131 Pump Station:	-NR-	0.00	0.00		
S77:	18.86	38.01	38.01	157	1
S78:	3.00	6.55	6.55	176	1
S79:	5.16	10.42	10.42	92	2
S4 Pump Station:	-NR-	0.00	0.00		
Clewiston Field Station:	-NR-	0.00	0.00		
S3 Pump Station:	-NR-	0.00	0.00		
S2 Pump Station:	-NR-	0.00	0.00		
S308:	46.60	93.48	93.48	122	4
S80:	9.30	19.58	19.58	224	1
Okeechobee Average	32.73	10.11	10.11		

(Sites S78, S79 and S80 not included)

Oke Nexrad Basin Avg 0.18 0.52 0.52

Okeechobee Lake Elevations	17 MAY 2020	-NR-	Difference from 17MAY20
17MAY20 -1 Day =	16 MAY 2020	-NR-	-NR-
17MAY20 -2 Days =	15 MAY 2020	-NR-	-NR-
17MAY20 -3 Days =	14 MAY 2020	11.03	-NR-
17MAY20 -4 Days =	13 MAY 2020	11.08	-NR-
17MAY20 -5 Days =	12 MAY 2020	11.14	-NR-
17MAY20 -6 Days =	11 MAY 2020	11.17	-NR-
17MAY20 -7 Days =	10 MAY 2020	11.20	-NR-
17MAY20 -30 Days =	17 APR 2020	11.34	-NR-
17MAY20 -1 Year =	17 MAY 2019	11.25	-NR-
17MAY20 -2 Year =	17 MAY 2018	13.29	-NR-

Long Term Mean 30day Avearge ET for Lake Alfred (Inches) = -NR-

Lake Okeechobee Net Inflow (LONIN)					
Average Flow over the previous 14 days					Avg-Daily Flow
17MAY20	Today =	17 MAY 2020	-3211	MON	-NR-
17MAY20	-1 Day =	16 MAY 2020	-3108	SUN	-NR-
17MAY20	-2 Days =	15 MAY 2020	-3050	SAT	-NR-
17MAY20	-3 Days =	14 MAY 2020	-2866	FRI	-4709
17MAY20	-4 Days =	13 MAY 2020	-2345	THU	-5786
17MAY20	-5 Days =	12 MAY 2020	-1972	WED	-718
17MAY20	-6 Days =	11 MAY 2020	-2152	TUE	-1756
17MAY20	-7 Days =	10 MAY 2020	-1897	MON	-2714
17MAY20	-8 Days =	09 MAY 2020	-628	SUN	-1378
17MAY20	-9 Days =	08 MAY 2020	62	SAT	-2961
17MAY20	-10 Days =	07 MAY 2020	5	FRI	-5818
17MAY20	-11 Days =	06 MAY 2020	408	THU	-4338
17MAY20	-12 Days =	05 MAY 2020	390	WED	-4133
17MAY20	-13 Days =	04 MAY 2020	579	TUE	-1007

S65E					
Average Flow over previous 14 days					Avg-Daily Flow
17MAY20	Today=	17 MAY 2020	422	MON	-NR-
17MAY20	-1 Day =	16 MAY 2020	441	SUN	-NR-
17MAY20	-2 Days =	15 MAY 2020	448	SAT	-NR-
17MAY20	-3 Days =	14 MAY 2020	454	FRI	87
17MAY20	-4 Days =	13 MAY 2020	485	THU	372
17MAY20	-5 Days =	12 MAY 2020	496	WED	298
17MAY20	-6 Days =	11 MAY 2020	510	TUE	390
17MAY20	-7 Days =	10 MAY 2020	512	MON	474
17MAY20	-8 Days =	09 MAY 2020	502	SUN	326
17MAY20	-9 Days =	08 MAY 2020	515	SAT	316
17MAY20	-10 Days =	07 MAY 2020	516	FRI	473
17MAY20	-11 Days =	06 MAY 2020	500	THU	447
17MAY20	-12 Days =	05 MAY 2020	490	WED	680
17MAY20	-13 Days =	04 MAY 2020	464	TUE	779

S65EX1					
Average Flow over previous 14 days					Avg-Daily Flow
17MAY20	Today=	17 MAY 2020	213	MON	-NR-
17MAY20	-1 Day =	16 MAY 2020	202	SUN	-NR-
17MAY20	-2 Days =	15 MAY 2020	204	SAT	-NR-

17MAY20	-3 Days =	14 MAY 2020	205	FRI		227
17MAY20	-4 Days =	13 MAY 2020	204	THU		207
17MAY20	-5 Days =	12 MAY 2020	205	WED		263
17MAY20	-6 Days =	11 MAY 2020	205	TUE		329
17MAY20	-7 Days =	10 MAY 2020	207	MON		393
17MAY20	-8 Days =	09 MAY 2020	196	SUN		280
17MAY20	-9 Days =	08 MAY 2020	194	SAT		277
17MAY20	-10 Days =	07 MAY 2020	191	FRI		210
17MAY20	-11 Days =	06 MAY 2020	186	THU		152
17MAY20	-12 Days =	05 MAY 2020	188	WED		0
17MAY20	-13 Days =	04 MAY 2020	188	TUE		0

Lake Okeechobee Outlets Last 14 Days

	S-77	Below S-77	S-78	S-79	
	Discharge	Discharge	Discharge	Discharge	
	(ALL DAY)	(ALL-DAY)	(ALL DAY)	(ALL DAY)	
DATE	(AC-FT)	(AC-FT)	(AC-FT)	(AC-FT)	
17 MAY 2020	-NR-	-NR-	-NR-	-NR-	
16 MAY 2020	1218	1303	1258	1195	
15 MAY 2020	1676	1924	1289	1003	
14 MAY 2020	2143	2455	1308	1277	
13 MAY 2020	2416	2736	1447	1231	
12 MAY 2020	2241	2736	1578	1275	
11 MAY 2020	1496	1660	1135	940	
10 MAY 2020	0	245	314	292	
09 MAY 2020	834	681	256	17	
08 MAY 2020	763	839	36	109	
07 MAY 2020	1741	1794	218	17	
06 MAY 2020	1275	1296	854	268	
05 MAY 2020	1289	1410	621	1010	
04 MAY 2020	1615	1682	766	1425	

	S-310	S-351	S-352	S-354	L8 Canal Pt
	Discharge	Discharge	Discharge	Discharge	Discharge
	(ALL DAY)	(ALL DAY)	(ALL DAY)	(ALL DAY)	(ALL DAY)
DATE	(AC-FT)	(AC-FT)	(AC-FT)	(AC-FT)	(AC-FT)
17 MAY 2020	-NR-	-NR-	-NR-	-NR-	-31
16 MAY 2020	143	-NR-	-NR-	-NR-	64
15 MAY 2020	92	-NR-	-NR-	-NR-	59
14 MAY 2020	237	3950	984	1523	48
13 MAY 2020	429	4008	1122	2158	23
12 MAY 2020	338	3276	1155	2195	72
11 MAY 2020	197	2455	1269	1758	69
10 MAY 2020	19	718	450	557	87
09 MAY 2020	80	0	0	0	70
08 MAY 2020	-16	0	0	0	-20
07 MAY 2020	395	504	248	277	99
06 MAY 2020	307	1985	975	843	129
05 MAY 2020	376	2072	1189	1109	46
04 MAY 2020	255	1411	840	1024	41

	S-308	Below S-308	S-80
	Discharge	Discharge	Discharge
	(ALL DAY)	(ALL-DAY)	(ALL-DAY)
DATE	(AC-FT)	(AC-FT)	(AC-FT)
17 MAY 2020	-NR-	-NR-	-NR-
16 MAY 2020	-1587	-41	15
15 MAY 2020	131	325	36
14 MAY 2020	-285	249	22
13 MAY 2020	-418	84	20
12 MAY 2020	-453	132	29

11 MAY 2020	-1301	-37	21
10 MAY 2020	-1569	-208	-NR-
09 MAY 2020	-1012	-40	42
08 MAY 2020	696	193	26
07 MAY 2020	-607	-274	33
06 MAY 2020	609	154	41
05 MAY 2020	626	-48	-NR-
04 MAY 2020	-563	54	25

*** NOTE: Discharge (ALL DAY) is computed using Spillway, Sector Gate and Lockages Discharges from 0015 hrs to 2400 hrs.


(I) - Flows preceded by "I" signify an instantaneous flow computed from the single value reported for the day

* On 11 May 1999, Lake Okeechobee Elevation was switched from Instantaneous 2400 value to an average-daily lake average.
 On 14 Mar 2001, due to the isolation of various gages within the standard 10 stations, the average of the interior 4 station gages was used as the Lake Okeechobee Elevation.
 On 05 November 2010, Lake Okeechobee Elevation was switched to a 9 gage mix of interior and edge gages to obtain a more reliable representation of the lake level.
 On 09 May 2011, Lake Okeechobee Elevation was switched to a 8 gage mix of interior and edge gages to obtain a more reliable representation of the lake level due to isolation of S135 from low lake levels.
 Today Lake Okechobee elevation is determined from the 4 Int & 4 Edge stations
 ++ For more information see the Jacksonville District Navigation website at <http://www.saj.usace.army.mil/>
 \$ For information regarding Lake Okeechobee Service Area water restrictions please refer to www.sfwmd.gov

Report Generated 18MAY2020 @ 23:38 ** Preliminary Data - Subject to Revision **

Lake Okeechobee

20MAY20 13:17:20



Classification Tables

Supplemental Tables used in conjunction with the LORS2008 Release

Guidance Flow Charts

- [Class Limits for Tributary Hydrologic Conditions](#)

Table K-2 in the Lake Okeechobee Water Control Plan

- [6-15 Day Precipitation Outlook Categories](#)

Table ?? in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Seasonal Outlook](#)

Table K-3 in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Multi-Seasonal Outlook](#)

Table K-4 in the Lake Okeechobee Water Control Plan

[Back to Lake Okeechobee Operations Main Page](#)

[Back to U.S. Army Corps of Engineers Lake Okeechobee Operations Homepage](#)

Tributary Hydrologic Classification*	Palmer Index Class Limits	2-wk Mean L.O. Net Inflow Class Limits
Very Wet	3.0 or greater	Greater \geq 6000 cfs
Wet	1.5 to 2.99	2500 - 5999 cfs
Near Normal	-1.49 to 1.49	500 - 2499 cfs
Dry	-2.99 to -1.5	-5000 – 500 cfs
Very Dry	-3.0 or less	Less than -5000 cfs

* use the wettest of the two indicators

Classification of Lake Okeechobee Net Inflow Seasonal Outlook*

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth** [feet]	Lake Okeechobee Net Inflow Seasonal Outlook
> 0.93	> 2.0	Very Wet
0.71 to 0.93	1.51 to 2.0	Wet
0.35 to 0.70	0.75 to 1.5	Normal
< 0.35	< 0.75	Dry

****Volume-depth conversion based on average lake surface area of 467,000 acres**

Classification of Lake Okeechobee Net Inflow Multi-Seasonal Outlook^{*}

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth^{**} [feet]	Lake Okeechobee Net Inflow Multi-Seasonal Outlook
> 2.0	> 4.3	Very Wet
1.18 to 2.0	2.51 to 4.3	Wet
0.5 to 1.17	1.1 to 2.5	Normal
< 0.5	< 1.1	Dry

^{}Volume-depth conversion based on average lake surface area of 467,000 acres**

6-15 Day Precipitation Outlook Categories*

6-15 Day Precipitation Outlook Categories	WSE Decision Tree Categories
Above Normal	Wet to Very Wet
Normal	Normal
Below Normal	Dry

*** Corresponds to Table 7-6 in the Lake Okeechobee Water Control Plan**

Under Construction