

Application of the Lake Okeechobee Regulation Schedule (LORS2008) on 06/29/2020 (ENSO Neutral Condition)

Lake Okeechobee Net Inflow Outlook:

The Lake Okeechobee Net Inflow Outlook has been computed using 4 methods: Croley's method¹, the SFWMD empirical method², a sub-sampling of Neutral years³ and a sub-sampling of warm years of the Atlantic Multi-decadal Oscillation (AMO) in combination with La Nina ENSO years⁴. The results for Croley's method and the SFWMD empirical method are based on the CPC Outlook.

Table of the Lake Okeechobee Net Inflow Outlooks in feet of equivalent depth. All methods are updated on a weekly basis with observed net inflow for the current month.

Season	Croley's Method ^{1*}		SFWMD Empirical Method ²		Sub-sampling of Neutral ENSO Years ³		Sub-sampling of AMO Warm + Neutral ENSO Years ⁴	
	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>
Current (Jun-Nov)	N/A	N/A	3.09	Very Wet	3.12	Very Wet	4.36	Very Wet
Multi Seasonal (Jun-Apr)	N/A	N/A	3.62	Wet	3.33	Wet	4.68	Very Wet

***Croley's Method Not Produced for This Report**

See Seasonal and Multi-Seasonal tables for the classification of Lake Okeechobee Outlooks.

The recommended methods and values for estimating the Lake Okeechobee Net Inflow Outlook are shaded and should be used in the LORS2008 Release Guidance Flow Charts.

****Sub-sampling is a weighted average of ENSO conditions based on the ENSO forecast used.**

Tributary Hydrologic Conditions Graph:

2076 cfs 14-day running average for Lake Okeechobee Net Inflow through 06/29/2020. According to the classification in Tributary Hydrologic Conditions table, this condition is Normal.

-2.21 for Palmer Drought Index on 06/27/2020.

According to the classification in Tributary Hydrologic Conditions table, this condition is Dry.

The wetter of the two conditions above is **Normal**.

LORS2008 Classification Tables:

Lake Okeechobee Stage on 06/29/2020

Lake Okeechobee Stage: **12.35 feet**

Lake Okeechobee Management Zone/Band		Bottom Elevation (feet, NGVD)	Current Lake Stage
High Lake Management Band		16.13	
Operational Band	High sub-band	15.66	
	Intermediate sub-band	15.20	
	Low sub-band	13.26	
Base Flow sub-band		12.60	
Beneficial Use sub-band		11.06	← 12.35 ft
Water Shortage Management Band			

Part C and Part D of LORS2008:

With Lake Okeechobee stage below the Base-Flow Sub-Band, Part C **nor** Part D of the 2008 LORS suggest releases to the WCAs or Estuaries required to manage lake stages.

Adaptive Protocol's Release Guidance: Caloosahatchee Estuary

The SFWMD's Lake Okeechobee Adaptive Protocol's Release Guidance suggests no S-77 release to the Caloosahatchee Estuary unless the Governing Board recommends otherwise.

LORS2008 Implementation on 06/29/2020 (ENSO Neutral Condition):


Status for week ending on 6/29/2020:

Water Supply Risk Evaluation

Area	Indicator	Value	Color Coded Scoring Scheme
LOK	Projected LOK Stage for the next two months	Base Flow sub band	M
	Palmer Index for LOK Tributary Conditions	-2.21 (Extremely Dry)	H
	CPC Precipitation Outlook	1 month: Above Normal	L
		3 months: Above Normal	L
	LOK Seasonal Net Inflow Outlook	3.12 ft	L
	ENSO Forecast (positive)	Normal to Extremely Wet	
	LOK Multi-Seasonal Net Inflow Outlook	3.33 ft	L
	ENSO Forecast (positive)	Wet	
WCAs	WCA 1: 3 Station Average (Site 1-7, 1-8T and 1-9)	Above Line 1 (16.15 ft)	L
	WCA 2A: Site 2-17	Above Line 1 (12.60 ft)	L
	WCA-3A: 3 Station Average (Site 63, 64 and 65)	Above Line 1 (10.27 ft)	L
LEC	Service Area 1	Year-Round Irrigation Rule in effect	L
	Service Area 2	Year-Round Irrigation Rule in effect	L
	Service Area 3	Year-Round Irrigation Rule in effect	L

Note: The water supply risk classification based on the Palmer index, as well as the LOK seasonal and multi-seasonal net inflow outlooks use slightly different classification intervals than those used by the 2008-LORS.


Lake Okeechobee SFWMM Jun 2020 Position Analysis




(See assumptions on the Position Analysis Results website)

Tributary Basin Condition Indicators as of June 29 2020

Palmer Index




Lake Okeechobee Net Inflow (LONIN) 14-day Running Average



Mon Jun 29 22:56:36 EDT 2020

Flowchart to Guide Recommendations for Lake Okeechobee Releases to the Caloosahatchee Estuary for 2008 LORS Baseflow & for Environmental Water Supply (revised 9-Aug-2012)



¹The 2008 LORS Release Guidance (Part D) can suggest baseflow releases in the Intermediate, Low, or Baseflow Subbands.

²Estuary "needs" water when the 30-day moving average salinity at I-75 bridge is projected to exceed 5 practical salinity units (psu) within 2 weeks.

³LOWSM = Lake Okeechobee Water Shortage Management.


⁴Tributary Hydrologic Condition (THC) is based on classification of Lake Okeechobee Net Inflow and Palmer Index.

⁵Can release less than the "up to" limit if lower release is sufficient to reach or sustain desired estuary salinity; cfs = cubic feet per second.

⁶After reviewing conditions in Water Conservation Areas (WCAs), Stormwater Treatment Areas (STAs), ENP, St. Lucie Estuary and Lake Okeechobee.

⁷Should this condition be reached, the Governing Board will be briefed at their next regularly scheduled meeting as part of the State of the Water Resources agenda item.

Lake Okeechobee Water Level History and Projected Stages



U. S. Army Corps of Engineers, Jacksonville District
 Lake Okeechobee and Vicinity Report
 ** Preliminary Data - Subject to Revision **

Data Ending 2400 hours 28 JUN 2020

Okeechobee Lake Regulation	Elevation (ft-NGVD)	Last Year (ft-NGVD)	2YRS Ago (ft-NGVD)
*Okeechobee Lake Elevation	12.35	11.23	14.13 (Official Elv)
Bottom of High Lake Mngmt= 16.13 Top of Water Short Mngmt= 11.06			
Currently in Operational Management Band			

Simulated Average LORS2008 [1965-2000]	12.23
Difference from Average LORS2008	0.12

28JUN (1965-2007) Period of Record Average	13.37
Difference from POR Average	-1.02

Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations

++Navigation Depth (Based on 2007 Channel Condition Survey) Route 1 ÷ 6.29'
 ++Navigation Depth (Based on 2008 Channel Condition Survey) Route 2 ÷ 4.49'
 Bridge Clearance = 51.22'

4 Interior and 4 Edge Okeechobee Lake Average (Avg-Daily values):

L001	L005	L006	LZ40	S4	S352	S308	S133
12.40	-NR-	12.33	12.33	12.31	12.43	12.35	12.36

*Combination Okeechobee Avg-Daily Lake Average = 12.35
 (*See Note)

Okeechobee Inflows (cfs):

S65E	848	S65EX1	317	Fisheating Cr	432
S154	0	S191	0	S135 Pumps	0
S84	81	S133 Pumps	0	S2 Pumps	0
S84X	54	S127 Pumps	0	S3 Pumps	0
S71	83	S129 Pumps	0	S4 Pumps	0
S72	0	S131 Pumps	0	C5	0
Total Inflows:	1814				

Okeechobee Outflows (cfs):

S135 Culverts	0	S354	228	S77	463
S127 Culverts	0	S351	0	S308	-257
S129 Culverts	0	S352	244		
S131 Culverts	0	L8 Canal Pt	82		
Total Outflows:	760				

****S77 structure flow is being used to compute Total Outflow.
 ****S308 below flow meter is being used to compute Total Outflow.

Okeechobee Pan Evaporation (inches):

S77	0.24	S308	0.29
Average Pan Evap x 0.75 Pan Coefficient = 0.20" = 0.02'			

Lake Average Precipitation using NEXRAD: = 0.00" = 0.00'

Evaporation - Precipitation: = 0.20" = 0.02'
 Evaporation - Precipitation using Lake Area of 730 square miles
 is equal to 3901 cfs out of the lake.
 Lake Okeechobee (Change in Storage) Flow is -1916 cfs or -3800 AC-FT

	Headwater Elevation (ft-msl)	Tailwater Elevation (ft-msl)	Disch (cfs)	----- Gate Positions -----							
				#1 (ft)	#2 (ft)	#3 (ft)	#4 (ft)	#5 (ft)	#6 (ft)	#7 (ft)	#8 (ft)
			(I) see note at bottom								
North East Shore											
S133 Pumps:	13.03	12.54	0	0	0	0	0	0	0		(cfs)
S193:											
S191:	18.41	12.54	0	0.0	0.0	0.0					
S135 Pumps:	13.64	12.37	0	0	0	0	0				(cfs)
S135 Culverts:			0	0.3	0.0						
North West Shore											
S65E:	21.12	12.24	848	0.6	0.5	0.0	0.5	0.5	0.0		
S65EX1:	21.12	12.24	317								
S127 Pumps:	13.51	12.51	0	0	0	0	0	0			(cfs)
S127 Culvert:			0	0.0							
S129 Pumps:	12.83	12.77	0	0	0	0					(cfs)
S129 Culvert:			0	0.0							
S131 Pumps:	13.08	12.60	0	0	0						(cfs)
S131 Culvert:			0								
Fisheating Creek											
nr Palmdale		32.22	432								
nr Lakeport											
C5:		-NR-	0	-NR-	-NR-	-NR-					
South Shore											
S4 Pumps:	12.12	12.20	0	0	0	0					(cfs)
S169:	12.21	12.20	106	5.0	5.0	5.0					
S310:	12.10		85								
S3 Pumps:	10.94	12.16	0	0	0	0					(cfs)
S354:	12.16	10.94	228	0.3	0.5						
S2 Pumps:	10.37	-NR-	0	-NR-	-NR-	-NR-	-NR-				(cfs)
S351:	-NR-	10.37	0	0.0	0.0	0.0					
S352:	12.40	10.33	244	0.4	0.5						
C10A:	-NR-	12.46		8.0	8.0	8.0	0.0	0.0			
L8 Canal PT		12.25	82								

S351 and S352 Temporary Pumps/S354 Spillway

S351:	10.37	-NR-	0	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-		
S352:	10.33	12.40	244	-NR-	-NR-	-NR-	-NR-				
S354:	10.94	12.16	228	-NR-	-NR-	-NR-	-NR-				

Caloosahatchee River (S77, S78, S79)

S47B:	12.44	11.12		0.0	0.0						
S47D:	11.13	11.13	1	4.6							

S77:
 Spillway and Sector Preferred Flow:
 12.22 11.01 461 0.5 0.5 2.5 0.0
 Flow Due to Lockages+: 2

S78:
 Spillway and Sector Flow:
 11.04 2.86 324 0.5 0.0 0.0 0.5
 Flow Due to Lockages+: 12

S79:
 Spillway and Sector Flow:
 3.09 2.13 877 0.0 0.0 1.0 2.0 0.0 0.0 0.0 0.0
 Flow Due to Lockages+: 9
 Percent of flow from S77 53%
 Chloride (ppm) 0

St. Lucie Canal (S308, S80)

S308:
 Spillway and Sector Preferred Flow:
 12.37 12.28 -257 3.0 3.0 3.0 3.0
 Flow Due to Lockages+: 0

S153: 18.75 12.11 60 0.0 0.0

S80:
 Spillway and Sector Flow:
 12.28 0.06 0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
 Flow Due to Lockages+: 14
 Percent of flow from S308 NA %

Steele Point Top Salinity (mg/ml) ****
 Steele Point Bottom Salinity (mg/ml) ****

Speedy Point Top Salinity (mg/ml) ****
 Speedy Point Bottom Salinity (mg/ml) ****

+ Flow Due to lockages is computed utilizing average daily headwater and
 tailwater along with total number of lockages for the day to calculate
 a volume which is then converted to an average discharge in cfs.
 ++ Preferred flow is determined from either the spillway discharge or the below flow meter daily

	1-Day	3-Day	7-Day	----- Wind -----	
Daily Precipitation Totals	(inches)	(inches)	(inches)	Direction (DegØ)	Speed (mph)
S133 Pump Station:	-NR-	0.00	0.00		
S193:	-NR-	0.00	0.00	-NR-	-NR-
Okeechobee Field Station:	-NR-	0.00	0.00		
S135 Pump Station:	-NR-	0.00	0.00		
S127 Pump Station:	-NR-	0.00	0.00		
S129 Pump Station:	-NR-	0.00	0.00		
S131 Pump Station:	-NR-	0.00	0.00		
S77:	32.22	32.22	33.00	199	4
S78:	15.26	15.27	15.36	127	3
S79:	15.99	15.99	16.19	225	1
S4 Pump Station:	-NR-	0.00	0.00		
Clewiston Field Station:	-NR-	0.00	0.00		
S3 Pump Station:	-NR-	0.00	0.00		
S2 Pump Station:	-NR-	0.00	0.00		
S308:	0.04	0.04	0.80	145	8
S80:	33.40	33.40	33.40	193	4
Okeechobee Average	16.13	2.48	2.60		

(Sites S78, S79 and S80 not included)

Oke Nexrad Basin Avg 0.00 0.00 0.42

Okeechobee Lake Elevations	28 JUN 2020	12.35	Difference from 28JUN20
28JUN20 -1 Day =	27 JUN 2020	12.36	0.01
28JUN20 -2 Days =	26 JUN 2020	12.38	0.03
28JUN20 -3 Days =	25 JUN 2020	12.39	0.04
28JUN20 -4 Days =	24 JUN 2020	12.39	0.04
28JUN20 -5 Days =	23 JUN 2020	12.37	0.02
28JUN20 -6 Days =	22 JUN 2020	12.35	0.00
28JUN20 -7 Days =	21 JUN 2020	12.33	-0.02
28JUN20 -30 Days =	29 MAY 2020	11.42	-0.93
28JUN20 -1 Year =	28 JUN 2019	11.23	-1.12
28JUN20 -2 Year =	28 JUN 2018	14.13	1.78

Long Term Mean 30day Avearge ET for Lake Alfred (Inches) = -NR-

Lake Okeechobee Net Inflow (LONIN)

Average Flow over the previous 14 days				Avg-Daily Flow
28JUN20 Today =	28 JUN 2020	2339	MON	-900
28JUN20 -1 Day =	27 JUN 2020	2408	SUN	-2965
28JUN20 -2 Days =	26 JUN 2020	2784	SAT	-1366
28JUN20 -3 Days =	25 JUN 2020	3045	FRI	784
28JUN20 -4 Days =	24 JUN 2020	3603	THU	-NR-
28JUN20 -5 Days =	23 JUN 2020	3893	WED	4083
28JUN20 -6 Days =	22 JUN 2020	4304	TUE	3832
28JUN20 -7 Days =	21 JUN 2020	5121	MON	3832
28JUN20 -8 Days =	20 JUN 2020	5496	SUN	9781
28JUN20 -9 Days =	19 JUN 2020	6317	SAT	13713
28JUN20 -10 Days =	18 JUN 2020	6886	FRI	280
28JUN20 -11 Days =	17 JUN 2020	7394	THU	-1144
28JUN20 -12 Days =	16 JUN 2020	8106	WED	-1585
28JUN20 -13 Days =	15 JUN 2020	8398	TUE	2062

S65E

Average Flow over previous 14 days				Avg-Daily Flow
28JUN20 Today=	28 JUN 2020	1147	MON	982
28JUN20 -1 Day =	27 JUN 2020	1156	SUN	1090
28JUN20 -2 Days =	26 JUN 2020	1166	SAT	1194
28JUN20 -3 Days =	25 JUN 2020	1175	FRI	1148
28JUN20 -4 Days =	24 JUN 2020	1200	THU	1252
28JUN20 -5 Days =	23 JUN 2020	1204	WED	1354
28JUN20 -6 Days =	22 JUN 2020	1213	TUE	1239
28JUN20 -7 Days =	21 JUN 2020	1237	MON	1280
28JUN20 -8 Days =	20 JUN 2020	1269	SUN	1391
28JUN20 -9 Days =	19 JUN 2020	1275	SAT	1415
28JUN20 -10 Days =	18 JUN 2020	1283	FRI	874
28JUN20 -11 Days =	17 JUN 2020	1316	THU	994
28JUN20 -12 Days =	16 JUN 2020	1324	WED	806
28JUN20 -13 Days =	15 JUN 2020	1346	TUE	1035

S65EX1

Average Flow over previous 14 days				Avg-Daily Flow
28JUN20 Today=	28 JUN 2020	480	MON	317
28JUN20 -1 Day =	27 JUN 2020	502	SUN	271
28JUN20 -2 Days =	26 JUN 2020	528	SAT	359

28JUN20	-3 Days =	25 JUN 2020	538	FRI		302
28JUN20	-4 Days =	24 JUN 2020	561	THU		391
28JUN20	-5 Days =	23 JUN 2020	581	WED		491
28JUN20	-6 Days =	22 JUN 2020	607	TUE		510
28JUN20	-7 Days =	21 JUN 2020	632	MON		608
28JUN20	-8 Days =	20 JUN 2020	637	SUN		656
28JUN20	-9 Days =	19 JUN 2020	641	SAT		535
28JUN20	-10 Days =	18 JUN 2020	644	FRI		441
28JUN20	-11 Days =	17 JUN 2020	637	THU		613
28JUN20	-12 Days =	16 JUN 2020	615	WED		619
28JUN20	-13 Days =	15 JUN 2020	581	TUE		612

Lake Okeechobee Outlets Last 14 Days

DATE	S-77 Discharge (ALL DAY) (AC-FT)	Below S-77 Discharge (ALL-DAY) (AC-FT)	S-78 Discharge (ALL DAY) (AC-FT)	S-79 Discharge (ALL DAY) (AC-FT)	
28 JUN 2020	920	1515	665	1784	
27 JUN 2020	966	1814	600	1570	
26 JUN 2020	440	779	363	1575	
25 JUN 2020	3	142	356	1433	
24 JUN 2020	205	404	424	1852	
23 JUN 2020	519	854	685	1803	
22 JUN 2020	2	617	1095	2703	
21 JUN 2020	1	814	1501	3688	
20 JUN 2020	3	754	1359	2221	
19 JUN 2020	3	477	896	4162	
18 JUN 2020	414	725	740	1766	
17 JUN 2020	478	529	388	1614	
16 JUN 2020	4	19	595	3224	
15 JUN 2020	2	-1	763	2291	

DATE	S-310 Discharge (ALL DAY) (AC-FT)	S-351 Discharge (ALL DAY) (AC-FT)	S-352 Discharge (ALL DAY) (AC-FT)	S-354 Discharge (ALL DAY) (AC-FT)	L8 Canal Pt Discharge (ALL DAY) (AC-FT)
28 JUN 2020	169	0	484	452	163
27 JUN 2020	96	0	275	394	91
26 JUN 2020	211	0	476	177	11
25 JUN 2020	122	415	497	642	-59
24 JUN 2020	-8	0	0	0	-160
23 JUN 2020	-184	0	0	0	-39
22 JUN 2020	-316	0	0	0	-89
21 JUN 2020	-492	0	0	0	-93
20 JUN 2020	-527	0	0	0	-249
19 JUN 2020	-315	0	0	0	-150
18 JUN 2020	395	0	0	0	132
17 JUN 2020	373	0	0	1021	54
16 JUN 2020	153	744	0	0	11
15 JUN 2020	25	190	0	0	-130

DATE	S-308 Discharge (ALL DAY) (AC-FT)	Below S-308 Discharge (ALL-DAY) (AC-FT)	S-80 Discharge (ALL-DAY) (AC-FT)
28 JUN 2020	1442	-510	27
27 JUN 2020	1480	-321	24
26 JUN 2020	1613	-387	41
25 JUN 2020	1227	-342	41
24 JUN 2020	8208	-NR-	24
23 JUN 2020	-NR-	-942	38

22 JUN 2020	-NR-	-695	27
21 JUN 2020	-NR-	-1134	-NR-
20 JUN 2020	-NR-	-969	27
19 JUN 2020	-NR-	-782	36
18 JUN 2020	-1221	-342	23
17 JUN 2020	-1395	-244	31
16 JUN 2020	-2220	-272	-NR-
15 JUN 2020	-1643	-513	38

*** NOTE: Discharge (ALL DAY) is computed using Spillway, Sector Gate and Lockages Discharges from 0015 hrs to 2400 hrs.


(I) - Flows preceded by "I" signify an instantaneous flow computed from the single value reported for the day

* On 11 May 1999, Lake Okeechobee Elevation was switched from Instantaneous 2400 value to an average-daily lake average.
 On 14 Mar 2001, due to the isolation of various gages within the standard 10 stations, the average of the interior 4 station gages was used as the Lake Okeechobee Elevation.
 On 05 November 2010, Lake Okeechobee Elevation was switched to a 9 gage mix of interior and edge gages to obtain a more reliable representation of the lake level.
 On 09 May 2011, Lake Okeechobee Elevation was switched to a 8 gage mix of interior and edge gages to obtain a more reliable representation of the lake level due to isolation of S135 from low lake levels.
 Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations
 ++ For more information see the Jacksonville District Navigation website at <http://www.saj.usace.army.mil/>
 \$ For information regarding Lake Okeechobee Service Area water restrictions please refer to www.sfwmd.gov

Report Generated 29JUN2020 @ 23:39 ** Preliminary Data - Subject to Revision **

Lake Okeechobee

29JUN20 22:45:25



- High Lake Management
- Okeechobee Avg Elev
- Average Elev [1965-2007]
- Water Shortage Management

Classification Tables

Supplemental Tables used in conjunction with the LORS2008 Release

Guidance Flow Charts

- [Class Limits for Tributary Hydrologic Conditions](#)

Table K-2 in the Lake Okeechobee Water Control Plan

- [6-15 Day Precipitation Outlook Categories](#)

Table ?? in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Seasonal Outlook](#)

Table K-3 in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Multi-Seasonal Outlook](#)

Table K-4 in the Lake Okeechobee Water Control Plan

[Back to Lake Okeechobee Operations Main Page](#)

[Back to U.S. Army Corps of Engineers Lake Okeechobee Operations Homepage](#)

Tributary Hydrologic Classification*	Palmer Index Class Limits	2-wk Mean L.O. Net Inflow Class Limits
Very Wet	3.0 or greater	Greater $\geq$ 6000 cfs
Wet	1.5 to 2.99	2500 - 5999 cfs
Near Normal	-1.49 to 1.49	500 - 2499 cfs
Dry	-2.99 to -1.5	-5000 – 500 cfs
Very Dry	-3.0 or less	Less than -5000 cfs

* use the wettest of the two indicators

Classification of Lake Okeechobee Net Inflow Seasonal Outlook*

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth** [feet]	Lake Okeechobee Net Inflow Seasonal Outlook
> 0.93	> 2.0	Very Wet
0.71 to 0.93	1.51 to 2.0	Wet
0.35 to 0.70	0.75 to 1.5	Normal
< 0.35	< 0.75	Dry

****Volume-depth conversion based on average lake surface area of 467,000 acres**

Classification of Lake Okeechobee Net Inflow Multi-Seasonal Outlook*

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth** [feet]	Lake Okeechobee Net Inflow Multi-Seasonal Outlook
> 2.0	> 4.3	Very Wet
1.18 to 2.0	2.51 to 4.3	Wet
0.5 to 1.17	1.1 to 2.5	Normal
< 0.5	< 1.1	Dry

****Volume-depth conversion based on average lake surface area of 467,000 acres**

6-15 Day Precipitation Outlook Categories*

6-15 Day Precipitation Outlook Categories	WSE Decision Tree Categories
Above Normal	Wet to Very Wet
Normal	Normal
Below Normal	Dry

*** Corresponds to Table 7-6 in the Lake Okeechobee Water Control Plan**

Under Construction