

Application of the Lake Okeechobee Regulation Schedule (LORS2008) on 09/05/2022 (ENSO Condition: La Niña)

Lake Okeechobee Net Inflow Outlook:

The Lake Okeechobee Net Inflow Outlook has been computed using 4 methods: Croley's method¹, the SFWMD empirical method², a sub-sampling of La Niña years³ and a sub-sampling of warm years of the Atlantic Multi-decadal Oscillation (AMO) in combination with La Niña ENSO years⁴. The results for Croley's method and the SFWMD empirical method are based on the CPC Outlook.

Table of the Lake Okeechobee Net Inflow Outlooks in feet of equivalent depth. All methods are updated on a weekly basis with observed net inflow for the current month.

Season	Croley's Method ^{1*}		SFWMD Empirical Method ²		Sub-sampling of La Niña ENSO Years ³		Sub-sampling of AMO Warm + La Niña ENSO Years ⁴	
	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>
Current (Sep-Feb)	N/A	N/A	1.51	Wet	1.21	Normal	1.08	Normal
Multi Seasonal (Sep-Apr)	N/A	N/A	1.70	Normal	1.15	Normal	0.84	Dry

*Croley's Method Not Produced for This Report

See Seasonal and Multi-Seasonal tables for the classification of Lake Okeechobee Outlooks.

The recommended methods and values for estimating the Lake Okeechobee Net Inflow Outlook are shaded and should be used in the LORS2008 Release Guidance Flow Charts.

**Sub-sampling is a weighted average of ENSO conditions based on the ENSO forecast used.

Tributary Hydrologic Conditions Graph:

-954 cfs 14-day running average for Lake Okeechobee Net Inflow through 09/05/2022. According to the classification in Tributary Hydrologic Conditions table, this condition is Dry.

-4.22 for Palmer Drought Index on 09/03/2022.

According to the classification in Tributary Hydrologic Conditions table, this condition is Very Dry.

The wetter of the two conditions above is **Dry**.

LORS2008 Classification Tables:

Lake Okeechobee Stage on 09/05/2022:

Lake Okeechobee Stage: **12.55 feet**

Lake Okeechobee Management Zone/Band		Bottom Elevation (feet, NGVD)	Current Lake Stage
High Lake Management Band		16.45	
Operational Band	High sub-band	16.06	
	Intermediate sub-band	15.67	
	Low sub-band	13.90	
Base Flow sub-band		12.64	
Beneficial Use sub-band		12.46	← 12.55 ft
Water Shortage Management Band			

Part C of LORS2008: Discharge to WCAs

No releases to WCAs.

Part D of LORS2008: Discharge to Tide

No releases to estuaries.

**Lake Okeechobee Releases to the Caloosahatchee Estuary
for 2008 LORS Baseflow & for Environmental Water Supply**

Guidance for Lake Okeechobee Releases to the Caloosahatchee Estuary indicates no S77 release to the Caloosahatchee Estuary unless the Governing Board recommends otherwise.


LORS2008 Implementation on 09/05/2022 (ENSO Condition- La Niña Watch)*:**Status for week ending 09/05/2022:****Water Supply Risk Evaluation**

Area	Indicator	Value	Color Coded Scoring Scheme
LOK	Projected LOK Stage for the next two months	Water Shortage Management Band	H
	Palmer Drought Index for LOK Tributary Conditions	-4.22 (Extremely Dry)	H
	CPC Precipitation Outlook	1 month: Above Normal	L
		3 months: Above Normal	L
	LOK Seasonal Net Inflow Outlook	1.21 ft	L
	ENSO Forecast	Normal	
	LOK Multi-Seasonal Net Inflow Outlook	1.15 ft	M
	ENSO Forecast	Normal	
WCAs	WCA 1: Station Average (Sites 1-7, 1-8T, and 1-9)	Above Line 1 (16.32 ft)	L
	WCA 2A: Site 2-17	Above Line 1 (12.17 ft)	L
	WCA-3A: 3 Station Average (Sites 63, 64, and 65)	Above Line 1 (9.41 ft)	L
LEC	Service Area 1	Year-Round Irrigation Rule in effect	L
	Service Area 2	Year-Round Irrigation Rule in effect	L
	Service Area 3	Year-Round Irrigation Rule in effect	L

Note: The water supply risk classification based on the Palmer index, as well as the LOK seasonal and multi-seasonal net inflow outlooks use slightly different classification intervals than those used by the 2008-LORS.



*- Flow data at S80 is not available since Aug 29 and was assumed to be zero

Lake Okeechobee SFWMM September 2022 Position Analysis



(See assumptions on the Position Analysis Results website)

Tributary Basin Condition Indicators as of September 04 2022



2008 LORS

Part C: Establish Allowable Lake Okeechobee Releases to the Water Conservation Areas




Figure 7-3


2008 LORS

Part D: Establish Allowable Lake Okeechobee Releases to Tide (Estuaries)


Note: This operational guidance provides essential supplementary information to be used in conjunction with other supporting documentation including text within the Water Control Plan.

When conducting Base Flow releases, flows can be distributed East and West up to 650 cfs as needed to minimize impacts or provide benefits through S-80 and S-79

Apply Meteorological Forecasts on a Weekly Basis; apply Seasonal and Multi-Seasonal Climate/Hydrologic Outlooks on a Monthly Basis



Flowchart to Guide Recommendations for Lake Okeechobee Releases to the Caloosahatchee Estuary for 2008 LORS Baseflow & for Environmental Water Supply (revised 9-Aug-2012)



¹The 2008 LORS Release Guidance (Part D) can suggest baseflow releases in the Intermediate, Low, or Baseflow Subbands.

²Estuary “needs” water when the 30-day moving average salinity at I-75 bridge is projected to exceed 5 practical salinity units (psu) within 2 weeks.

³LOWSM = Lake Okeechobee Water Shortage Management.


⁴Tributary Hydrologic Condition (THC) is based on classification of Lake Okeechobee Net Inflow and Palmer Index.

⁵Can release less than the “up to” limit if lower release is sufficient to reach or sustain desired estuary salinity; cfs = cubic feet per second.

⁶After reviewing conditions in Water Conservation Areas (WCAs), Stormwater Treatment Areas (STAs), ENP, St. Lucie Estuary and Lake Okeechobee.

⁷Should this condition be reached, the Governing Board will be briefed at their next regularly scheduled meeting as part of the State of the Water Resources agenda item

Lake Okeechobee Water Level History and Projected Stages



U. S. Army Corps of Engineers, Jacksonville District
Lake Okeechobee and Vicinity Report
** Preliminary Data - Subject to Revision **

Data Ending 2400 hours 04 SEP 2022

Okeechobee Lake Regulation	Elevation (ft-NGVD)	Last Year (ft-NGVD)	2YRS Ago (ft-NGVD)
*Okeechobee Lake Elevation	12.55	14.69	14.40 (Official Elv)
Bottom of High Lake Mngmt= 16.45 Top of Water Short Mngmt= 12.46			
Currently in Operational Management Band			

Simulated Average LORS2008 [1965-2000] 13.29
Difference from Average LORS2008 -0.74

04SEP (1965-2007) Period of Record Average 14.30
Difference from POR Average -1.75

Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations

++Navigation Depth (Based on 2007 Channel Condition Survey) Route 1 6.49'
++Navigation Depth (Based on 2008 Channel Condition Survey) Route 2 4.69'
Bridge Clearance = 49.41'

4 Interior and 4 Edge Okeechobee Lake Average (Avg-Daily values):

L001	L005	L006	LZ40	S4	S352	S308	S133
12.53	12.62	12.56	12.56	12.60	12.64	12.42	12.47

*Combination Okeechobee Avg-Daily Lake Average = 12.55
(*See Note)

Okeechobee Inflows (cfs):

S65E	397	S65EX1	0	Fisheating Cr	734
S154	0	S191	0	S135 Pumps	0
S84	4	S133 Pumps	0	S2 Pumps	0
S84X	1	S127 Pumps	0	S3 Pumps	0
S71	0	S129 Pumps	0	S4 Pumps	0
S72	0	S131 Pumps	0	C5	0
Total Inflows: 1136					

Okeechobee Outflows (cfs):

S135 Culverts	0	S354	0	S77	-NR-
S127 Culverts	0	S351	94	S308	-NR-
S129 Culverts	0	S352	7		
S131 Culverts	0	L8 Canal Pt	-NR-		
Total Outflows: No Report Due To Missing S77 or S308 Discharge Data					

****S77 below flow meter is being used to compute Total Outflow.
****S308 structure flow is being used to compute Total Outflow.

Okeechobee Pan Evaporation (inches):

S77	-NR-	S308	-NR-
Average Pan Evap x 0.75 Pan Coefficient = -NR-" = -NR-'			

Lake Average Precipitation using NEXRAD: = -NR-" = -NR-'

Evaporation - Precipitation: = -NR-" = -NR-'
Evaporation - Precipitation using Lake Area of 730 square miles

is equal to -NR-
Lake Okeechobee (Change in Storage) Flow is -3933 cfs or -7800 AC-FT

Headwater Tailwater		Disch	----- Gate Positions -----							
Elevation	Elevation		#1	#2	#3	#4	#5	#6	#7	#8
(ft-msl)	(ft-msl)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)
(I) see note at bottom										
North East Shore										
S133 Pumps:	12.97	12.47	0	0	0	0	0	0	(cfs)	
S193:										
S191:	18.63	12.44	0	0.0	0.0	0.0				
S135 Pumps:	13.31	12.38	0	0	0	0	0		(cfs)	
S135 Culverts:			0	0.0	0.0					
North West Shore										
S65E:	20.90	12.32	397	0.4	0.3	0.0	0.0	0.2	0.0	
S65EX1:	20.90	12.32	0							
S127 Pumps:	12.45	12.51	0	0	0	0	0	0	(cfs)	
S127 Culvert:			0	0.0						
S129 Pumps:	13.15	12.97	0	0	0	0			(cfs)	
S129 Culvert:			0	0.0						
S131 Pumps:	12.88	12.75	0	0	0				(cfs)	
S131 Culvert:			0							
Fisheating Creek										
nr Palmdale		32.69	734							
nr Lakeport										
C5:		-NR-	0	-NR-	-NR-	-NR-				
South Shore										
S4 Pumps:	12.61	-NR-	0	-NR-	-NR-	-NR-			(cfs)	
S169:	12.59	12.62	-NR-	-NR-	-NR-	-NR-				
S310:	12.51		-35							
S3 Pumps:	10.22	12.60	0	0	0	0			(cfs)	
S354:	12.60	10.22	0	0.0	0.0					
S2 Pumps:	9.91	12.54	0	0	0	0	0		(cfs)	
S351:	12.54	9.91	94	0.4	0.4	0.4				
S352:	12.61	9.91	7	0.0	0.1					
C10A:	-NR-	12.37		8.0	8.0	8.0	0.0	0.0		
L8 Canal PT		12.43	-NR-							

S351 and S352 Temporary Pumps/S354 Spillway

S351:	9.91	12.54	94	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	
S352:	9.91	12.61	7	-NR-	-NR-	-NR-	-NR-			
S354:	10.22	12.60	0	-NR-	-NR-	-NR-	-NR-			

Caloosahatchee River (S77, S78, S79)

S47B:	12.69	10.81		0.0	0.0					
S47D:	10.80	10.79	66	5.0						
S77:										
Spillway and Sector Preferred Flow:										
	12.58	10.69	-NR-	0.0	0.0	0.0	0.0			
Flow Due to Lockages+:			-NR-							

S78:

Spillway and Sector Flow:
10.70 2.78 1069 1.0 0.0 0.0 2.0
Flow Due to Lockages+: -NR-

S79:

Spillway and Sector Flow:
-NR- -NR- -NR- 0.0 0.0 2.0 2.0 4.0 4.0 2.0 2.0
Flow Due to Lockages+: -NR-
Percent of flow from S77 -NR-%
Chloride (ppm) -N

St. Lucie Canal (S308, S80)

S308:

Spillway and Sector Preferred Flow:
12.41 14.09 0 0.0 0.0 0.0 0.0
Flow Due to Lockages+: -NR-

S153: 18.63 13.88 47 0.0 0.0

S80:

Spillway and Sector Flow:
14.13 0.61 0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
Flow Due to Lockages+: -NR-
Percent of flow from S308 NA %

Steele Point Top Salinity (mg/ml) ****
Steele Point Bottom Salinity (mg/ml) ****

Speedy Point Top Salinity (mg/ml) ****
Speedy Point Bottom Salinity (mg/ml) ****

+ Flow Due to lockages is computed utilizing average daily headwater and
tailwater along with total number of lockages for the day to calculate
a volume which is then converted to an average discharge in cfs.

++ Preferred flow is determined from either the spillway discharge or the below flow meter daily

Daily Precipitation Totals	1-Day (inches)	3-Day (inches)	7-Day (inches)	----- Wind ----- Direction Speed (Deg) (mph)
S133 Pump Station:	-NR-	0.00	0.00	
S193:	-NR-	0.00	0.00	-NR- -NR-
Okeechobee Field Station:	-NR-	0.00	0.00	
S135 Pump Station:	-NR-	0.00	0.00	
S127 Pump Station:	-NR-	0.00	0.00	
S129 Pump Station:	-NR-	0.00	0.00	
S131 Pump Station:	-NR-	0.00	0.00	
S77:	0.00	0.00	1.46	110 4
S78:	0.01	0.01	0.03	169 2
S79:	-NR-	0.00	1.98	-NR- -NR-
S4 Pump Station:	-NR-	0.00	0.00	
Clewiston Field Station:	-NR-	0.00	0.00	
S3 Pump Station:	-NR-	0.00	0.00	
S2 Pump Station:	-NR-	0.00	0.00	
S308:	0.00	0.00	0.00	117 1
S80:	0.00	0.00	0.47	341 0
Okeechobee Average (Sites S78, S79 and S80 not included)	0.00	0.00	0.11	
Oke Nexrad Basin Avg	-NR-	0.00	0.00	

Okeechobee Lake Elevations	04 SEP 2022	12.55	Difference from 04SEP22
04SEP22 -1 Day =	03 SEP 2022	12.57	0.02

04SEP22	-2 Days =	02 SEP 2022	12.57	0.02
04SEP22	-3 Days =	01 SEP 2022	12.56	0.01
04SEP22	-4 Days =	31 AUG 2022	12.57	0.02
04SEP22	-5 Days =	30 AUG 2022	12.58	0.03
04SEP22	-6 Days =	29 AUG 2022	12.59	0.04
04SEP22	-7 Days =	28 AUG 2022	12.59	0.04
04SEP22	-30 Days =	05 AUG 2022	12.95	0.40
04SEP22	-1 Year =	04 SEP 2021	14.69	2.14
04SEP22	-2 Year =	04 SEP 2020	14.40	1.85

Long Term Mean 30day Avearge ET for Lake Alfred (Inches) = -NR-

Lake Okeechobee Net Inflow (LONIN)					
Average Flow over the previous 14 days					Avg-Daily Flow
04SEP22	Today =	04 SEP 2022	-814	MON	-NR-
04SEP22	-1 Day =	03 SEP 2022	-1174	SUN	147
04SEP22	-2 Days =	02 SEP 2022	-1276	SAT	2176
04SEP22	-3 Days =	01 SEP 2022	-1736	FRI	-1826
04SEP22	-4 Days =	31 AUG 2022	-1852	THU	-1429
04SEP22	-5 Days =	30 AUG 2022	-2002	WED	-1687
04SEP22	-6 Days =	29 AUG 2022	-1959	TUE	368
04SEP22	-7 Days =	28 AUG 2022	-2074	MON	-1871
04SEP22	-8 Days =	27 AUG 2022	-1304	SUN	-NR-
04SEP22	-9 Days =	26 AUG 2022	-1412	SAT	-NR-
04SEP22	-10 Days =	25 AUG 2022	-1432	FRI	-NR-
04SEP22	-11 Days =	24 AUG 2022	-1603	THU	-26
04SEP22	-12 Days =	23 AUG 2022	-1767	WED	-1561
04SEP22	-13 Days =	22 AUG 2022	-1844	TUE	-2434

S65E					
Average Flow over previous 14 days					Avg-Daily Flow
04SEP22	Today=	04 SEP 2022	650	MON	470
04SEP22	-1 Day =	03 SEP 2022	630	SUN	716
04SEP22	-2 Days =	02 SEP 2022	585	SAT	915
04SEP22	-3 Days =	01 SEP 2022	534	FRI	993
04SEP22	-4 Days =	31 AUG 2022	463	THU	1000
04SEP22	-5 Days =	30 AUG 2022	391	WED	830
04SEP22	-6 Days =	29 AUG 2022	332	TUE	1085
04SEP22	-7 Days =	28 AUG 2022	259	MON	767
04SEP22	-8 Days =	27 AUG 2022	211	SUN	689
04SEP22	-9 Days =	26 AUG 2022	168	SAT	467
04SEP22	-10 Days =	25 AUG 2022	143	FRI	292
04SEP22	-11 Days =	24 AUG 2022	131	THU	249
04SEP22	-12 Days =	23 AUG 2022	123	WED	304
04SEP22	-13 Days =	22 AUG 2022	110	TUE	317

S65EX1					
Average Flow over previous 14 days					Avg-Daily Flow
04SEP22	Today=	04 SEP 2022	0	MON	0
04SEP22	-1 Day =	03 SEP 2022	0	SUN	0
04SEP22	-2 Days =	02 SEP 2022	0	SAT	0
04SEP22	-3 Days =	01 SEP 2022	2	FRI	0
04SEP22	-4 Days =	31 AUG 2022	2	THU	0
04SEP22	-5 Days =	30 AUG 2022	2	WED	0
04SEP22	-6 Days =	29 AUG 2022	3	TUE	0
04SEP22	-7 Days =	28 AUG 2022	6	MON	0
04SEP22	-8 Days =	27 AUG 2022	6	SUN	0
04SEP22	-9 Days =	26 AUG 2022	6	SAT	0
04SEP22	-10 Days =	25 AUG 2022	6	FRI	0
04SEP22	-11 Days =	24 AUG 2022	6	THU	0
04SEP22	-12 Days =	23 AUG 2022	6	WED	0
04SEP22	-13 Days =	22 AUG 2022	6	TUE	0

Lake Okeechobee Outlets Last 14 Days

DATE	S-77 Discharge (ALL DAY) (AC-FT)	Below S-77 Discharge (ALL-DAY) (AC-FT)	S-78 Discharge (ALL DAY) (AC-FT)	S-79 Discharge (ALL DAY) (AC-FT)
04 SEP 2022	-NR-	-16	-NR-	-NR-
03 SEP 2022	-NR-	68	2404	-NR-
02 SEP 2022	-NR-	45	2015	5470
01 SEP 2022	-NR-	92	1789	6895
31 AUG 2022	-NR-	201	-NR-	5958
30 AUG 2022	-NR-	86	-NR-	8603
29 AUG 2022	1	150	1945	9330
28 AUG 2022	0	221	1958	5148
27 AUG 2022	1	169	1342	2976
26 AUG 2022	0	117	767	2088
25 AUG 2022	0	250	709	1829
24 AUG 2022	295	501	305	943
23 AUG 2022	839	893	882	1539
22 AUG 2022	470	609	716	1423

DATE	S-310 Discharge (ALL DAY) (AC-FT)	S-351 Discharge (ALL DAY) (AC-FT)	S-352 Discharge (ALL DAY) (AC-FT)	S-354 Discharge (ALL DAY) (AC-FT)	L8 Canal Pt Discharge (ALL DAY) (AC-FT)
04 SEP 2022	-70	187	14	0	-NR-
03 SEP 2022	-232	74	0	0	-NR-
02 SEP 2022	-270	199	0	0	-NR-
01 SEP 2022	2	141	0	0	-NR-
31 AUG 2022	124	809	0	0	-NR-
30 AUG 2022	-200	300	0	0	-NR-
29 AUG 2022	-141	522	0	0	-NR-
28 AUG 2022	42	0	0	0	-NR-
27 AUG 2022	10	507	0	0	-NR-
26 AUG 2022	-95	1218	0	0	-NR-
25 AUG 2022	59	1798	153	323	-NR-
24 AUG 2022	109	1961	255	908	-NR-
23 AUG 2022	124	1777	617	922	-NR-
22 AUG 2022	49	899	675	409	-NR-

DATE	S-308 Discharge (ALL DAY) (AC-FT)	Below S-308 Discharge (ALL-DAY) (AC-FT)	S-80 Discharge (ALL-DAY) (AC-FT)
04 SEP 2022	-NR-	-NR-	-NR-
03 SEP 2022	-NR-	-NR-	-NR-
02 SEP 2022	-NR-	-NR-	-NR-
01 SEP 2022	-NR-	-NR-	-NR-
31 AUG 2022	-NR-	-NR-	-NR-
30 AUG 2022	-NR-	-NR-	-NR-
29 AUG 2022	-NR-	-NR-	-NR-
28 AUG 2022	-NR-	-NR-	28
27 AUG 2022	-NR-	-NR-	4
26 AUG 2022	-NR-	-NR-	35
25 AUG 2022	-NR-	-NR-	7
24 AUG 2022	-NR-	-NR-	7
23 AUG 2022	-NR-	-NR-	0
22 AUG 2022	-NR-	-NR-	18


*** NOTE: Discharge (ALL DAY) is computed using Spillway, Sector Gate and Lockages Discharges from 0015 hrs to 2400 hrs.

(I) - Flows preceeded by "I" signify an instantaneous flow computed from the single value reported for the day

-
- * On 11 May 1999, Lake Okeechobee Elevation was switched from Instantaneous 2400 value to an average-daily lake average.
 - On 14 Mar 2001, due to the isolation of various gages within the standard 10 stations, the average of the interior 4 station gages was used as the Lake Okeechobee Elevation.
 - On 05 November 2010, Lake Okeechobee Elevation was switched to a 9 gage mix of interior and edge gages to obtain a more reliable representation of the lake level.
 - On 09 May 2011, Lake Okeechobee Elevation was switched to a 8 gage mix of interior and edge gages to obtain a more reliable representation of the lake level due to isolation of S135 from low lake levels.
 - Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations
 - ++ For more information see the Jacksonville District Navigation website at <http://www.saj.usace.army.mil/>
 - \$ For information regarding Lake Okeechobee Service Area water restrictions please refer to www.sfwmd.gov

Lake Okeechobee

05SEP22 07:45:26



- High Lake Management
- Okeechobee Avg Elev
- Average Elev [1965-2007]
- Water Shortage Management

Classification Tables

Supplemental Tables used in conjunction with the LORS2008 Release

Guidance Flow Charts

- [Class Limits for Tributary Hydrologic Conditions](#)

Table K-2 in the Lake Okeechobee Water Control Plan

- [6-15 Day Precipitation Outlook Categories](#)

Table ?? in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Seasonal Outlook](#)

Table K-3 in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Multi-Seasonal Outlook](#)

Table K-4 in the Lake Okeechobee Water Control Plan

[**Back to Lake Okeechobee Operations Main Page**](#)

[**Back to U.S. Army Corps of Engineers Lake Okeechobee Operations Homepage**](#)

Tributary Hydrologic Classification*	Palmer Index Class Limits	2-wk Mean L.O. Net Inflow Class Limits
Very Wet	3.0 or greater	Greater \geq 6000 cfs
Wet	1.5 to 2.99	2500 - 5999 cfs
Near Normal	-1.49 to 1.49	500 - 2499 cfs
Dry	-2.99 to -1.5	-5000 – 500 cfs
Very Dry	-3.0 or less	Less than -5000 cfs

* use the wettest of the two indicators

Classification of Lake Okeechobee Net Inflow Seasonal Outlook*

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth** [feet]	Lake Okeechobee Net Inflow Seasonal Outlook
> 0.93	> 2.0	Very Wet
0.71 to 0.93	1.51 to 2.0	Wet
0.35 to 0.70	0.75 to 1.5	Normal
< 0.35	< 0.75	Dry

****Volume-depth conversion based on average lake surface area of 467,000 acres**

Classification of Lake Okeechobee Net Inflow Multi-Seasonal Outlook*

Lake Net Inflow Prediction [million acre-feet]	Equivalent Depth** [feet]	Lake Okeechobee Net Inflow Multi-Seasonal Outlook
> 2.0	> 4.3	Very Wet
1.18 to 2.0	2.51 to 4.3	Wet
0.5 to 1.17	1.1 to 2.5	Normal
< 0.5	< 1.1	Dry

****Volume-depth conversion based on average lake surface area of 467,000 acres**

6-15 Day Precipitation Outlook Categories*

6-15 Day Precipitation Outlook Categories	WSE Decision Tree Categories
Above Normal	Wet to Very Wet
Normal	Normal
Below Normal	Dry

*** Corresponds to Table 7-6 in the Lake Okeechobee Water Control Plan**