

# Application of the Lake Okeechobee Regulation Schedule (LORS2008) on 10/10/2022 (ENSO Condition: La Niña)

## Lake Okeechobee Net Inflow Outlook:

The Lake Okeechobee Net Inflow Outlook has been computed using 4 methods: Croley's method<sup>1</sup>, the SFWMD empirical method<sup>2</sup>, a sub-sampling of La Niña years<sup>3</sup> and a sub-sampling of warm years of the Atlantic Multi-decadal Oscillation (AMO) in combination with La Niña ENSO years<sup>4</sup>. The results for Croley's method and the SFWMD empirical method are based on the CPC Outlook.

Table of the Lake Okeechobee Net Inflow Outlooks in feet of equivalent depth. All methods are updated on a weekly basis with observed net inflow for the current month.

Season	Croley's Method <sup>1*</sup>		SFWMD Empirical Method <sup>2</sup>		Sub-sampling of La Niña ENSO Years <sup>3</sup>		Sub-sampling of AMO Warm + La Niña ENSO Years <sup>4</sup>	
	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>	Value (ft)	<u>Condition</u>
Current (Oct-Mar)	N/A	N/A	1.35	Normal	0.93	Normal	0.77	Normal
Multi Seasonal (Oct-Apr)	N/A	N/A	1.42	Normal	0.84	Dry	0.66	Dry

**\*Croley's Method Not Produced for This Report**

See Seasonal and Multi-Seasonal tables for the classification of Lake Okeechobee Outlooks.

The recommended methods and values for estimating the Lake Okeechobee Net Inflow Outlook are shaded and should be used in the LORS2008 Release Guidance Flow Charts.

**\*\*Sub-sampling is a weighted average of ENSO conditions based on the ENSO forecast used.**

## ***Tributary Hydrologic Conditions Graph:***

**19876 cfs** 14-day running average for Lake Okeechobee Net Inflow through 10/10/2022.  
According to the classification in Tributary Hydrologic Conditions table, this condition is Very Wet.

**-0.81** for Palmer Drought Index on 10/08/2022.

According to the classification in Tributary Hydrologic Conditions table, this condition is Near Normal.

The wetter of the two conditions above is **Very Wet**.

## **LORS2008 Classification Tables:**

### **Lake Okeechobee Stage on 10/10/2022:**

Lake Okeechobee Stage: **14.53 feet**

Lake Okeechobee Management Zone/Band		Bottom Elevation (feet, NGVD)	Current Lake Stage
High Lake Management Band		16.77	
Operational Band	High sub-band	16.40	
	Intermediate sub-band	15.93	
	Low sub-band	14.50	← 14.53 ft
Base Flow sub-band		13.00	
Beneficial Use sub-band		12.99	
Water Shortage Management Band			

**Part C of LORS2008: Discharge to WCAs**

No releases to WCAs.

**Part D of LORS2008: Discharge to Tide**

Up to 450 cfs at S-79 and up to 200 cfs at S-80.

**Lake Okeechobee Releases to the Caloosahatchee Estuary  
for 2008 LORS Baseflow & for Environmental Water Supply**

Guidance for Lake Okeechobee Releases to the Caloosahatchee Estuary indicates no S77 release to the Caloosahatchee Estuary unless the Governing Board recommends otherwise.


**LORS2008 Implementation on 10/10/2022 (ENSO Condition- La Niña Watch):****Status for week ending 10/10/2022:****Water Supply Risk Evaluation**

Area	Indicator	Value	Color Coded Scoring Scheme
<b>LOK</b>	Projected LOK Stage for the next two months	Low Sub-band	L
	Palmer Drought Index for LOK Tributary Conditions	-0.81 (Normal to Extremely Wet)	L
	CPC Precipitation Outlook	1 month: Normal	L
		3 months: Normal	L
	LOK Seasonal Net Inflow Outlook	0.93 ft	M
	ENSO Forecast	Dry	
	LOK Multi-Seasonal Net Inflow Outlook	0.84 ft	H
	ENSO Forecast	Dry	
<b>WCAs</b>	WCA 1: 3 Station Average (Sites 1-7, 1-8T, 1-9)	Above Line 1 (17.16 ft)	L
	WCA 2A: Site 2-17	Above Line 1 (13.85 ft)	L
	WCA-3A: 3 Station Average (Sites 63, 64, and 65)	Above Line 1 (10.71 ft)	L
<b>LEC</b>	Service Area 1	Year-Round Irrigation Rule in effect	L
	Service Area 2	Year-Round Irrigation Rule in effect	L
	Service Area 3	Year-Round Irrigation Rule in effect	L

Note: The water supply risk classification based on the Palmer index, as well as the LOK seasonal and multi-seasonal net inflow outlooks use slightly different classification intervals than those used by the 2008-LORS.



---

# Lake Okeechobee SFWMM October 2022 Position Analysis



(See assumptions on the Position Analysis Results website)

Tributary Basin Condition Indicators as of October 09 2022



# 2008 LORS

## Part C: Establish Allowable Lake Okeechobee Releases to the Water Conservation Areas




Figure 7-3


# 2008 LORS

## Part D: Establish Allowable Lake Okeechobee Releases to Tide (Estuaries)

Note: This operational guidance provides essential supplementary information to be used in conjunction with other supporting documentation including text within the Water Control Plan.


When conducting Base Flow releases, flows can be distributed East and West up to 650 cfs as needed to minimize impacts or provide benefits through S-80 and S-79

Apply Meteorological Forecasts on a Weekly Basis; apply Seasonal and Multi-Seasonal Climate/Hydrologic Outlooks on a Monthly Basis





# Flowchart to Guide Recommendations for Lake Okeechobee Releases to the Caloosahatchee Estuary for 2008 LORS Baseflow & for Environmental Water Supply (revised 9-Aug-2012)



<sup>1</sup>The 2008 LORS Release Guidance (Part D) can suggest baseflow releases in the Intermediate, Low, or Baseflow Subbands.

<sup>2</sup>Estuary "needs" water when the 30-day moving average salinity at I-75 bridge is projected to exceed 5 practical salinity units (psu) within 2 weeks.

<sup>3</sup>LOWSM = Lake Okeechobee Water Shortage Management.


<sup>4</sup>Tributary Hydrologic Condition (THC) is based on classification of Lake Okeechobee Net Inflow and Palmer Index.

<sup>5</sup>Can release less than the "up to" limit if lower release is sufficient to reach or sustain desired estuary salinity; cfs = cubic feet per second.

<sup>6</sup>After reviewing conditions in Water Conservation Areas (WCAs), Stormwater Treatment Areas (STAs), ENP, St. Lucie Estuary and Lake Okeechobee.

<sup>7</sup>Should this condition be reached, the Governing Board will be briefed at their next regularly scheduled meeting as part of the State of the Water Resources agenda item.

# Lake Okeechobee Water Level History and Projected Stages



U. S. Army Corps of Engineers, Jacksonville District  
Lake Okeechobee and Vicinity Report  
\*\* Preliminary Data - Subject to Revision \*\*

Data Ending 2400 hours 09 OCT 2022

---

Okeechobee Lake Regulation	Elevation (ft-NGVD)	Last Year (ft-NGVD)	2YRS Ago (ft-NGVD)
*Okeechobee Lake Elevation	14.53	15.77	16.05 (Official Elv)
Bottom of High Lake Mngmt= 16.88 Top of Water Short Mngmt= 12.95			
Currently in Operational Management Band			

Simulated Average LORS2008 [1965-2000] 13.91  
Difference from Average LORS2008 0.62

09OCT (1965-2007) Period of Record Average 15.01  
Difference from POR Average -0.48

Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations

++Navigation Depth (Based on 2007 Channel Condition Survey) Route 1 8.47'  
++Navigation Depth (Based on 2008 Channel Condition Survey) Route 2 6.67'  
Bridge Clearance = 49.70'

---

4 Interior and 4 Edge Okeechobee Lake Average (Avg-Daily values):

L001	L005	L006	LZ40	S4	S352	S308	S133
13.80	14.53	14.61	14.55	14.63	14.65	14.40	14.36

\*Combination Okeechobee Avg-Daily Lake Average = 14.53  
(\*See Note)

---

Okeechobee Inflows (cfs):

S65E	13599	S65EX1	281	Fisheating Cr	1553
S154	4	S191	184	S135 Pumps	0
S84	1415	S133 Pumps	0	S2 Pumps	0
S84X	363	S127 Pumps	0	S3 Pumps	0
S71	136	S129 Pumps	23	S4 Pumps	0
S72	0	S131 Pumps	17	C5	0
Total Inflows: 17574					

Okeechobee Outflows (cfs):

S135 Culverts	0	S354	0	S77	4
S127 Culverts	0	S351	0	S308	1
S129 Culverts	0	S352	0		
S131 Culverts	0	L8 Canal Pt	-183		
Total Outflows: -178					

\*\*\*\*S77 structure flow is being used to compute Total Outflow.  
\*\*\*\*S308 structure flow is being used to compute Total Outflow.

Okeechobee Pan Evaporation (inches):

S77	0.25	S308	0.18
Average Pan Evap x 0.75 Pan Coefficient = 0.16" = 0.01'			

Lake Average Precipitation using NEXRAD: = -NR-" = -NR-'

Evaporation - Precipitation: = -NR-" = -NR-'

Evaporation - Precipitation using Lake Area of 730 square miles

is equal to -NR-  
Lake Okeechobee (Change in Storage) Flow is 15024 cfs or 29800 AC-FT

Headwater Tailwater		Disch	----- Gate Positions -----							
Elevation	Elevation		#1	#2	#3	#4	#5	#6	#7	#8
(ft-msl)	(ft-msl)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)
(I) see note at bottom										
North East Shore										
S133 Pumps:	13.58	14.44	0	0	0	0	0	0	(cfs)	
S193:										
S191:	19.43	14.41	184	0.3	0.0	0.0				
S135 Pumps:	13.38	14.36	0	0	0	0	0		(cfs)	
S135 Culverts:			0	0.0	0.0					
North West Shore										
S65E:	21.05	14.93	13599	5.3	5.5	5.3	5.3	6.0	5.4	
S65EX1:	21.05	14.93	281							
S127 Pumps:	13.39	14.42	0	0	0	0	0	0	(cfs)	
S127 Culvert:			0	0.0						
S129 Pumps:	12.83	14.54	23	25	0	0			(cfs)	
S129 Culvert:			0	0.0						
S131 Pumps:	12.76	14.58	17	0	19				(cfs)	
S131 Culvert:			0							
Fisheating Creek										
nr Palmdale		33.41	1553							
nr Lakeport										
C5:		-NR-	0	-NR-	-NR-	-NR-				
South Shore										
S4 Pumps:	12.05	-NR-	0	-NR-	-NR-	-NR-			(cfs)	
S169:	14.67	14.76	-NR-	-NR-	-NR-	-NR-				
S310:	14.61		18							
S3 Pumps:	11.03	14.78	0	0	0	0			(cfs)	
S354:	14.78	11.03	0	0.0	0.0					
S2 Pumps:	9.89	14.73	0	0	0	0	0		(cfs)	
S351:	14.73	9.89	0	0.0	0.0	0.0				
S352:	14.71	9.93	0	0.0	0.0					
C10A:	-NR-	14.52		8.0	8.0	8.0	0.0	0.0		
L8 Canal PT		14.57	-183							

---

S351 and S352 Temporary Pumps/S354 Spillway

S351:	9.89	14.73	0	-NR-	-NR-	-NR-	-NR-	-NR-	-NR-	
S352:	9.93	14.71	0	-NR-	-NR-	-NR-	-NR-			
S354:	11.03	14.78	0	-NR-	-NR-	-NR-	-NR-			

---

Caloosahatchee River (S77, S78, S79)

S47B:	13.18	10.97		0.0	0.5					
S47D:	10.99	10.98	65	6.5						
S77:										
Spillway and Sector Preferred Flow:										
	14.46	10.82	0	0.0	0.0	0.0	0.0			
Flow Due to Lockages+:			4							

S78:

Spillway and Sector Flow:  
10.89 3.05 494 0.5 0.0 0.0 1.0  
Flow Due to Lockages+: 13

S79:

Spillway and Sector Flow:  
3.30 1.23 -NR- 0.0 0.0 2.0 2.0 2.0 2.0 0.0 0.0  
Flow Due to Lockages+: -NR-  
Percent of flow from S77 -NR-%  
Chloride (ppm) 0

St. Lucie Canal (S308, S80)

S308:

Spillway and Sector Preferred Flow:  
14.49 13.80 0 0.0 0.0 0.0 0.0  
Flow Due to Lockages+: 1

S153: 18.81 13.63 133 0.5 0.0

S80:

Spillway and Sector Flow:  
13.89 2.80 0 0.0 0.0 0.0 0.0 0.0 0.0 0.0  
Flow Due to Lockages+: 15  
Percent of flow from S308 NA %

Steele Point Top Salinity (mg/ml) \*\*\*\*  
Steele Point Bottom Salinity (mg/ml) \*\*\*\*

Speedy Point Top Salinity (mg/ml) \*\*\*\*  
Speedy Point Bottom Salinity (mg/ml) \*\*\*\*

+ Flow Due to lockages is computed utilizing average daily headwater and tailwater along with total number of lockages for the day to calculate a volume which is then converted to an average discharge in cfs.

++ Preferred flow is determined from either the spillway discharge or the below flow meter daily

Daily Precipitation Totals	1-Day (inches)	3-Day (inches)	7-Day (inches)	----- Wind -----	
				Direction (Deg $\diamond$ )	Speed (mph)
S133 Pump Station:	-NR-	0.00	0.00		
S193:	-NR-	0.00	0.00	-NR-	-NR-
Okeechobee Field Station:	-NR-	0.00	0.00		
S135 Pump Station:	-NR-	0.00	0.00		
S127 Pump Station:	-NR-	0.00	0.00		
S129 Pump Station:	-NR-	0.00	0.00		
S131 Pump Station:	-NR-	0.00	0.00		
S77:	0.00	0.00	0.00	61	5
S78:	0.00	0.00	0.00	52	2
S79:	-NR-	0.00	0.00	1	4
S4 Pump Station:	-NR-	0.00	0.00		
Clewiston Field Station:	-NR-	0.00	0.00		
S3 Pump Station:	-NR-	0.00	0.00		
S2 Pump Station:	-NR-	0.00	0.00		
S308:	0.00	0.00	0.00	80	3
S80:	0.10	0.10	0.10	54	2
Okeechobee Average (Sites S78, S79 and S80 not included)	0.00	0.00	0.00		
-----					
Oke Nexrad Basin Avg	-NR-	0.00	0.00		
-----					

Okeechobee Lake Elevations	09 OCT 2022	14.53	Difference from 09OCT22
09OCT22 -1 Day =	08 OCT 2022	14.46	-0.07

09OCT22	-2 Days =	07 OCT 2022	14.38	-0.15
09OCT22	-3 Days =	06 OCT 2022	14.30	-0.23
09OCT22	-4 Days =	05 OCT 2022	14.22	-0.31
09OCT22	-5 Days =	04 OCT 2022	14.14	-0.39
09OCT22	-6 Days =	03 OCT 2022	14.06	-0.47
09OCT22	-7 Days =	02 OCT 2022	13.97	-0.56
09OCT22	-30 Days =	09 SEP 2022	12.53	-2.00
09OCT22	-1 Year =	09 OCT 2021	15.77	1.24
09OCT22	-2 Year =	09 OCT 2020	16.05	1.52

---

Long Term Mean 30day Avearge ET for Lake Alfred (Inches) = -NR-

---

Lake Okeechobee Net Inflow (LONIN)					
Average Flow over the previous 14 days					Avg-Daily Flow
09OCT22	Today =	09 OCT 2022	21514	MON	15024
09OCT22	-1 Day =	08 OCT 2022	21499	SUN	17243
09OCT22	-2 Days =	07 OCT 2022	21013	SAT	16940
09OCT22	-3 Days =	06 OCT 2022	20224	FRI	16940
09OCT22	-4 Days =	05 OCT 2022	19295	THU	17243
09OCT22	-5 Days =	04 OCT 2022	18762	WED	17142
09OCT22	-6 Days =	03 OCT 2022	17949	TUE	19058
09OCT22	-7 Days =	02 OCT 2022	16998	MON	21175
09OCT22	-8 Days =	01 OCT 2022	16177	SUN	23293
09OCT22	-9 Days =	30 SEP 2022	15637	SAT	23293
09OCT22	-10 Days =	29 SEP 2022	14931	FRI	31763
09OCT22	-11 Days =	28 SEP 2022	13213	THU	48198
09OCT22	-12 Days =	27 SEP 2022	10196	WED	21175
09OCT22	-13 Days =	26 SEP 2022	8686	TUE	12705

---

S65E					
Average Flow over previous 14 days					Avg-Daily Flow
09OCT22	Today=	09 OCT 2022	9768	MON	13157
09OCT22	-1 Day =	08 OCT 2022	9132	SUN	13189
09OCT22	-2 Days =	07 OCT 2022	8417	SAT	12914
09OCT22	-3 Days =	06 OCT 2022	7665	FRI	12503
09OCT22	-4 Days =	05 OCT 2022	6905	THU	11698
09OCT22	-5 Days =	04 OCT 2022	6190	WED	11040
09OCT22	-6 Days =	03 OCT 2022	5514	TUE	10026
09OCT22	-7 Days =	02 OCT 2022	4898	MON	9286
09OCT22	-8 Days =	01 OCT 2022	4324	SUN	9094
09OCT22	-9 Days =	30 SEP 2022	3754	SAT	8610
09OCT22	-10 Days =	29 SEP 2022	3208	FRI	7641
09OCT22	-11 Days =	28 SEP 2022	2720	THU	6738
09OCT22	-12 Days =	27 SEP 2022	2295	WED	5530
09OCT22	-13 Days =	26 SEP 2022	1922	TUE	5325

---

S65EX1					
Average Flow over previous 14 days					Avg-Daily Flow
09OCT22	Today=	09 OCT 2022	372	MON	281
09OCT22	-1 Day =	08 OCT 2022	352	SUN	283
09OCT22	-2 Days =	07 OCT 2022	332	SAT	284
09OCT22	-3 Days =	06 OCT 2022	312	FRI	285
09OCT22	-4 Days =	05 OCT 2022	292	THU	288
09OCT22	-5 Days =	04 OCT 2022	271	WED	292
09OCT22	-6 Days =	03 OCT 2022	250	TUE	294
09OCT22	-7 Days =	02 OCT 2022	229	MON	296
09OCT22	-8 Days =	01 OCT 2022	208	SUN	299
09OCT22	-9 Days =	30 SEP 2022	187	SAT	302
09OCT22	-10 Days =	29 SEP 2022	165	FRI	351
09OCT22	-11 Days =	28 SEP 2022	140	THU	1036
09OCT22	-12 Days =	27 SEP 2022	66	WED	923
09OCT22	-13 Days =	26 SEP 2022	0	TUE	0

---

Lake Okeechobee Outlets Last 14 Days

DATE	S-77 Discharge (ALL DAY) (AC-FT)	Below S-77 Discharge (ALL-DAY) (AC-FT)	S-78 Discharge (ALL DAY) (AC-FT)	S-79 Discharge (ALL DAY) (AC-FT)
09 OCT 2022	8	6	1004	-NR-
08 OCT 2022	10	126	886	-NR-
07 OCT 2022	6	-14	1187	-NR-
06 OCT 2022	4	122	1737	-NR-
05 OCT 2022	3	352	1630	7878
04 OCT 2022	0	664	3153	10440
03 OCT 2022	2	952	4860	14548
02 OCT 2022	2	979	5522	17900
01 OCT 2022	0	1090	6389	20390
30 SEP 2022	0	1020	8806	26683
29 SEP 2022	0	863	8459	48441
28 SEP 2022	10	-413	8856	14845
27 SEP 2022	0	424	-NR-	-NR-
26 SEP 2022	4	1	2973	11359

DATE	S-310 Discharge (ALL DAY) (AC-FT)	S-351 Discharge (ALL DAY) (AC-FT)	S-352 Discharge (ALL DAY) (AC-FT)	S-354 Discharge (ALL DAY) (AC-FT)	L8 Canal Pt Discharge (ALL DAY) (AC-FT)
09 OCT 2022	35	0	0	0	-362
08 OCT 2022	45	0	0	0	-410
07 OCT 2022	3	0	0	0	-534
06 OCT 2022	13	0	0	0	-620
05 OCT 2022	-111	0	0	0	-775
04 OCT 2022	-139	0	0	0	-1022
03 OCT 2022	-290	0	0	0	-1367
02 OCT 2022	-395	0	0	0	-1825
01 OCT 2022	-406	0	0	0	-1928
30 SEP 2022	-479	0	0	0	-1902
29 SEP 2022	-234	0	0	-266	-1613
28 SEP 2022	-4	0	0	0	-1715
27 SEP 2022	-185	0	0	0	-1448
26 SEP 2022	-200	0	0	0	-1121

DATE	S-308 Discharge (ALL DAY) (AC-FT)	Below S-308 Discharge (ALL-DAY) (AC-FT)	S-80 Discharge (ALL-DAY) (AC-FT)
09 OCT 2022	2	-NR-	30
08 OCT 2022	7	-NR-	35
07 OCT 2022	2	-NR-	20
06 OCT 2022	1	-NR-	20
05 OCT 2022	-0	-NR-	27
04 OCT 2022	243	-NR-	17
03 OCT 2022	0	-NR-	14
02 OCT 2022	-1	-NR-	492
01 OCT 2022	-206	-NR-	455
30 SEP 2022	0	-NR-	1016
29 SEP 2022	0	-NR-	5831
28 SEP 2022	0	-NR-	5600
27 SEP 2022	-1281	-NR-	1003
26 SEP 2022	-2074	-NR-	28

\*\*\* NOTE: Discharge (ALL DAY) is computed using Spillway, Sector Gate and Lockages Discharges from 0015 hrs to 2400 hrs.

(I) - Flows preceeded by "I" signify an instantaneous flow computed from the single value reported for the day

---

\* On 11 May 1999, Lake Okeechobee Elevation was switched from Instantaneous 2400 value to an average-daily lake average.  
On 14 Mar 2001, due to the isolation of various gages within the standard 10 stations, the average of the interior 4 station gages was used as the Lake Okeechobee Elevation.  
On 05 November 2010, Lake Okeechobee Elevation was switched to a 9 gage mix of interior and edge gages to obtain a more reliable representation of the lake level.  
On 09 May 2011, Lake Okeechobee Elevation was switched to a 8 gage mix of interior and edge gages to obtain a more reliable representation of the lake level due to isolation of S135 from low lake levels.  
Today Lake Okeechobee elevation is determined from the 4 Int & 4 Edge stations

++ For more information see the Jacksonville District Navigation website at <http://www.saj.usace.army.mil/>

\$ For information regarding Lake Okeechobee Service Area water restrictions please refer to [www.sfwmd.gov](http://www.sfwmd.gov)


---

Report Generated 10OCT2022 @ 09:30 \*\* Preliminary Data - Subject to Revision \*\*



# Lake Okeechobee

10OCT22 09:17:26



- High Lake Management
- Okeechobee Avg Elev
- Average Elev [1965-2007]
- Water Shortage Management

# Classification Tables

---

Supplemental Tables used in conjunction with the LORS2008 Release

Guidance Flow Charts

- [Class Limits for Tributary Hydrologic Conditions](#)

Table K-2 in the Lake Okeechobee Water Control Plan

- [6-15 Day Precipitation Outlook Categories](#)

Table ?? in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Seasonal Outlook](#)

Table K-3 in the Lake Okeechobee Water Control Plan

- [Classification of Lake Okeechobee Net Inflow for Multi-Seasonal Outlook](#)

Table K-4 in the Lake Okeechobee Water Control Plan

---

[\*\*Back to Lake Okeechobee Operations Main Page\*\*](#)

[\*\*Back to U.S. Army Corps of Engineers Lake Okeechobee Operations Homepage\*\*](#)

Tributary Hydrologic Classification*	Palmer Index Class Limits	2-wk Mean L.O. Net Inflow Class Limits
Very Wet	3.0 or greater	Greater $\geq$ 6000 cfs
Wet	1.5 to 2.99	2500 - 5999 cfs
Near Normal	-1.49 to 1.49	500 - 2499 cfs
Dry	-2.99 to -1.5	-5000 – 500 cfs
Very Dry	-3.0 or less	Less than -5000 cfs

\* use the wettest of the two indicators

## Classification of Lake Okeechobee Net Inflow Seasonal Outlook\*

<b>Lake Net Inflow Prediction  [million acre-feet]</b>	<b>Equivalent Depth**  [feet]</b>	<b>Lake Okeechobee  Net Inflow  Seasonal Outlook</b>
> 0.93	> 2.0	Very Wet
0.71 to 0.93	1.51 to 2.0	Wet
0.35 to 0.70	0.75 to 1.5	Normal
< 0.35	< 0.75	Dry

**\*\*Volume-depth conversion based on average lake surface area of 467,000 acres**

## Classification of Lake Okeechobee Net Inflow Multi-Seasonal Outlook\*

<b>Lake Net Inflow Prediction</b>  <b>[million acre-feet]</b>	<b>Equivalent Depth**</b>  <b>[feet]</b>	<b>Lake Okeechobee  Net Inflow  Multi-Seasonal Outlook</b>
> 2.0	> 4.3	Very Wet
1.18 to 2.0	2.51 to 4.3	Wet
0.5 to 1.17	1.1 to 2.5	Normal
< 0.5	< 1.1	Dry

**\*\*Volume-depth conversion based on average lake surface area of 467,000 acres**

## **6-15 Day Precipitation Outlook Categories\***

<b>6-15 Day Precipitation Outlook Categories</b>	<b>WSE Decision Tree Categories</b>
Above Normal	Wet to Very Wet
Normal	Normal
Below Normal	Dry

**\* Corresponds to Table 7-6 in the Lake Okeechobee Water Control Plan**