
Tamiami Trail Flow Formula (TTFF) - Target Flow from WCA-3A to ENP

		-44.62		24.32		-96.31		-221.79	
WCA-3A Ave	NCA-3A Average Stage (β1) NESRS2 St		Previous 7-day Average Flow (β3)	Forecast Precipitation (β4)		Forecast PET (β5)		Regulation Schedule Stage (β6)	
			TTFF f	ormula coefficie	nts				
Average Daily Target Flow ²									cfs
5 This week target flow with adjustment (3 + 4)								918	cfs
4	4 This week calculated target flow							972	cfs
3 Adjustment for forecast (2-1)			- ,				-54		
2 Previous week target flow (recalculated with observed rainfall and							956		
1 Previous week target flow (calculated with forecasted 7-day QPF and PET) 1010 cfs									cfs
			TTFF	Applicati	ion				
3AS3WX 7-day Total Observed PET								1.01	Ш
	•							0.02	
Observed WCA-3 7-day Total Observed NEXRAD Rainfall				From	10/11/2025	to	10/17/2025	<u>Value</u>	
	•	ecasieu FLI							
WCA3 7-day Quantitative Precipitation Forecast (QPF) 3AS3WX - 7-day Total Forecasted PET								0.15 1.01	
Forecasted				From	10/18/2025	to	10/24/2025	<u>Value</u>	
	rological	Data		_			10/01/005-		
otal Flow	to ENP		7-day Average Daily Flow					971	cfs
5333 + S333N - S334 ¹			7-day Average Daily Flow					649	cfs
i-12s Total			7-day Average Daily Flow					323	
5-334			7-day Average Daily Flow					0	cfs
5-333N			7-day Average Daily Flow					324	
5-333			7-day Average Daily Flow					325	cfs
5-12D			7-day Average Daily Flow					323	cfs
5-12C			7-day Average Daily Flow					0	cfs
S-12A S-12B		7-day Average Daily Flow 7-day Average Daily Flow					0	cfs cfs	
<u>Station</u>			<u>Variable</u>	From	10/11/2025	to	10/17/2025	<u>Value</u>	
	ed Flow I	Data							
_			Average bully stage					10.41	IC NOVD25
NESRS2 Regulatory Stage WCA-3A		3Δ	Average Daily Stage Average Daily Stage						ft-NGVD29 ft-NGVD29
WCA-3A (Average for Site 63, 64 and 65)		te 63, 64 and 65)	Average Daily Stage						ft-NGVD29
<u>Station</u>			<u>Variable</u>			on	10/17/2025	<u>Value</u>	<u>Unit</u>
Observ	ed Stage	Data							
Daily Target Flow for		: Flow for			10/21/2025	to	10/27/2025	918	cts
			•	-					

Target flow is distributed from east to west (S-333, S-12D, S-12C, S-12B, and S-12A) to prioritize water deliveries to NESRS first and WSRS second, subject to downstream constraints.

²Actual discharges may vary from target discharges because of changing hydrologic conditions.



 $^{^{1}}$ S-333 + S-333N - S-334 becomes zero if the sum of S-333 and S-333N is less than S-334 flow. Calculation is done daily.