



11-22-15- 11-23-15

Rev 8, 10/01/2015

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Revision No. 08

Author: *Cabin Ward* Date: *10/1/15*

Approved: *[Signature]* Date: *10/1/15*

Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure.

Revision 8: Added requirement for validating CCS level margin prior to starting L31 pumps

11/22  
Pump  
Run  
North Pumping Station  
37,130,660 Gallons

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

*Bryan Ingram*

ATTACHMENT 2

NORTH PUMPING STATION HOURLY LOG SHEET

Month 11 Day 23 Year 15

Time	East Pump (107942)H3	Center Pump (107941)H2	West Pump (107940)H1	RPM East Pump	RPM Center Pump	RPM West Pump	North Canal Level North of 344 St.	South Canal Level South of 344 St.	System Checks Sat.
00:00	Flow:	Flow:	Flow:						
00:00	Total:	Total:	Total:						
1:00	Flow:	Flow:	Flow:				.35	.80	✓
1:00	Total:	Total:	Total:						
2:00 0220	Flow: 24254	Flow: ERROR	Flow: 20634	576	576	576	.25	.80	✓
2:00	Total: 17155190	Total: ERROR	Total: 31048498						
3:00	Flow: 22397	Flow: ERROR	Flow: 20508	576	576	576	.30	.80	✓
3:00	Total: 19010834	Total: ERROR	Total: 31821969						
4:00	Flow: 22195	Flow: ERROR	Flow: 20530	576	576	576	.20	.80	✓
4:00	Total: 19297159	Total: ERROR	Total: 33061179						
5:00	Flow: 22091	Flow: ERROR	Flow: 20525	576	576	576	.10	.80	✓
5:00	Total: 20598571	Total: ERROR	Total: 34280996						
6:00	Flow: 22634	Flow: <del>ERROR</del>	Flow: 20777	576	576	576	.0	.8	✓
6:00	Total: 21953031	Total: <del>ERROR</del>	Total: 35560400						
7:00	Flow: 22750	Flow: <del>ERROR</del>	Flow: 20780	576	576	576	+1	.8	✓
7:00	Total: 23399181	Total: <del>ERROR</del>	Total: 36808352						
8:00	Flow: 22542	Flow: <del>ERROR</del>	Flow: 20763	576	576	576	+2	.8	✓
8:00	Total: 24633829	Total: <del>ERROR</del>	Total: 38045850						
9:00	Flow: 23187	Flow: <del>ERROR</del>	Flow: 20124	576	576	576	+2	.8	✓
9:00	Total: 25974407	Total: <del>ERROR</del>	Total: 39276262						
10:00	Flow: 22858	Flow: <del>ERROR</del>	Flow: 19885	576	576	576	+2	.8	✓
10:00	Total: 27352279	Total: <del>ERROR</del>	Total: 40469633						
11:00	Flow: 23211	Flow: <del>ERROR</del>	Flow: 19747	576	576	576	+3	.8	✓
11:00	Total: 28716992	Total: <del>ERROR</del>	Total: 41652862						
11:55	Flow: 22647	Flow: <del>ERROR</del>	Flow: 19531	576	576	576	.0	.8	✓
11:55	Total: 29918567	Total: <del>ERROR</del>	Total: 42706872						

(82)

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

ATTACHMENT 2

NORTH PUMPING STATION HOURLY LOG SHEET				Month	Day	Year			
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	RPM East Pump	RPM Center Pump	RPM West Pump	North Canal Level North of 344 St	South Canal Level South of 344 St	System Checks Sat
13:00	Flow:	Flow:	Flow:						
13:00	Total:	Total:	Total:						
14:00	Flow:	Flow:	Flow:						
14:00	Total:	Total:	Total:						
15:00	Flow:	Flow:	Flow:						
15:00	Total:	Total:	Total:						
16:00	Flow:	Flow:	Flow:						
16:00	Total:	Total:	Total:						
17:00	Flow:	Flow:	Flow:						
17:00	Total:	Total:	Total:						
18:00	Flow:	Flow:	Flow:						
18:00	Total:	Total:	Total:						
19:00	Flow:	Flow:	Flow:						
19:00	Total:	Total:	Total:						
20:00	Flow:	Flow:	Flow:						
20:00	Total:	Total:	Total:						
21:00	Flow:	Flow:	Flow:						
21:00	Total:	Total:	Total:						
22:00	Flow:	Flow:	Flow:						
22:00	Total:	Total:	Total:						
23:00	Flow:	Flow:	Flow:						
23:00	Total:	Total:	Total:						
24:00	Flow:	Flow:	Flow:						
24:00	Total:	Total:	Total:						

**PUMP OPERATOR**  
 \_\_\_\_\_  
 Date: \_\_\_\_\_

**VERIFICATION COORDINATOR**  
 \_\_\_\_\_  
 Date: \_\_\_\_\_

ERIC CASH

11/23/15

Rev 8, 10/01/2015

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Revision No. 08

Author: *Eric Cash* Date: 11/1/15

Approved: *[Signature]* Date: 10/1/15

Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure.

Revision 8: Added requirement for validating CCS level margin prior to starting L31 pumps

South Pump Station  
11/22 Pump Run  
Nights Nan Sweeney  
Days Eric Cash  
37,069,945 Gallons

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

ATTACHMENT 3

11/22 Pump Run

SOUTH PUMP STATION HOURLY LOG SHEET						
Month <u>11</u> Day <u>22</u> Year <u>15</u>						
Time	North Pump (107944)	South Pump (107939)	RPM No. Pump	RPM So. Pump	South Canal Level	System Checks Sat
00:00	Flow:	Flow:				
00:00	Total:	Total:				
1:00	Flow:	Flow:				
1:00	Total:	Total:				
<del>2:00</del> 2:25	Flow: 34212	Flow: 31124				✓
<del>2:00</del> 2:25	Total: 29074754	Total: 40997322			.8	✓
3:00	Flow: 34704	Flow: 32121				✓
3:00	Total: 36185944	Total: 42022663			.8	✓
4:00	Flow: 34515	Flow: 31792				✓
4:00	Total: 32270912	Total: 43955085			.8	✓
5:00	Flow: 34573	Flow: 32365				✓
5:00	Total: 34338785	Total: 45892382			.8	✓
6:00	Flow: 34076	Flow: 32525	598	598	.8	✓
6:00	Total: 3633415	Total: 4786395				
7:00	Flow: 34564	Flow: 32426	598	598	.8	✓
7:00	Total: 36359903	Total: 49162612				
8:00	Flow: 34452	Flow: 31274	588	588	.8	✓
8:00	Total: 40373198	Total: 5184359				
9:00	Flow: 34344	Flow: 29352	588	588	.8	
9:00	Total: 42461624	Total: 53374221				
10:00	Flow: 34641	Flow: ERROR	588	588	.8	✓
10:00	Total: 44489735	Total: 52966966				
11:00	Flow: 34832	Flow: ERROR	588	588	.8	✓
11:00	Total: 46525912	Total: 5406049				
12:00	Flow: 34928	Flow: ERROR	588	588	.8	✓
12:00	Total: 4827492	Total: 54018019				

FL

PUMP OPERATOR ELCCASH  
Date 11/23/15

VERIFIED BY PUMP COORDINATOR 6088 11/23/15

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE**

**ATTACHMENT 3**

SOUTH PUMP STATION HOURLY LOG SHEET						
Time	North Pump (107944)	South Pump (107939)	RPM No. Pump	RPM So. Pump	South Canal Level	System Checks Sat
13:00	Flow:	Flow:				
13:00	Total:	Total:				
14:00	Flow:	Flow:				
14:00	Total:	Total:				
15:00	Flow:	Flow:				
15:00	Total:	Total:				
16:00	Flow:	Flow:				
16:00	Total:	Total:				
17:00	Flow:	Flow:				
17:00	Total:	Total:				
18:00	Flow:	Flow:				
18:00	Total:	Total:				
19:00	Flow:	Flow:				
19:00	Total:	Total:				
20:00	Flow:	Flow:				
20:00	Total:	Total:				
21:00	Flow:	Flow:				
21:00	Total:	Total:				
22:00	Flow:	Flow:				
22:00	Total:	Total:				
23:00	Flow:	Flow:				
23:00	Total:	Total:				
24:00	Flow:	Flow:				
24:00	Total:	Total:				

**PUMP OPERATOR**  
 \_\_\_\_\_  
 Date: \_\_\_\_\_

**VERIFIED BY PUMP  
COORDINATOR**  
 \_\_\_\_\_  
 Date: \_\_\_\_\_

11-23-15-11-24-15

Rev 8, 10/01/2015

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Revision No. 08

Author: *Patricia Ward* Date: 10/1/15

Approved: *Paul Swartz* Date: 10/1/15

Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure.

Revision 8: Added requirement for validating CCS level margin prior to starting L31 pumps

11/23  
Pump RUN  
North Pumping Station  
37,110,727

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## TABLE OF CONTENTS

*Bryan Ingram*  
*11/04/2015*

<b>SECTION</b>		
<i>1.0</i> <b>PURPOSE</b>	.....	3
<i>2.0</i> <b>PRECAUTIONS AND LIMITATIONS</b>	.....	3
<i>3.0</i> <b>PREREQUISITES</b>	.....	4
<i>4.0</i> <b>NORMAL OPERATIONS</b>		
<i>4.1</i> North Pumping Station Start-up	.....	5
4.2 South Pumping Station Start-up	.....	6
4.3 South Pumping Station Shutdown	.....	7
<i>4.4</i> North Pumping Station Shutdown	.....	8
<i>5.0</i> <b>INFREQUENT OPERATIONS</b>		
<i>5.1</i> Emergency shutdown of pump stations	.....	9
<i>6.0</i> <b>RECORDS</b>	.....	11
<i>7.0</i> <b>REFERENCES AND COMMITMENTS</b>	.....	11

### ATTACHMENTS

ATTACHMENT 1	Pump Coordinator Roles and Responsibilities.....	12
ATTACHMENT 2	North Pump Operator Roles and Responsibilities.....	15
ATTACHMENT 3	South Pump Operator Roles and Responsibilities.....	20

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

### 1.0 PURPOSE

This procedure provides instructions for operating the North and South Pumping Stations to inject L31 Canal Water into the Canal Cooling System (CCS). The North Pumping Station consists of 3 (three) axial flow pumps, West 30" Pump, Center 30" Pump and East 30" Pump. The South Pumping Station consists of 2 (two) axial pumps, North 36" Pump and the South 36" Pump. Two shifts will be utilized to operate the pumping stations. Each shift will consist of a FPL Pump Coordinator, and One (1) AWE Pump Operator.

### 2.0 PRECAUTIONS AND LIMITATIONS

#### 2.1 Precautions

Working over or around water requires either a personal flotation device or appropriate fall protection.

When work is to be performed on equipment in the water then 30" ring buoys with 90' of line shall be available with a lifesaving skiff at the work location.

Each shift should be familiar with the layout of each station specifically the location of floatation devices, spill kits, emergency shutdown equipment, fire extinguisher and logbooks that include all contact information.

Pump operation should be controlled using the Variable Frequency Drive (VFDs).

Pump control container live panel access is restricted to certified electricians

#### 2.2 Limitations

Prior to Pump Operation, CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches. Management notification is required if freeboard level is less than 7 inches. No pump operation is allowed if freeboard level is less than 5 inches.

When both pumping stations are capable of pumping they are to be manned continuously by a dedicated operator.

The North Pumping Station is always to be started first with a minimum of 5 minutes operation prior to starting the South Pumping Station.

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

4) The South Pumping Station is always to be stopped first with a minimum of 5 minutes prior to stopping the North Pumping Station.

5) Water level in the south canal shall not be allowed to decrease less than the initial level that the pumps were first started.

6) Pump control container access is restricted to AWE operators and FPL oversight.

### 3.0 PREREQUISITES

1) Prior to Pump Operation, CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches. Management notification is required if freeboard level is less than 7 inches. No pump operation is allowed if freeboard level is less than 5 inches.

2) Ensure staff gauges are installed at both pump locations and verify that level can be visibly determined and recorded hourly when the pumps are capable of pumping. Ensure canal level indication is available from the data loggers.

3) Ensure flow measuring devices are energized and not indicating any faults.

4) Ensure data loggers are energized and ready to operate.

5) Verify floating turbidity curtain and secondary debris screens (fence) are intact and positioned to encompass the pump location.

6) Ensure logbooks are at each pump station

7) Review the criteria for emergency shutdown of the pumps:

Manatees or crocodiles noted less than 50 feet from the pumps

Excessive pipe movement

Excessive leakage on pump discharge piping

Significant shore erosion since the last inspection

When directed by either Pump Operator or the Pump Coordinator

Erratic pump motor amperage ( $> \pm 10\%$  of benchmark full flow value)

### 4.0 NORMAL OPERATIONS

1) When normal pumping cycles are imminent, the pump Operation will be fully staffed for 18 hour operation, 7 day per week. This staff will be comprised of a day and night

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

shift coverage which will include One (1) vender supplied pump operator, and One (1) FPL Project Team member per shift.

2. The on shift FPL Project Team member will be responsible for monitoring the SFWMD website a minimum once every 15 minutes for the 504 acre-feet threshold. In addition the FPL PTN Chemistry Department will perform hourly monitoring of the SFWMD website with notifications to the Chemistry Manager and PGM if transfer volume reaches 400 acre-feet.

3. Prior to Pump Operation:

4. The CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches. Management notification is required if freeboard level is less than 7 inches to provide:

- 5. canal level data
- 6. general canal status
- 7. weather forecast that may add to the CCS level.

8. After reaching 504 acre-feet notification shall be made to Ray Moore and/or Alan Katz after commencing and/or securing pump operation.

9. Any questions or concerns that should arise during either shift of operation shall be vetted through Ray Moore or Alan Katz.

## 4.1 North Pumping Station Start-up

**CAUTION**

***The North Pumping Station is always to be started a minimum of 5 minutes operation prior to starting the South Pumping Station.***

1. Ensure North Pump Operator has reviewed ATTACHMENT 2, North Pump Operator Roles and Responsibilities.

2. Pre-Start Up Check List:

- 3. external leakage
- 4. perform pre-start checks
- 5. Signs of shore erosion
- 6. Excessive pipe movement
- 7. Verify Grass and Trash are clear from inside Turbidity Curtain
- 8. Erratic Motor Amperage
- 9. Verify CCS is clear at South Discharge

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE**

3. Monitor South Florida Water Management District and confirm the SFWMD flow authorization for the next pumping period until 11:59 PM and document below (bay delivery point of 504 acre-feet).

4. Record the canal levels at the North and South canal and document on Attachment 2 for North and Attachment 3 for South.

**CAUTION**

*Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started*

5. Verify Flow indicators are energized for the pump discharge headers on Attachment 2 for North and Attachment 3 for South.

- 6. Turn Pump ON
- 7. Check for Manatee and Wildlife
- 8. Verify pump Breaker is ON
- 9. Verify Main Breaker is ON
- 10. Verify SWITCH is turned to VFD
- 11. Verify HZ is set a desired setting (60HZ = full power)
- 12. PUSH START button
- 13. Verify Water is Flowing from motor tube

14. Verify water flow is observed at the south side of Palm Drive and document on Attachment 2.

**4.2 South Pumping Station Start-up**

**CAUTION**

*The North Pumping Station is always to be started a minimum of 5 minutes operation prior to starting the South Pumping Station.*

1. Ensure South Pump Operator has reviewed ATTACHMENT 3, South Pump Operator Roles and Responsibilities.
2. Pre-Start Up Check List:
  - external leakage

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE**

- perform pre-start checks
  - Signs of shore erosion
  - Excessive pipe movement
  - Verify Grass and Trash are Cleared inside Turbidity Curtain
  - Erratic Motor Amperage
  - Verify CCS is clear at the Discharge
3. Verify Flow indicators are energized for the pump discharge headers. Document on Attachment 3.
  4. Record the Total flow rate from the North Pumping Station on Attachment 3.
  5. Record the canal levels at the North and South canal and document on Attachment 2 for North and Attachment 3 for South.

**CAUTION**

***Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started***

6. Verify that the North Station Pump(s) are Operating
7. Turn Pump ON
  - Check for Manatee and Wildlife
  - Verify pump Breaker is ON
  - Verify Main Breaker is ON
  - verify SWITCH is turned to VFD
  - Verify HZ is set a desired setting (60HZ = full power)
  - PUSH START button
  - Verify Water is Flowing from motor tube
8. Verify water flow is observed at the Cooling Canal System and document on Attachment 3.

**4.3 South Pumping Station Shutdown****CAUTION**

***The South Pumping Station is always to be stopped a minimum of 5 minutes prior to stopping the North Pumping Station.***

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE**

1. Verify that the Injection of L31 Canal Water to the Canal Cooling System is to be shutdown.

**CAUTION**

***Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started***

2. Record the canal levels at the North and South canal and document on Attachment 2 and Attachment 3
3. Shutdown Pump
  - Read TOTALIZER PRIOR to turning pump off
  - Push OFF button
  - Allow Frequency to COAST down to 00:00
  - HZ Reading will remain the same
  - Listen for pump to STOP RUNNING
  - Once you have verified pump has come to COMPLETE STOP
  - Turn SWITCH to OFF (ONE CLICK ONLY)
4. Verify water flow is observed to stop at the Canal Cooling System.
5. Record the shutdown time and flow volume totals of the South Pumping Station on ATTACHMENT 3, South Pump Operator Roles and Responsibilities.
6. Check out the system for:
  - Visual inspect for excess grass and trash and document in log
  - Signs of shore erosion
  - Read staff gauge and continue to log for an additional 10 minutes
7. Verify the South Pumping Station is shutdown prior to shutting down the North Pumping Station.

**4.4 North Pumping Station Shutdown****CAUTION**

***The South Pumping Station is always to be stopped a minimum of 5 minutes prior to stopping the North Pumping Station.***

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

1. Verify that the South Pumping Station is shut down

**CAUTION**

*Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started*

2. Record the canal levels at the North and South canal and document on Attachment 2 and Attachment 3

3. Shutdown Pump

- Read TOTALIZER PRIOR to turning pump off
- Push OFF button
- Allow Frequency to COAST down to 00:00
- HZ Reading will remain the same
- Listen for pump to STOP RUNNING
- Once you have verified pump has come to COMPLETE STOP
- Turn SWITCH to OFF (ONE CLICK ONLY)

4. Shutdown the running pumps at the North Pumping Station and verify water flow is observed to stop at the south side of Palm Drive.

5. Record the shutdown time and flow volume totals of the North Pumping Station on ATTACHMENT 2, North Pump Operator Roles and Responsibilities.

6. Check out the system for:

- Visual inspect for excess grass and trash and document in log
- Signs of shore erosion
- Read staff gauge and continue to log for an additional 10 minutes

7. Notify the Water District Management that Injection of L31 Canal Water to the Canal Cooling System is shutdown. SFWMD Operation Control Center 561-682-6116.

## 5.0 INFREQUENT OPERATIONS

5.1 Emergency shutdown of pump stations

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

1. Immediately stop the Pumps and notify the Pump Coordinator and the other Pump Station that flow has stopped when any of the following conditions apply:

- Erratic pump motor amperage indicative of suction blockage
- Intake grate fouling that is degrading pump performance
- Manatees or crocodiles noted less than 50 feet from the pumps
- Excessive pipe movement
- Excessive leakage on pump discharge piping
- Emergency evacuation order
- Significant shore erosion since the last inspection
- When directed by either Pump Operator

2. Pump Coordinator to notify the SFWM of the reason that the pumps were immediately shutdown.

3. Notify Environmental of the reason that the pumps were immediately shutdown and request assistance as required.

4. Pump Coordinator shall document the date/time of the event total flow volume pumped and a description of actions taken and persons notified.

Date/Time: \_\_\_\_\_ / \_\_\_\_\_

---

---

---

---

---

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

### 6.0 RECORDS

The Pump Coordinator is to scan and transmit the North and South Pump Operator daily log readings each day to Environmental for subsequent submittal to DERM/SFWDM. Transfer electronic copies to WO 40379504 Documents EDMS file folder.

### 7.0 REFERENCES AND COMMITMENTS

Class 1 Construction permit, permit # CLI-2014-0312

South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-WU/ROW/ERP

Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)

Taylor Engineering FPL PTN Cooling Canal Freshwater Recharge

PTN Engineering Change (EC) 282152

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 1

### Pump Coordinator Roles and Responsibilities

The FPL Pump Coordinator is the main point of contact for all activities associated with the injection of L31 Canal water into the Canal Cooling System.

The Pump Coordinator will report to FPL Environmental and will provide direction to the Pump Operators on Starting and Stopping of the pumps including infrequent operations involving the emergency shutdown of all pumping equipment.

Responsibilities of the Pump Coordinator include but are not limited to the following items:

- Maintaining the safe operation of the North and South Pumping Stations
- Briefing the Pump Operators on their roles and responsibilities
- Ensuring Pump Stations remain in compliance with the:
  - Class 1 Construction permit, permit # CLI-2014-0312
  - South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-WU/ROW/ERP
  - Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)
- Communicating any issues with pump performance or compliance with the permit to the Control Room and Environmental
- Coordination of Emergency Response activities to address an evacuation
- Obtaining the daily water pump start authorization and maintaining Pumping Stations in compliance with the SFWMD permitted pumping start time. Authorization is defined as after the daily SFWMD bay discharge quota is reached.
- Coordinating Pump starts/stops at the North and South Pumping Stations
- Ensuring Pump Operator performs all designated routines throughout the shift
- Maintain a 24 hour Event Log of daily activities, 11:59hrs through 11:58hrs the next day (to be part of the submittal)

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE****ATTACHMENT 1****Pump Coordinator Roles and Responsibilities**

- Periodically inspect each Pump Station (approx. once per 3hrs) to verify and validate (V&V) recorded data of the operators and conduct of Pump Operations
- Maintaining 24/7 coverage of the Pump Stations when the North and South Pumps are operational
- Maintaining housekeeping standards at the North and South Pumping Stations
- Scan and transfer reports daily of pump data to FPL Environmental at 11:59 AM or shortly thereafter each day. Transfer electronic copy to WO 40379504 EDMS file.

## Contact information

Control Room	-	Shift Manager	X6492
Control Room	-	Emergency	X4444
Rory Rahming	-	Environmental	786-427-7437
Nan Sweeney	(Dayshift) -	Pump Coordinator	570-241-8135
Willis Nettles	(Night Shift)-	Pump Coordinator	772-473-1041

Coastal and Wetlands Resource Section		305-372-6575
FWC	<a href="mailto:ImperiledSpecies@myFWC.com">ImperiledSpecies@myFWC.com</a>	
FWC Hotline		888-404-3922
U.S. Fish and Wildlife Service		772-562-3909
State of Florida Bureau Archaeological Research		850-245-6444
Miami-Dade County Office of Historic Preservation		305-375-3412

DERM Coastal and Wetlands Resource Compliance Supervisor  
John Ricisak [ricisj@miamidade.gov](mailto:ricisj@miamidade.gov)  
DERM Coastal and Wetlands Resource Permitting Supervisor  
Christine Hopps [hoppsc@miamidade.gov](mailto:hoppsc@miamidade.gov)

## SFWMD:

Executive Director, Len Lindahl, [LLindahl@sfwmd.gov](mailto:LLindahl@sfwmd.gov)  
Water Resources Division Director, Terri Bates, [tbates@sfwmd.gov](mailto:tbates@sfwmd.gov)  
Water Resources Hydrologist, Simon Sunderland, P.G, [ssunder@sfwmd.gov](mailto:ssunder@sfwmd.gov)  
Bureau Chief, Maria Clemente, P.E. at [mclement@sfwmd.gov](mailto:mclement@sfwmd.gov)



INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

ATTACHMENT 1

Pump Coordinator Roles and Responsibilities

11/23  
Pump Run

Date / Time EVENT LOG BOOK Page 1 of \_

11/24/10/45 Set up pump Stations & Wildlife Checks

11/24/1224 Started North pumps

11/24/1229 Started South pumps

10300 North pump Station 2,369,952

10300 South pump Station 2,030,810

10400 South pump Station 3,888,720

10400 North pump Station 3,906,360

10500 NORTH pump STATION 3,912,510

10500 SOUTH pump STATION 3,864,270

10600 NORTH pump STATION 3,895,650

10600 SOUTH pump STATION 3,863,430

10700 NORTH pump STATION 3,877,980

10700 SOUTH pump STATION 3,880,410

10800 NORTH pump STATION 3,890,310

10800 SOUTH pump STATION 3,862,470

10900 NORTH pump STATION 3,892,680

10900 SOUTH pump STATION 3,973,530

11000 NORTH pump STATION 3,888,480

11000 SOUTH pump STATION 3,920,010

11100 NORTH pump STATION 3,895,920

11100 SOUTH pump STATION 3,939,060

11155 NORTH pump STATION 3,580,885

11150 SOUTH pump STATION 3,324,675

TOTAL Gallons pumped by NORTH STATION = 37,110,727

TOTAL Gallons pumped by SOUTH STATION = 36,547,385

Mike Gallagher  
Mike Gallagher  
11-24-15

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

*[Handwritten signature]*  
**ATTACHMENT 2**

## North Pump Operator Roles and Responsibilities

The AWE North Pump Operator is responsible for the safe operation of the three submersible pumps and associated variable speed drives and instrumentation. All pumping evolutions will be at the direction of the Pump Coordinator except if an emergency shutdown is required.

All events or equipment issues will be documented in the enclosed Event Log and will be immediately reported to the Pump Coordinator. Responsibilities of the Pump Operator include but are not limited to the following items:

- [Handwritten initials]* Maintaining the safe operation of the North Pumping Stations and performing and logging required periodic maintenance/lubrication of pump equipment Prior to Pump Operation, CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches.
- [Handwritten initials]* Management notification is required if freeboard level is less than 7 inches to provide canal level data, general canal status, and weather forecast that may add to the CCS level. No pump operation is allowed if freeboard level is less than 5 inches.
- [Handwritten initials]* Ensuring Pump Stations remain in compliance with the:
  - [Handwritten initials]* Class 2 Construction permit, permit # CLI-2014-0312
  - [Handwritten initials]* South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-U/ROW/ERP
  - [Handwritten initials]* Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)
- [Handwritten initials]* Communicating any issues with pump performance or compliance with the permit to the Pump Coordinator
- [Handwritten initials]* Performing Emergency Response activities to address an evacuation order or a fuel/oil spill
- [Handwritten initials]* Ensure spill response equipment maintained in good condition
- [Handwritten initials]* Maintaining Pump flows at the direction of the Pump Coordinator
- [Handwritten initials]* Perform Manatee and crocodile watch when pumps are running (Polarized lenses are required for Manatee watch)
- [Handwritten initials]* Perform all designated routines, readings and recordings throughout the shift including maintaining housekeeping standards at the North Pumping Station
- [Handwritten initials]* Maintain a 24 hour Event Log of daily activities, 11:59hrs through 11:58hrs the next day(to be part of the submittal)
- [Handwritten initials]* Maintaining 24/7 coverage of the North Pump Station when the North Pumps are operational





INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

ATTACHMENT 2

*Bryan Ingram*

NORTH PUMPING STATION HOURLY LOG SHEET									
Month <u>11</u> Day <u>24</u> Year <u>15</u>									
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	RPM East Pump	RPM Center Pump	RPM West Pump	North Canal Level North of 344 St	South Canal Level South of 344 St	System Checks Sat
00:00	Flow:	Flow:	Flow:						
00:00	Total:	Total:	Total:						
1:00	Flow:	Flow:	Flow:						
1:00	Total:	Total:	Total:						
2:00	Flow: 24475	Flow: ERROR	Flow: ERROR	576	576	576	-.30	.80	✓
0224	Total: 29994249	Total: ERROR	Total: ERROR						
3:00	Flow: 22788	Flow: ERROR	Flow: ERROR	576	576	576	-.25	.80	✓
3:00	Total: 30137722	Total: ERROR	Total: ERROR						
4:00	Flow: 23019	Flow: ERROR	Flow: ERROR	576	576	576	-.30	.80	✓
4:00	Total: 32132269	Total: ERROR	Total: ERROR						
5:00	Flow: 22998	Flow: ERROR	Flow: ERROR	576	576	576	-.25	.80	✓
5:00	Total: 33485239	Total: ERROR	Total: ERROR						
6:00	Flow: 22457	Flow: <del>ERROR</del>	Flow: <del>ERROR</del>	576	576	576	-.2	.8	✓
6:00	Total: 35034734	Total: <del>ERROR</del>	Total: <del>ERROR</del>						
7:00	Flow: 22409	Flow: <del>ERROR</del>	Flow: <del>ERROR</del>	576	576	576	.0	.8	✓
7:00	Total: 36260325	Total: <del>ERROR</del>	Total: <del>ERROR</del>						
8:00	Flow: 22868	Flow: <del>ERROR</del>	Flow: <del>ERROR</del>	576	576	576	+.1	.8	✓
8:00	Total: 37615790	Total: <del>ERROR</del>	Total: <del>ERROR</del>						
9:00	Flow: 22488	Flow: <del>ERROR</del>	Flow: <del>ERROR</del>	576	576	576	+.1	.8	✓
9:00	Total: 38984452	Total: <del>ERROR</del>	Total: <del>ERROR</del>						
10:00	Flow: 22728	Flow: <del>ERROR</del>	Flow: <del>ERROR</del>	576	576	576	+.1	.8	✓
10:00	Total: 40338551	Total: <del>ERROR</del>	Total: <del>ERROR</del>						
11:00	Flow: 22736	Flow: <del>ERROR</del>	Flow: <del>ERROR</del>	576	576	576	+.2	.8	✓
11:00	Total: 41700643	Total: <del>ERROR</del>	Total: <del>ERROR</del>						
11:55	Flow: 23078	Flow: <del>ERROR</del>	Flow: <del>ERROR</del>	576	576	576	+.2	.8	✓
11:55	Total: 42937440	Total: <del>ERROR</del>	Total: <del>ERROR</del>	60472	60472	60472			

PUMP OPERATOR: *Rubow*  
Date: *11-24-15*

VERIFIED BY PUMP COORDINATOR: *[Signature]*  
Date: *11-24-2015*

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 2

NORTH PUMPING STATION HOURLY LOG SHEET									
	Month			Day			Year		
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	RPM East Pump	RPM Center Pump	RPM West Pump	North Canal Level North of 344 St	South Canal Level South of 344 St	System Checks Sat
13:00	Flow:	Flow:	Flow:						
13:00	Total:	Total:	Total:						
14:00	Flow:	Flow:	Flow:						
14:00	Total:	Total:	Total:						
15:00	Flow:	Flow:	Flow:						
15:00	Total:	Total:	Total:						
16:00	Flow:	Flow:	Flow:						
16:00	Total:	Total:	Total:						
17:00	Flow:	Flow:	Flow:						
17:00	Total:	Total:	Total:						
18:00	Flow:	Flow:	Flow:						
18:00	Total:	Total:	Total:						
19:00	Flow:	Flow:	Flow:						
19:00	Total:	Total:	Total:						
20:00	Flow:	Flow:	Flow:						
20:00	Total:	Total:	Total:						
21:00	Flow:	Flow:	Flow:						
21:00	Total:	Total:	Total:						
22:00	Flow:	Flow:	Flow:						
22:00	Total:	Total:	Total:						
23:00	Flow:	Flow:	Flow:						
23:00	Total:	Total:	Total:						
24:00	Flow:	Flow:	Flow:						
24:00	Total:	Total:	Total:						

**PUMP OPERATOR** \_\_\_\_\_

**VERIFIED BY PUMP COORDINATOR** \_\_\_\_\_  
Date: \_\_\_\_\_

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 3

### South Pump Operator Roles and Responsibilities

The AWE South Pump Operator is responsible for the safe operation of the two 36" axial pumps. All pumping evolutions will be at the direction of the Pump Coordinator except if an emergency shutdown is required. All events or equipment issues will be documented in the enclosed Event Log and will be immediately reported to the Pump Coordinator.

Responsibilities of the Pump Operator include but are not limited to the following items:

- Maintaining the safe operation of the South Pumping Station and performing and logging required periodic maintenance/lubrication of pump equipment
- Ensuring Pump Stations remain in compliance with the:
  - Class 1 Construction permit, permit # CLI-2014-0312
  - South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-WU/ROW/ERP
  - Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)
- Communicating any issues with pump performance or compliance with the permit to the Pump Coordinator
- Performing Emergency Response activities to address an evacuation order
- Monitor the transformer containment pad daily and drain the water when it rains
- Maintaining Pump flows at the direction of the Pump Coordinator
- Perform Manatee and crocodile watch when pumps are running (Polarized lenses are required for Manatee watch)
- Perform all designated routines, readings and recordings throughout the shift including maintaining housekeeping standards at the South Pumping Station
- Maintain a 24 hour Event Log of daily activities, 11:59hrs through 11:58hrs the next day (to be part of the submittal)
- Maintaining 24/7 coverage of the South Pump Station when the South Pumps are operational





# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 3

SOUTH PUMP STATION HOURLY LOG SHEET							Month	Day	Year
Time	North Pump (107944)	South Pump (107939)	RPM No.Pump	RPM So.Pump	South Canal Level	System Checks Sat			
00:00	Flow:	Flow:							
00:00	Total:	Total:							
1:00	Flow:	Flow:							
1:00	Total:	Total:							
2:00	Flow:	Flow:							
2:00	Total:	Total:							
3:00	Flow:	Flow:							
3:00	Total:	Total:							
4:00	Flow:	Flow:							
4:00	Total:	Total:							
5:00	Flow:	Flow:							
5:00	Total:	Total:							
6:00	Flow:	Flow:							
6:00	Total:	Total:							
7:00	Flow:	Flow:							
7:00	Total:	Total:							
8:00	Flow:	Flow:							
8:00	Total:	Total:							
9:00	Flow:	Flow:							
9:00	Total:	Total:							
10:00	Flow:	Flow:							
10:00	Total:	Total:							
11:00	Flow:	Flow:							
11:00	Total:	Total:							
12:00	Flow:	Flow:							
12:00	Total:	Total:							

PUMP OPERATOR \_\_\_\_\_

VERIFIED BY PUMP COORDINATOR \_\_\_\_\_

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 3

SOUTH PUMP STATION HOURLY LOG SHEET						
Time	North Pump (107944)	South Pump (107939)	RPM No.Pump	RPM So.Pump	South Canal Level	System Checks Sat
13:00	Flow:	Flow:				
13:00	Total:	Total:				
14:00	Flow:	Flow:				
14:00	Total:	Total:				
15:00	Flow:	Flow:				
15:00	Total:	Total:				
16:00	Flow:	Flow:				
16:00	Total:	Total:				
17:00	Flow:	Flow:				
17:00	Total:	Total:				
18:00	Flow:	Flow:				
18:00	Total:	Total:				
19:00	Flow:	Flow:				
19:00	Total:	Total:				
20:00	Flow:	Flow:				
20:00	Total:	Total:				
21:00	Flow:	Flow:				
21:00	Total:	Total:				
22:00	Flow:	Flow:				
22:00	Total:	Total:				
23:00	Flow:	Flow:				
23:00	Total:	Total:				
24:00	Flow:	Flow:				
24: 00	Total:	Total:				

**PUMP OPERATOR** \_\_\_\_\_

Date \_\_\_\_\_

**VERIFIED BY PUMP  
COORDINATOR** \_\_\_\_\_

Date: \_\_\_\_\_

ELSCCASH  
Kyle Carr

Rev 8, 10/01/2015

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Revision No. 08

Author: *Patricia Ward* Date: 10/1/15

Approved: *Pat Swartz* Date: 10/1/15

Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure.

Revision 8: Added requirement for validating CCS level margin prior to starting L31 pumps

11/23  
Pump Run  
South Pumping Station  
36,547,385 Gallons

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## TABLE OF CONTENTS

### SECTION

<i>DEC</i> <b>1.0</b>	<b>PURPOSE.....</b>	<b>3</b>
<i>DEC</i> <b>2.0</b>	<b>PRECAUTIONS AND LIMITATIONS.....</b>	<b>3</b>
<i>DEC</i> <b>3.0</b>	<b>PREREQUISITES.....</b>	<b>4</b>
<i>DEC</i> <b>4.0</b>	<b>NORMAL OPERATIONS</b>	
	4.1 North Pumping Station Start-up.....	5
<i>DEC</i>	4.2 South Pumping Station Start-up.....	6
<i>DEC</i>	4.3 South Pumping Station Shutdown.....	7
	4.4 North Pumping Station Shutdown.....	8
<i>DEC</i> <b>5.0</b>	<b>INFREQUENT OPERATIONS</b>	
<i>DEC</i>	5.1 Emergency shutdown of pump stations.....	9
<i>DEC</i> <b>6.0</b>	<b>RECORDS.....</b>	<b>11</b>
<i>DEC</i> <b>7.0</b>	<b>REFERENCES AND COMMITMENTS.....</b>	<b>11</b>

### ATTACHMENTS

ATTACHMENT 1	Pump Coordinator Roles and Responsibilities.....	12
ATTACHMENT 2	North Pump Operator Roles and Responsibilities.....	15
ATTACHMENT 3	South Pump Operator Roles and Responsibilities.....	20

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

### 1.0 PURPOSE

This procedure provides instructions for operating the North and South Pumping Stations to inject L31 Canal Water into the Canal Cooling System (CCS). The North Pumping Station consists of 3 (three) axial flow pumps, West 30" Pump, Center 30" Pump and East 30" Pump. The South Pumping Station consists of 2 (two) axial pumps, North 36" Pump and the South 36" Pump. Two shifts will be utilized to operate the pumping stations. Each shift will consist of a FPL Pump Coordinator, and One (1) AWE Pump Operator.

### 2.0 PRECAUTIONS AND LIMITATIONS

#### 2.1 Precautions

- ① Working over or around water requires either a personal flotation device or appropriate fall protection.
- ② When work is to be performed on equipment in the water then 30" ring buoys with 90' of line shall be available with a lifesaving skiff at the work location.
- ③ Each shift should be familiar with the layout of each station specifically the location of floatation devices, spill kits, emergency shutdown equipment, fire extinguisher and logbooks that include all contact information.
- ④ Pump operation should be controlled using the Variable Frequency Drive (VFDs).
- ⑤ Pump control container live panel access is restricted to certified electricians

#### 2.2 Limitations

- ① Prior to Pump Operation, CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches. Management notification is required if freeboard level is less than 7 inches. No pump operation is allowed if freeboard level is less than 5 inches.
- ② When both pumping stations are capable of pumping they are to be manned continuously by a dedicated operator.
- ③ The North Pumping Station is always to be started first with a minimum of 5 minutes operation prior to starting the South Pumping Station.

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE**

④<sub>REC</sub> The South Pumping Station is always to be stopped first with a minimum of 5 minutes prior to stopping the North Pumping Station.

⑤<sub>REC</sub> Water level in the south canal shall not be allowed to decrease less than the initial level that the pumps were first started.

⑥<sub>REC</sub> Pump control container access is restricted to AWE operators and FPL oversight.

**3.0 PREREQUISITES**

①<sub>REC</sub> Prior to Pump Operation, CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches. Management notification is required if freeboard level is less than 7 inches. No pump operation is allowed if freeboard level is less than 5 inches.

②<sub>REC</sub> Ensure staff gauges are installed at both pump locations and verify that level can be visibly determined and recorded hourly when the pumps are capable of pumping. Ensure canal level indication is available from the data loggers.

③<sub>REC</sub> Ensure flow measuring devices are energized and not indicating any faults.

④<sub>REC</sub> Ensure data loggers are energized and ready to operate.

⑤<sub>REC</sub> Verify floating turbidity curtain and secondary debris screens (fence) are intact and positioned to encompass the pump location.

⑥<sub>REC</sub> Ensure logbooks are at each pump station

⑦<sub>REC</sub> Review the criteria for emergency shutdown of the pumps:

- ⑧<sub>REC</sub> Manatees or crocodiles noted less than 50 feet from the pumps
- ⑨<sub>REC</sub> Excessive pipe movement
- ⑩<sub>REC</sub> Excessive leakage on pump discharge piping
- ⑪<sub>REC</sub> Significant shore erosion since the last inspection
- ⑫<sub>REC</sub> When directed by either Pump Operator or the Pump Coordinator
- ⑬<sub>REC</sub> Erratic pump motor amperage (> ± 10% of benchmark full flow value)

**4.0 NORMAL OPERATIONS**

⑭<sub>REC</sub> When normal pumping cycles are imminent, the pump Operation will be fully staffed for 18 hour operation, 7 day per week. This staff will be comprised of a day and night

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

shift coverage which will include One (1) vendor supplied pump operator, and One (1) FPL Project Team member per shift.

② The on shift FPL Project Team member will be responsible for monitoring the SFWMD website a minimum once every 15 minutes for the 504 acre-feet threshold. In addition the FPL PTN Chemistry Department will perform hourly monitoring of the SFWMD website with notifications to the Chemistry Manager and PGM if transfer volume reaches 400 acre-feet.

③ Prior to Pump Operation:

④ Verify CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches.

④ Management notification is required if freeboard level is less than 7 inches to provide:

④ canal level data

④ general canal status

④ weather forecast that may add to the CCS level.

④ After reaching 504 acre-feet notification shall be made to Ray Moore and/or Alan Katz after commencing and/or securing pump operation.

④ Any questions or concerns that should arise during either shift of operation shall be vetted through Ray Moore or Alan Katz.

### 4.1 North Pumping Station Start-up

#### **CAUTION**

***The North Pumping Station is always to be started a minimum of 5 minutes operation prior to starting the South Pumping Station.***

1. Ensure North Pump Operator has reviewed ATTACHMENT 2, North Pump Operator Roles and Responsibilities.
2. Pre-Start Up Check List:
  - external leakage
  - perform pre-start checks
  - Signs of shore erosion
  - Excessive pipe movement
  - Verify Grass and Trash are clear from inside Turbidity Curtain
  - Erratic Motor Amperage
  - Verify CCS is clear at South Discharge

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

3. Monitor South Florida Water Management District and confirm the SFWMD flow authorization for the next pumping period until 11:59 PM and document below (bay delivery point of 504 acre-feet).
4. Record the canal levels at the North and South canal and document on Attachment 2 for North and Attachment 3 for South.

**CAUTION**

***Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started***

5. Verify Flow indicators are energized for the pump discharge headers on Attachment 2 for North and Attachment 3 for South.
6. Turn Pump ON
  - Check for Manatee and Wildlife
  - Verify pump Breaker is ON
  - Verify Main Breaker is ON
  - verify SWITCH is turned to VFD
  - Verify HZ is set a desired setting (60HZ = full power)
  - PUSH START button
  - Verify Water is Flowing from motor tube
7. Verify water flow is observed at the south side of Palm Drive and document on Attachment 2.

*DFC*  
**4.2** South Pumping Station Start-up  
*DKC*

**CAUTION** *DKC*

***The North Pumping Station is always to be started a minimum of 5 minutes operation prior to starting the South Pumping Station.***

*DKC* Ensure South Pump Operator has reviewed ATTACHMENT 3, South Pump Operator Roles and Responsibilities.

*DKC* Pre-Start Up Check List:

- external leakage

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

- ☐ ☐<sub>KC</sub> perform pre-start checks
- ☐ ☐<sub>KC</sub> Signs of shore erosion
- ☐ ☐<sub>KC</sub> Excessive pipe movement
- ☐ ☐<sub>KC</sub> Verify Grass and Trash are Cleared inside Turbidity Curtain
- ☐ ☐<sub>KC</sub> Erratic Motor Amperage
- ☐ ☐<sub>KC</sub> Verify CCS is clear at the Discharge

☐ ☐<sub>KC</sub> Verify Flow indicators are energized for the pump discharge headers. Document on Attachment 3.

☐ ☐<sub>KC</sub> Record the Total flow rate from the North Pumping Station on Attachment 3.

☐ ☐<sub>KC</sub> Record the canal levels at the North and South canal and document on Attachment 2 for North and Attachment 3 for South.

**CAUTION** <sub>KC</sub>

***Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started***

☐ ☐<sub>KC</sub> Verify that the North Station Pump(s) are Operating

☐ ☐<sub>KC</sub> Turn Pump ON

☐ ☐<sub>KC</sub> Check for Manatee and Wildlife

☐ ☐<sub>KC</sub> Verify pump Breaker is ON

☐ ☐<sub>KC</sub> Verify Main Breaker is ON

☐ ☐<sub>KC</sub> verify SWITCH is turned to VFD

☐ ☐<sub>KC</sub> Verify HZ is set a desired setting (60HZ = full power)

☐ ☐<sub>KC</sub> PUSH START button

☐ ☐<sub>KC</sub> Verify Water is Flowing from motor tube

☐ ☐<sub>KC</sub> Verify water flow is observed at the Cooling Canal System and document on Attachment 3.

### 4.3 South Pumping Station Shutdown

**CAUTION** <sub>KC</sub>

***The South Pumping Station is always to be stopped a minimum of 5 minutes prior to stopping the North Pumping Station.***

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

① KC Verify that the Injection of L31 Canal Water to the Canal Cooling System is to be shutdown.

**CAUTION** KC

*Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started*

② KC Record the canal levels at the North and South canal and document on Attachment 2 and Attachment 3

③ KC Shutdown Pump

④ KC Read TOTALIZER PRIOR to turning pump off

⑤ KC Push OFF button

⑥ KC Allow Frequency to COAST down to 00:00

⑦ KC HZ Reading will remain the same

⑧ KC Listen for pump to STOP RUNNING

⑨ KC Once you have verified pump has come to COMPLETE STOP

⑩ KC Turn SWITCH to OFF (ONE CLICK ONLY)

⑪ KC Verify water flow is observed to stop at the Canal Cooling System.

⑫ KC Record the shutdown time and flow volume totals of the South Pumping Station on ATTACHMENT 3, South Pump Operator Roles and Responsibilities.

⑬ KC Check out the system for:

⑭ KC Visual inspect for excess grass and trash and document in log

⑮ KC Signs of shore erosion

⑯ KC Read staff gauge and continue to log for an additional 10 minutes

⑰ KC Verify the South Pumping Station is shutdown prior to shutting down the North Pumping Station.

## 4.4 North Pumping Station Shutdown

**CAUTION**

*The South Pumping Station is always to be stopped a minimum of 5 minutes prior to stopping the North Pumping Station.*

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

1. Verify that the South Pumping Station is shut down

**CAUTION**

***Water level in the South Canal shall not be allowed to decrease less than the initial level that the Pumps were started***

2. Record the canal levels at the North and South canal and document on Attachment 2 and Attachment 3
3. Shutdown Pump
  - Read TOTALIZER PRIOR to turning pump off
  - Push OFF button
  - Allow Frequency to COAST down to 00:00
  - HZ Reading will remain the same
  - Listen for pump to STOP RUNNING
  - Once you have verified pump has come to COMPLETE STOP
  - Turn SWITCH to OFF (ONE CLICK ONLY)
4. Shutdown the running pumps at the North Pumping Station and verify water flow is observed to stop at the south side of Palm Drive.
5. Record the shutdown time and flow volume totals of the North Pumping Station on ATTACHMENT 2, North Pump Operator Roles and Responsibilities.
6. Check out the system for:
  - Visual inspect for excess grass and trash and document in log
  - Signs of shore erosion
  - Read staff gauge and continue to log for an additional 10 minutes
7. Notify the Water District Management that Injection of L31 Canal Water to the Canal Cooling System is shutdown. SFWMD Operation Control Center 561-682-6116.

DEC  
5.0 INFREQUENT OPERATIONS  
DKC

5.1 Emergency shutdown of pump stations  
DEC

### INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

1. Immediately stop the Pumps and notify the Pump Coordinator and the other Pump Station that flow has stopped when any of the following conditions apply:

Erratic pump motor amperage indicative of suction blockage

Intake grate fouling that is degrading pump performance

Manatees or crocodiles noted less than 50 feet from the pumps

Excessive pipe movement

Excessive leakage on pump discharge piping

Emergency evacuation order

Significant shore erosion since the last inspection

When directed by either Pump Operator

2. Pump Coordinator to notify the SFWM of the reason that the pumps were immediately shutdown.

3. Notify Environmental of the reason that the pumps were immediately shutdown and request assistance as required.

4. Pump Coordinator shall document the date/time of the event total flow volume pumped and a description of actions taken and persons notified.

Date/Time: \_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_

---

---

---

---

---

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

### 6.0 RECORDS

The Pump Coordinator is to scan and transmit the North and South Pump Operator daily log readings each day to Environmental for subsequent submittal to DERM/SFWDM. Transfer electronic copies to WO 40379504 Documents EDMS file folder.

### 7.0 REFERENCES AND COMMITMENTS

- Class 1 Construction permit, permit # CLI-2014-0312
- South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-WU/ROW/ERP
- Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)
- Taylor Engineering FPL PTN Cooling Canal Freshwater Recharge
- PTN Engineering Change (EC) 282152

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 1

### Pump Coordinator Roles and Responsibilities

The FPL Pump Coordinator is the main point of contact for all activities associated with the injection of L31 Canal water into the Canal Cooling System.

The Pump Coordinator will report to FPL Environmental and will provide direction to the Pump Operators on Starting and Stopping of the pumps including infrequent operations involving the emergency shutdown of all pumping equipment.

Responsibilities of the Pump Coordinator include but are not limited to the following items:

- Maintaining the safe operation of the North and South Pumping Stations
- Briefing the Pump Operators on their roles and responsibilities
- Ensuring Pump Stations remain in compliance with the:
  - Class 1 Construction permit, permit # CLI-2014-0312
  - South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-WU/ROW/ERP
  - Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)
- Communicating any issues with pump performance or compliance with the permit to the Control Room and Environmental
- Coordination of Emergency Response activities to address an evacuation
- Obtaining the daily water pump start authorization and maintaining Pumping Stations in compliance with the SFWMD permitted pumping start time. Authorization is defined as after the daily SFWMD bay discharge quota is reached.
- Coordinating Pump starts/stops at the North and South Pumping Stations
- Ensuring Pump Operator performs all designated routines throughout the shift
- Maintain a 24 hour Event Log of daily activities, 11:59hrs through 11:58hrs the next day (to be part of the submittal)

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE****ATTACHMENT 1****Pump Coordinator Roles and Responsibilities**

- Periodically inspect each Pump Station (approx. once per 3hrs) to verify and validate (V&V) recorded data of the operators and conduct of Pump Operations
- Maintaining 24/7 coverage of the Pump Stations when the North and South Pumps are operational
- Maintaining housekeeping standards at the North and South Pumping Stations
- Scan and transfer reports daily of pump data to FPL Environmental at 11:59 AM or shortly thereafter each day. Transfer electronic copy to WO 40379504 EDMS file.

## Contact information

Control Room	-	Shift Manager	X6492
Control Room	-	Emergency	X4444
Rory Rahming	-	Environmental	786-427-7437
Nan Sweeney	(Dayshift) -	Pump Coordinator	570-241-8135
Willis Nettles	(Night Shift)-	Pump Coordinator	772-473-1041

Coastal and Wetlands Resource Section		305-372-6575
FWC	<a href="mailto:ImperiledSpecies@myFWC.com">ImperiledSpecies@myFWC.com</a>	
FWC Hotline		888-404-3922
U.S. Fish and Wildlife Service		772-562-3909
State of Florida Bureau Archaeological Research		850-245-6444
Miami-Dade County Office of Historic Preservation		305-375-3412

DERM Coastal and Wetlands Resource Compliance Supervisor  
 John Ricisak [ricisj@miamidade.gov](mailto:ricisj@miamidade.gov)  
 DERM Coastal and Wetlands Resource Permitting Supervisor  
 Christine Hopps [hoppsc@miamidade.gov](mailto:hoppsc@miamidade.gov)

## SFWMD:

Executive Director, Len Lindahl, [LLindahl@sfwmd.gov](mailto:LLindahl@sfwmd.gov)  
 Water Resources Division Director, Terri Bates, [tbates@sfwmd.gov](mailto:tbates@sfwmd.gov)  
 Water Resources Hydrologist, Simon Sunderland, P.G, [ssunder@sfwmd.gov](mailto:ssunder@sfwmd.gov)  
 Bureau Chief, Maria Clemente, P.E. at [mclement@sfwmd.gov](mailto:mclement@sfwmd.gov)

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

ATTACHMENT 1

Pump Coordinator Roles and Responsibilities

11/23  
Pump Run

Date / Time EVENT LOG BOOK Page 1 of 1

11/24/1045 Set up pump Stations & Wildlife Checks

11/24/1224 Started North pumps

11/24/1229 Started South pumps

10300 North pump Station 2,369,952

10300 South pump Station 2,030,810

10400 South pump Station 3,888,720

10400 North pump Station 3,906,360

10500 NORTH pump STATION 3,912,510

10500 SOUTH pump STATION 3,864,270

10600 NORTH pump STATION 3,895,650

10600 SOUTH pump STATION 3,863,430

10700 NORTH pump STATION 3,877,980

10700 SOUTH pump STATION 3,880,410

10800 NORTH pump STATION 3,890,310

10800 SOUTH pump STATION 3,862,470

10900 NORTH pump STATION 3,892,680

10900 SOUTH pump STATION 3,973,530

11000 NORTH pump STATION 3,888,480

11000 SOUTH pump STATION 3,920,010

11100 NORTH pump STATION 3,895,920

11100 SOUTH pump STATION 3,939,060

11155 NORTH pump STATION 3,580,885

11150 SOUTH pump STATION 3,324,675

TOTAL Gallons pumped by NORTH STATION = 37,110,727  
 TOTAL Gallons pumped by SOUTH STATION = 36,547,385

Mike Gallagher  
 Mike Gallagher  
 11-24-15

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 2

### North Pump Operator Roles and Responsibilities

The AWE North Pump Operator is responsible for the safe operation of the three submersible pumps and associated variable speed drives and instrumentation. All pumping evolutions will be at the direction of the Pump Coordinator except if an emergency shutdown is required.

All events or equipment issues will be documented in the enclosed Event Log and will be immediately reported to the Pump Coordinator. Responsibilities of the Pump Operator include but are not limited to the following items:

- Maintaining the safe operation of the North Pumping Stations and performing and logging required periodic maintenance/lubrication of pump equipment Prior to Pump Operation, CCS level at the Turtle Point shall have a minimum freeboard level of 7 inches.
- Management notification is required if freeboard level is less than 7 inches to provide canal level data, general canal status, and weather forecast that may add to the CCS level. No pump operation is allowed if freeboard level is less than 5 inches.
- Ensuring Pump Stations remain in compliance with the:
  - Class 1 Construction permit, permit # CLI-2014-0312
  - South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-WU/ROW/ERP
  - Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)
- Communicating any issues with pump performance or compliance with the permit to the Pump Coordinator
- Performing Emergency Response activities to address an evacuation order or a fuel/oil spill
- Ensure spill response equipment maintained in good condition
- Maintaining Pump flows at the direction of the Pump Coordinator
- Perform Manatee and crocodile watch when pumps are running (Polarized lenses are required for Manatee watch)
- Perform all designated routines, readings and recordings throughout the shift including maintaining housekeeping standards at the North Pumping Station
- Maintain a 24 hour Event Log of daily activities, 11:59hrs through 11:58hrs the next day(to be part of the submittal)
- Maintaining 24/7 coverage of the North Pump Station when the North Pumps are operational





# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 2

NORTH PUMPING STATION HOURLY LOG SHEET				Month	Day	Year			
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	RPM East Pump	RPM Center Pump	RPM West Pump	North Canal Level North of 344 St	South Canal Level South of 344 St	System Checks Sat
00:00	Flow:	Flow:	Flow:						
00:00	Total:	Total:	Total:						
1:00	Flow:	Flow:	Flow:						
1:00	Total:	Total:	Total:						
2:00	Flow:	Flow:	Flow:						
2:00	Total:	Total:	Total:						
3:00	Flow:	Flow:	Flow:						
3:00	Total:	Total:	Total:						
4:00	Flow:	Flow:	Flow:						
4:00	Total:	Total:	Total:						
5:00	Flow:	Flow:	Flow:						
5:00	Total:	Total:	Total:						
6:00	Flow:	Flow:	Flow:						
6:00	Total:	Total:	Total:						
7:00	Flow:	Flow:	Flow:						
7:00	Total:	Total:	Total:						
8:00	Flow:	Flow:	Flow:						
8:00	Total:	Total:	Total:						
9:00	Flow:	Flow:	Flow:						
9:00	Total:	Total:	Total:						
10:00	Flow:	Flow:	Flow:						
10:00	Total:	Total:	Total:						
11:00	Flow:	Flow:	Flow:						
11:00	Total:	Total:	Total:						
12:00	Flow:	Flow:	Flow:						
12:00	Total:	Total:	Total:						

PUMP OPERATOR \_\_\_\_\_  
Date \_\_\_\_\_

VERIFIED BY PUMP COORDINATOR \_\_\_\_\_  
Date: \_\_\_\_\_

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 2

NORTH PUMPING STATION HOURLY LOG SHEET				Month	Day	Year			
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	RPM East Pump	RPM Center Pump	RPM West Pump	North Canal Level North of 344 St	South Canal Level South of 344 St	System Checks Sat
13:00	Flow:	Flow:	Flow:						
13:00	Total:	Total:	Total:						
14:00	Flow:	Flow:	Flow:						
14:00	Total:	Total:	Total:						
15:00	Flow:	Flow:	Flow:						
15:00	Total:	Total:	Total:						
16:00	Flow:	Flow:	Flow:						
16:00	Total:	Total:	Total:						
17:00	Flow:	Flow:	Flow:						
17:00	Total:	Total:	Total:						
18:00	Flow:	Flow:	Flow:						
18:00	Total:	Total:	Total:						
19:00	Flow:	Flow:	Flow:						
19:00	Total:	Total:	Total:						
20:00	Flow:	Flow:	Flow:						
20:00	Total:	Total:	Total:						
21:00	Flow:	Flow:	Flow:						
21:00	Total:	Total:	Total:						
22:00	Flow:	Flow:	Flow:						
22:00	Total:	Total:	Total:						
23:00	Flow:	Flow:	Flow:						
23:00	Total:	Total:	Total:						
24:00	Flow:	Flow:	Flow:						
24:00	Total:	Total:	Total:						

**PUMP OPERATOR** \_\_\_\_\_

**VERIFIED BY PUMP COORDINATOR** \_\_\_\_\_  
Date: \_\_\_\_\_

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 3

### South Pump Operator Roles and Responsibilities

The AWE South Pump Operator is responsible for the safe operation of the two 36" axial pumps. All pumping evolutions will be at the direction of the Pump Coordinator except if an emergency shutdown is required. All events or equipment issues will be documented in the enclosed Event Log and will be immediately reported to the Pump Coordinator.

Responsibilities of the Pump Operator include but are not limited to the following items:

- Maintaining the safe operation of the South Pumping Station and performing and logging required periodic maintenance/lubrication of pump equipment
- Ensuring Pump Stations remain in compliance with the:
  - Class 1 Construction permit, permit # CLI-2014-0312
  - South Florida Water Management District Emergency Order, SFWMD No. 2015-034-DAO-WU/ROW/ERP
  - Army Corps of Engineer Permit, SAJ-2014-02451 (NWP/GP-MLC)
- Communicating any issues with pump performance or compliance with the permit to the Pump Coordinator
- Performing Emergency Response activities to address an evacuation order
- Monitor the transformer containment pad daily and drain the water when it rains
- Maintaining Pump flows at the direction of the Pump Coordinator
- Perform Manatee and crocodile watch when pumps are running (Polarized lenses are required for Manatee watch)
- Perform all designated routines, readings and recordings throughout the shift including maintaining housekeeping standards at the South Pumping Station
- Maintain a 24 hour Event Log of daily activities, 11:59hrs through 11:58hrs the next day (to be part of the submittal)
- Maintaining 24/7 coverage of the South Pump Station when the South Pumps are operational





INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

ATTACHMENT 3

SOUTH PUMP STATION HOURLY LOG SHEET						
Time	North Pump (107944)	South Pump (107939)	RPM No. Pump	RPM So. Pump	South Canal Level	System Checks Sat
00:00	Flow:	Flow:				
00:00	Total:	Total:				
1:00	Flow:	Flow:				
1:00	Total:	Total:				
<del>2:00</del> 2:29	Flow: 33000	Flow: 30891	588	588	0.75	✓
<del>2:00</del> 2:29	Total: 48408723	Total: 54030828			0.75	✓
3:00	Flow: 34129	Flow: <del>30948</del> 35082	588	588	0.75	✓
3:00	Total: 49436956	Total: 55132256				
4:00	Flow: 33423	Flow: 31071	588	588	0.75	✓
4:00	Total: 51447801	Total: 57334599				
5:00	Flow: 33348	Flow: 30967	588	588	0.75	✓
5:00	Total: 53465091	Total: 59874976				
6:00	Flow: 33317	Flow: 31149	588	588	.75	✓
6:00	Total: 55209330	Total: 61585563				
7:00	Flow: 33779	Flow: 31102	588	588	.75	✓
7:00	Total: 57423277	Total: 63958405				
8:00	Flow: 35532	Flow: 25330	588	588	.75	✓
8:00	Total: 59484116	Total: 65728516				
9:00	Flow: 33919	Flow: ERROR	588	588	.75	✓
9:00	Total: 61506964	Total: 65910788				
10:00	Flow: 33746	Flow: ERROR	588	588	.75	✓
10:00	Total: 6375654	Total: 65910788				
11:00	Flow: 31554	Flow: ERROR	588	588	.75	✓
11:00	Total: 6647007	Total: ERROR				
12:00	Flow: 35133	Flow: ERROR	588	588	.75	✓
12:00	Total: 6915653	Total: ERROR				

PUMP OPERATOR ERIC CASH  
Date 11/24/15

VERIFIED BY PUMP COORDINATOR Mike Kelly  
11-24-2015

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## ATTACHMENT 3

SOUTH PUMP STATION HOURLY LOG SHEET						
Time	North Pump (107944)	South Pump (107939)	RPM No.Pump	RPM So.Pump	South Canal Level	System Checks Sat
13:00	Flow:	Flow:				
13:00	Total:	Total:				
14:00	Flow:	Flow:				
14:00	Total:	Total:				
15:00	Flow:	Flow:				
15:00	Total:	Total:				
16:00	Flow:	Flow:				
16:00	Total:	Total:				
17:00	Flow:	Flow:				
17:00	Total:	Total:				
18:00	Flow:	Flow:				
18:00	Total:	Total:				
19:00	Flow:	Flow:				
19:00	Total:	Total:				
20:00	Flow:	Flow:				
20:00	Total:	Total:				
21:00	Flow:	Flow:				
21:00	Total:	Total:				
22:00	Flow:	Flow:				
22:00	Total:	Total:				
23:00	Flow:	Flow:				
23:00	Total:	Total:				
24:00	Flow:	Flow:				
24:00	Total:	Total:				

**PUMP OPERATOR** \_\_\_\_\_  
Date \_\_\_\_\_

**VERIFIED BY PUMP  
COORDINATOR** \_\_\_\_\_  
Date: \_\_\_\_\_

# Pump Run 11/24

Rev 8, 10/01/2015

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

### ATTACHMENT 1

### Pump Coordinator Roles and Responsibilities

Date / Time	EVENT LOG BOOK	Page _ of _
11/25/1200	Did not Reach 504 acre feet.	
/	Did not pump	
/		
/		Pump co-ordinator
/		
/		
/		Kenneth Spring
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM  
ATTACHMENT 2**

<b>NORTH PUMPING STATION HOURLY LOG SHEET</b> Month <b>11</b> Day <b>24</b> Year <b>2015</b>						
Time	West Pump (107942)	Center Pump (107941)	East Pump (107940)	North Canal Level	South Canal Level	System Check/Stat
00:00	Flow: Total:	Flow: Total:	Flow: Total:			
01:00	Flow: Total:	Flow: Total:	Flow: Total:			
02:00	Flow: Total:	Flow: Total:	Flow: Total:			
03:00	Flow: Total:	Flow: Total:	Flow: Total:			
04:00	Flow: Total:	Flow: Total:	Flow: Total:			
05:00	Flow: Total:	Flow: Total:	Flow: Total:			
06:00	Flow: Total:	Flow: Total:	Flow: Total:			
07:00	Flow: Total:	Flow: Total:	Flow: Total:			
08:00	Flow: Total:	Flow: Total:	Flow: Total:			
09:00	Flow: Total:	Flow: Total:	Flow: Total:			
10:00	Flow: Total:	Flow: Total:	Flow: Total:			
11:00	Flow: Total:	Flow: Total:	Flow: Total:			
12:00	Flow: Total:	Flow: Total:	Flow: Total:			
13:00	Flow: Total:	Flow: Total:	Flow: Total:			
14:00	Flow: Total:	Flow: Total:	Flow: Total:			
15:00	Flow: Total:	Flow: Total:	Flow: Total:			
16:00	Flow: Total:	Flow: Total:	Flow: Total:			
17:00	Flow: Total:	Flow: Total:	Flow: Total:			
18:00	Flow: Total:	Flow: Total:	Flow: Total:			
19:00	Flow: Total:	Flow: Total:	Flow: Total:			
20:00	Flow: Total:	Flow: Total:	Flow: Total:			
21:00	Flow: Total:	Flow: Total:	Flow: Total:			
22:00	Flow: Total:	Flow: Total:	Flow: Total:			
23:00	Flow: Total:	Flow: Total:	Flow: Total:			
23:59	Flow: Total:	Flow: Total:	Flow: Total:			

**LESS THAN 504**  
**NO WATER ALLOTTED**  
*Nannette Sweeney*  
*Nannette Sweeney*  
**11/24/15**

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM  
ATTACHMENT 3**

<b>SOUTH PUMP STATION HOURLY LOG SHEET</b>							Month	<b>11</b>	Day	<b>24</b>	Year	<b>2015</b>
Time	North Pump (107944)	South Pump (107939)		North Canal Level	South Canal Level	System Check Sat						
00:00	Flow: Total:	Flow: Total:										
01:00	Flow: Total:	Flow: Total:										
02:00	Flow: Total:	Flow: Total:										
03:00	Flow: Total:	Flow: Total:										
04:00	Flow: Total:	Flow: Total:										
05:00	Flow: Total:	Flow: Total:										
06:00	Flow: Total:	Flow: Total:										
07:00	Flow: Total:	Flow: Total:										
08:00	Flow: Total:	Flow: Total:										
09:00	Flow: Total:	Flow: Total:										
10:00	Flow: Total:	Flow: Total:										
11:00	Flow: Total:	Flow: Total:										
12:00	Flow: Total:	Flow: Total:										
13:00	Flow: Total:	Flow: Total:										
14:00	Flow: Total:	Flow: Total:										
15:00	Flow: Total:	Flow: Total:										
16:00	Flow: Total:	Flow: Total:										
17:00	Flow: Total:	Flow: Total:										
18:00	Flow: Total:	Flow: Total:										
19:00	Flow: Total:	Flow: Total:										
20:00	Flow: Total:	Flow: Total:										
21:00	Flow: Total:	Flow: Total:										
22:00	Flow: Total:	Flow: Total:										
23:00	Flow: Total:	Flow: Total:										
23:59	Flow: Total:	Flow: Total:										

**LESS THAN 504**  
**NO WATER ALLOTTED**  
*Nannette Sweeney*  
*Nannette Sweeney*  
**11/24/15**

# Pump Run 11/25

Rev 8, 10/01/2015

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

### ATTACHMENT 1

### Pump Coordinator Roles and Responsibilities

Date / Time

EVENT LOG BOOK

Page \_ of \_

11/26/200 Did not reach 504 acre feet.

Did not Pump.

Pump Coordinator

by Kenneth Spitz

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM  
ATTACHMENT 2**

**NORTH PUMPING STATION HOURLY LOG SHEET**    Month **11**    Day **25**    Year **2015**

Time	West Pump (107942)	Center Pump (107941)	East Pump (107940)	North Canal Level	South Canal Level	System Checks/Stat
00:00	Flow: Total:	Flow: Total:	Flow: Total:			
01:00	Flow: Total:	Flow: Total:	Flow: Total:			
02:00	Flow: Total:	Flow: Total:	Flow: Total:			
03:00	Flow: Total:	Flow: Total:	Flow: Total:			
04:00	Flow: Total:	Flow: Total:	Flow: Total:			
05:00	Flow: Total:	Flow: Total:	Flow: Total:			
06:00	Flow: Total:	Flow: Total:	Flow: Total:			
07:00	Flow: Total:	Flow: Total:	Flow: Total:			
08:00	Flow: Total:	Flow: Total:	Flow: Total:			
09:00	Flow: Total:	Flow: Total:	Flow: Total:			
10:00	Flow: Total:	Flow: Total:	Flow: Total:			
11:00	Flow: Total:	Flow: Total:	Flow: Total:			
12:00	Flow: Total:	Flow: Total:	Flow: Total:			
13:00	Flow: Total:	Flow: Total:	Flow: Total:			
14:00	Flow: Total:	Flow: Total:	Flow: Total:			
15:00	Flow: Total:	Flow: Total:	Flow: Total:			
16:00	Flow: Total:	Flow: Total:	Flow: Total:			
17:00	Flow: Total:	Flow: Total:	Flow: Total:			
18:00	Flow: Total:	Flow: Total:	Flow: Total:			
19:00	Flow: Total:	Flow: Total:	Flow: Total:			
20:00	Flow: Total:	Flow: Total:	Flow: Total:			
21:00	Flow: Total:	Flow: Total:	Flow: Total:			
22:00	Flow: Total:	Flow: Total:	Flow: Total:			
23:00	Flow: Total:	Flow: Total:	Flow: Total:			
23:59	Flow: Total:	Flow: Total:	Flow: Total:			

**LESS THAN 504**  
**NO WATER ALLOTTED**  
*Nannette Sweeney*  
*Nannette Sweeney*  
**11/25/15**

**INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM  
ATTACHMENT 3**

**SOUTH PUMP STATION HOURLY LOG SHEET**      Month **11**      Day **25**      Year **2015**

Time	North Pump (107944)	South Pump (107939)		North Canal Level	South Canal Level	System Check Sat
00:00	Flow: Total:	Flow: Total:				
01:00	Flow: Total:	Flow: Total:				
02:00	Flow: Total:	Flow: Total:				
03:00	Flow: Total:	Flow: Total:				
04:00	Flow: Total:	Flow: Total:				
05:00	Flow: Total:	Flow: Total:				
06:00	Flow: Total:	Flow: Total:				
07:00	Flow: Total:	Flow: Total:				
08:00	Flow: Total:	Flow: Total:				
09:00	Flow: Total:	Flow: Total:				
10:00	Flow: Total:	Flow: Total:				
11:00	Flow: Total:	Flow: Total:				
12:00	Flow: Total:	Flow: Total:				
13:00	Flow: Total:	Flow: Total:				
14:00	Flow: Total:	Flow: Total:				
15:00	Flow: Total:	Flow: Total:				
16:00	Flow: Total:	Flow: Total:				
17:00	Flow: Total:	Flow: Total:				
18:00	Flow: Total:	Flow: Total:				
19:00	Flow: Total:	Flow: Total:				
20:00	Flow: Total:	Flow: Total:				
21:00	Flow: Total:	Flow: Total:				
22:00	Flow: Total:	Flow: Total:				
23:00	Flow: Total:	Flow: Total:				
23:59	Flow: Total:	Flow: Total:				

**LESS THAN 504**  
**NO WATER ALLOTTED**  
*Nannette Sweeney*  
*Nannette Sweeney*  
**11/25/15**



## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Author:  Date: 11/25/15

Approved:  Date: 11/25/15

Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure

Revision 8: Added requirement for validation CCS level margin prior to starting L31 pumps

Revision 9: A complete re-write of the procedure which includes L31 pump curves and calculation methodology.

North Station Pumped  
23,412,738 gals

South station Pumped  
22,801,710 gals

North Pumping Station  
Pump Run 11/26/15



Pump Run 11/26

DATA SHEET 1\*FPI PUMP SPREAD SHEET AND CURVES\*Page 1 of 4

AXIAL FLOW PUMP - Daily Report

Date: 11/27/15

Location: L31 North Station

Pump Model: FPI AAF 30-26

Pump Drive Ratio: 1:3.14 Motor: Pump

Discharge Elevation 3.9 feet

System Loss See Chart Below

Permit No: \_\_\_\_\_

Site Description: Three 30" AAF Pumps pumping North to South

\*Note: Static Head is the difference between the upstream static gauge reading and the Discharge Elevation, unless the discharge is submerged. If submerged discharge, the Static head is the difference between Upstream and Downstream static gauges.

Operator Initials	Upstream Static Gauge Pump On		Upstream Static Gauge Pump Off		Pump Run Time Hours	Electric Motor Speed	Pump RPM	Up Stream Static Gauge Reading	Down Stream Static Gauge Reading	Static Head Difference*	System Loss for Chart Below	TDH (Static + System Loss)	Flow Rate Using Adjusted Pump Curve (gpm)	Number Pumps Running	Total Flow (gallons)	Notes:
	Date	Time	Date	Time												
Sample	1/15/2015	5:00:00 PM	1/15/2015	6:00:00 PM	1.00	1800	576	0.6	0.6	3.3	6.00	9.3	23,403	3	4,212,540	
AC	11/27	6:18	11/27	07:00	.42	1800	576	.0	.7	3.9	6.0	9.9	23,025	3	69,084 x 42 = 2,901,528	
AC		7:00		8:00	1	1800	576	.1	.7	3.9	6.0	9.9	23,091	3	69,273 x 60 = 4,156,380	
AC		8:00		9:00	1	1800	576	.2	.7	3.9	6.0	9.9	23,153	3	69,459 x 60 = 4,167,540	
AC		9:00		10:00	1	1800	576	.3	.7	3.9	6.0	9.9	23,215	3	69,645 x 60 = 4,178,700	
AC		10:00		11:00	1	1800	576	.4	.7	3.9	6.0	9.9	23,278	3	69,834 x 60 = 4,190,040	
AC		11:00		11:55	.55	1800	576	.4	.7	3.9	6.0	9.9	23,276	3	69,824 x 55 = 3,840,870	
							0			3.9		3.9			0	
							0			3.9		3.9			0	
							0			3.9		3.9			0	
							0			3.9		3.9			0	
							0			3.9		3.9			0	

Field Entry Columns

Total Flow = 23,412,138 gals  
 Total Pump Time = 5 hours 42 min.


Pump rpm	Q	TDH	Static	System
578	22700	10.1	4.1	6.0
489	18800	8.25	4.1	4.15
460	17900	7.6	4.1	3.5

Use System Loss Nearest pump speed  
 example: 528 rpm use 4.15 system

DATA SHEET \*FPI PUMP SPREAD SHEET AND CURVES\* Page 2 of 4

Motor Pump	1800 rpm	1550 rpm	1800 rpm	573 rpm	494 rpm
TDR (%)	Pump 1100% Flow Rate (gpm)	Pump 80% Flow Rate (gpm)			
7.4	24473	19559			
7.5	24421	19486			
7.6	24370	19414			
7.7	24318	19341			
7.8	24266	19267			
7.9	24212	19192			
8	24157	19117			
8.1	24103	19042			
8.2	24048	18967			
8.3	23994	18892			
8.4	23939	18817			
8.5	23881	18737			
8.6	23822	18658			
8.7	23763	18578			
8.8	23704	18499			
8.9	23645	18419			
9	23586	18340			
9.1	23526	18260			
9.2	23465	18181			
9.3	23403	18101			
9.4	23340	18016			
9.5	23278	17929			
9.6	23215	17842			
9.7	23153	17754			
9.8	23091	17667			
9.9	23028	17580			
10	22966	17493			
10.1	22904	17405			
10.2	22842	17318			
10.3	22779	17231			
10.4	22717	17141			
10.5	22655	17057			
10.6	22593	16963			
10.7	22530	16879			
10.8	22466	16795			

30" Diameter Adjusted Pump Multi Speed Curve



The performance is guaranteed for this design point only when pumping clean water at 65 degrees F. Consult factory for certified performance curve.

Company: FPI 30" Diameter  
 Name: Adjusted Multi Speed  
 9232015

FPI  
 Catalog: FPI 50, Vers 1.1  
 Actual Flow: 600

Size: AF30-26-485  
 Speed: 480 - 610 rpm  
 Unit: A (90)



Pump Run 11/26

# DATA SHEET\*FPI PUMP SPREAD SHEET AND CURVES\*Page 3 of 4

AXIAL FLOW PUMP - Daily Report																
Location: L31 South Station		Date: 11/27/15		Pump Model: FPI AAF 36-30		Pump Drive Ratio: 1:2.88 Motor: Pump		Discharge Elevation: 4.1 feet		System Loss: See Chart Below		Notes:				
Permit No:		Two 36" AAF Pumps pumping West to East		Pump On		Pump Off		Pump Run Time		Electric Motor Speed		Pump RPM		Up Stream Staffage Reading		
Site Description:		Date		Time		Date		Time		Hours		RPM		Reading		
Operator Initials	Pump On Date	Pump On Time	Pump Off Date	Pump Off Time	Pump Run Time	Electric Motor Speed	Pump RPM	Up Stream Staffage Reading	Down Stream Staffage Reading	Static Head Difference*	System Loss for Chart Below	TDH (Static + System Loss)	Flow Rate Using Adjusted Pump Curve (gpm)	Number Pumps Running	Total Flow (gallons)	Notes
Sample	1/15/2015	5:00:00 PM	1/15/2015	6:00:00 PM	1:00	1760	611	0.6	0.25	3.5	14.9	18.4	34,791	2	4,174,920	
K.S.	11/27	6:23	11/27	7:00	.37	1760	630	.7	.7	3.4	18.3	21.7	34,865	2	69,730 x 37 = 2,580,010	
K.S.		7:00		8:00	1	1760	630	.7	.7	3.4	18.3	21.7	34,865	2	69,730 x 60 = 4,183,800	
K.S.		8:00		9:00	1	1760	630	.7	.7	3.4	18.3	21.7	34,865	2	69,730 x 60 = 4,183,800	
K.S.		9:00		10:00	1	1760	630	.7	.7	3.4	18.3	21.7	34,865	2	69,730 x 60 = 4,183,800	
K.S.		10:00		11:00	1	1760	630	.7	.7	3.4	18.3	21.7	34,865	2	69,730 x 60 = 4,183,800	
K.S.		11:00		11:50	.50	1760	630	.7	.7	3.4	18.3	21.7	34,865	2	69,730 x 50 = 3,486,500	
							0			4.1		4.1			0	
							0			4.1		4.1			0	
							0			4.1		4.1			0	
							0			4.1		4.1			0	
							0			4.1		4.1			0	
													Total Flow =	22,801,710 gals		
													Total Pump Time =	5 hours 37 mins		


Field Entry Columns

System Loss Based on Field Test Data				
Pump rpm	Q	TDH	Static	System
630	32400	23.5	8.6	14.9
535	25800	18.3	8.6	9.7

Use System Loss Nearest pump speed example: 430 rpm use 9.7 with system

# DATA SHEET \*FPI PUMP SPREAD SHEET AND CURVES\* Page 4 of 4

36" Diameter Adjusted Pump Multi-Speed Curve



The performance is guaranteed for the design path only when pumping clean water at 35 degrees F. Consult factory for certified performance curve.

Company: FPI 36" Diameter  
Name: Adjusted Multi Speed  
9/23/2016

FR  
Catalog: FPI 50 - 625 rpm  
AXIAL FLOW - 900

Size: AFSS-30-515  
Speed: 510 - 625 rpm  
Line: A (35)



Motor Pump	1800 rpm 62.5 rpm	1760 rpm 61.1 rpm	1499 rpm 52.0 rpm
TDH (ft)	Pump 100% Flow Rate (gpm)	Pump 98% Flow Rate (gpm)	Pump 83% Flow Rate (gpm)
16.9	37225	35874	25734
17	37157	35805	25597
17.1	37090	35736	25459
17.2	37022	35666	25322
17.3	36955	35597	25185
17.4	36887	35528	25048
17.5	36820	35456	24911
17.6	36752	35382	24773
17.7	36684	35308	24632
17.8	36617	35235	24493
17.9	36549	35161	24354
18	36482	35087	24216
18.1	36414	35013	23987
18.2	36347	34939	23828
18.3	36277	34865	23657
18.4	36204	34791	23474
18.5	36132	34718	23292
18.6	36050	34644	23109
18.7	35988	34570	Do Not Operate
18.8	35916	34496	Do Not Operate
18.9	35843	34422	Do Not Operate
19	35771	34346	Do Not Operate
19.1	35699	34263	Do Not Operate
19.2	35627	34179	Do Not Operate
19.3	35555	34095	Do Not Operate
19.4	35482	34011	Do Not Operate
19.5	35410	33927	Do Not Operate
19.6	35338	33844	Do Not Operate
19.7	35266	33760	Do Not Operate
19.8	35194	33676	Do Not Operate
19.9	35117	33592	Do Not Operate
20	35056	33508	Do Not Operate
20.1	34954	33425	Do Not Operate
20.2	34872	33341	Do Not Operate
20.3	34790	33257	Do Not Operate

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## DATA SHEET 2

NORTH PUMPING STATION HOURLY LOG SHEET			Date: Month	Day	Year					
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	HZ/RPM East Pump	HZ/RPM Center Pump	HZ/RPM West Pump	N-Canal Level North of 344 St	S-Canal Level South of 344 St	System Checks Sat (Y/N)	
00:00	Flow:	Flow:	Flow:							
00:00	Total:	Total:	Total:							
1:00	Flow:	Flow:	Flow:							
1:00	Total:	Total:	Total:							
2:00	Flow:	Flow:	Flow:							
2:00	Total:	Total:	Total:							
3:00	Flow:	Flow:	Flow:							
3:00	Total:	Total:	Total:							
4:00	Flow:	Flow:	Flow:							
4:00	Total:	Total:	Total:							
5:00	Flow:	Flow:	Flow:							
5:00	Total:	Total:	Total:							
6:00 6:18	Flow:	Flow:	Flow:	60/576	60/576	60/576	.0	.7	✓	
6:00 6:18	Total:	Total:	Total:							
7:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.1	.7	✓	
7:00	Total:	Total:	Total:							
8:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.1	.7	✓	
8:00	Total:	Total:	Total:							
9:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.2	.7	✓	
9:00	Total:	Total:	Total:							
10:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.3	.7	✓	
10:00	Total:	Total:	Total:							
11:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.7	✓	
11:00	Total:	Total:	Total:							
12:00 11:55	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.7	✓	
12:00 11:55	Total:	Total:	Total:							

PUMP OPERATOR A. Cooper  
Date 11/27/15

VERIFIED BY PUMP COORDINATOR K. King Date: 11/27

Pump Run 11/26

Rev 9 10/1/15

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Author: *Adam Ward* Date: 11/25/15  
Approved: *Mark J. Smith* Date: 11/25/15

- Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure
- Revision 8: Added requirement for validation CCS level margin prior to starting L31 pumps
- Revision 9: A complete re-write of the procedure which includes L31 pump curves and calculation methodology.

North station Pumped  
23,412,738 gals

South Station Pumped  
22,801,70<sup>AC</sup>~~3~~ gals

South Pumping Station  
Pump Run 11/26/15

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

South Pump station

## ATTACHMENT 4

### Event Log

Date / Time

EVENT LOG BOOK

Page \_ of \_

11/27/15/

Checked out pumps everything look good (Ready to start)

Checked area for wildlife before starting pump (all clear)

~~0623~~ Pumps running at 60Hz with 630 RPM

0625 Contacted Jimmy at South Florida Water Management  
Explained we will run until 1200 hrs

0629 Sent out text message to all appropriate individuals

Monitored pumps & area for wildlife during pump run

11:50 Pumps shut down

All Breakers shut off

Lights turned off & control box locked up

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## DATA SHEET 3

SOUTH PUMP STATION HOURLY LOG SHEET							Month	Day	Year
Time	North Pump (107944)	South Pump (107939)	HZ/RPM No.Pump	HZ/RPM So.Pump	South Canal Level	System Checks Sat			
00:00	Flow:	Flow:							
00:00	Total:	Total:							
1:00	Flow:	Flow:							
1:00	Total:	Total:							
2:00	Flow:	Flow:							
2:00	Total:	Total:							
3:00	Flow:	Flow:							
3:00	Total:	Total:							
4:00	Flow:	Flow:							
4:00	Total:	Total:							
5:00	Flow:	Flow:							
5:00	Total:	Total:							
6:00 6:23	Flow:	Flow:	60/630	60/630	.7	✓			
6:00 6:23	Total:	Total:	60/630	60/630	.7	✓			
7:00	Flow:	Flow:	60/630	60/630	.7	✓			
7:00	Total:	Total:	60/630	60/630	.7	✓			
8:00	Flow:	Flow:	60/630	60/630	.7	✓			
8:00	Total:	Total:	60/630	60/630	.7	✓			
9:00	Flow:	Flow:	60/630	60/630	.7	✓			
9:00	Total:	Total:	60/630	60/630	.7	✓			
10:00	Flow:	Flow:	60/630	60/630	.7	✓			
10:00	Total:	Total:	60/630	60/630	.7	✓			
11:00	Flow:	Flow:	60/630	60/630	.7	✓			
11:00	Total:	Total:	60/630	60/630	.7	✓			
12:00 11:50	Flow:	Flow:	60/630	60/630	.7	✓			
12:00 11:50	Total:	Total:	60/630	60/630	.7	✓			

PUMP OPERATOR K. Singh

VERIFIED BY PUMP COORDINATOR K. Singh



11/27/15 Pump Run

DATA SHEET 1\*FPI PUMP SPREAD SHEET AND CURVES\*Page 1 of 4

**AXIAL FLOW PUMP - Daily Report**

Date: 11/28/15

Location: L31 North Station Pump Model: FPIAAF-30-25

Permit No: \_\_\_\_\_ Pump Drive Ratio: 1:3.14 Motor: Pump

Site Description: Three 30" AAF Pumps pumping North to South Discharge Elevation: 3.9 feet

System Loss: See Chart Below

\*Note: Static Head is the difference between the upstream staffage reading and the discharge elevation, unless the discharge is submerged. If submerged discharge, the static head is the difference between upstream and downstream staffages.

Operator Initials	Upstream Staffage Pump On		Upstream Staffage Pump Off		Pump Run Time Hours	Electric Motor Speed	Pump RPM	Up Stream Staffage Reading	Down Stream Staffage Reading	Static Head Difference*	System Loss for Chart Below	TDH (Static + System Loss)	Flow Rate Using Adjusted Pump Curve (gpm)	Number Pumps Running	Total Flow (gallons)	Notes:
	Date	Time	Date	Time												
Sample	1/15/2015	5:00:00 PM	1/15/2015	6:00:00 PM	1.00	1800	573	0.6	0.6	3.3	6.00	9.3	23,403	3	4,212,540	
AC	11/28	5:03	11/28	6:00	57	1800	576	-.4	.8	4.3	6.0	10.3	22,779	3	68337*57= 3,895,209	
AC		6:00		7:00	1	1800	576	-.4	.7	4.3	6.0	10.3	22,779	3	68337*60= 4,100,220	
AC		7:00		8:00	1	1800	576	-.3	.7	4.2	6.0	10.2	22,842	3	68526*60= 4,111,560	
AC		8:00		9:00	1	1800	576	.0	.7	3.9	6.0	9.9	23,028	3	69084*60= 4,145,040	
AC		9:00		10:00	1	1800	576	.1	.7	3.8	6.0	9.8	23,091	3	69273*60= 4,156,380	
AC		10:00		11:00	1	1800	576	.2	.7	3.7	6.0	9.7	23,153	3	69459*60= 4,167,540	
AC		11:00		11:55	.55	1800	576	.3	.7	3.6	6.0	9.6	23,215	3	69645*60= 4,178,700	
							0			3.9		3.9			0	
							0			3.9		3.9			0	
							0			3.9		3.9			0	
							0			3.9		3.9			0	

Total Flow = 28,406,424 gpm  
 Total Pump Time = 6.52 hours

Field Entry Columns


System Loss Based on Field Test Data				
Pump (gpm)	Q	TDH	Static	System
578	22700	10.1	4.1	6.0
489	18800	8.25	4.1	4.15
460	17300	7.5	4.1	3.5

Use System Loss Nearest pump speed  
 example: 528 rpm use 4.15 system

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

DATA SHEET \*FPI PUMP SPREAD SHEET AND CURVES \*Page 2 of 4

30" Diameter Adjusted Pump Multi-Speed Curve



Company: FPI, 30" Diameter  
 Name: Adjusted Multi-Speed  
 9/23/2015

FPI  
 Catalog: FPI EA, Vers 1.1  
 AXIAL FLOW - 600

Size: AF30-56-485  
 Speed: 480 - 610 rpm  
 Unit: A (80)



The performance is guaranteed for the design point only when pumping clean water at 65 degrees F. Consult factory for certified performance curve.

Motor Pump	1800 rpm	1550 rpm
TDH (ft)	Pump 100% Flow Rate (gpm)	Pump 86% Flow Rate (gpm)
7.4	24473	19559
7.5	24421	19486
7.6	24370	19414
7.7	24318	19341
7.8	24266	19267
7.9	24212	19192
8	24157	19117
8.1	24103	19042
8.2	24048	18967
8.3	23994	18892
8.4	23939	18817
8.5	23881	18737
8.6	23822	18658
8.7	23763	18578
8.8	23704	18499
8.9	23645	18419
9	23586	18340
9.1	23526	18260
9.2	23465	18181
9.3	23403	18101
9.4	23340	18016
9.5	23278	17929
9.6	23215	17842
9.7	23153	17754
9.8	23091	17667
9.9	23028	17580
10	22966	17493
10.1	22904	17405
10.2	22842	17318
10.3	22779	17231
10.4	22717	17141
10.5	22655	17057
10.6	22593	16969
10.7	22530	16799
10.8	22466	16695

Pump Run 11/27/15

# DATA SHEET\*FPI PUMP SPREAD SHEET AND CURVES\*Page 3 of 4

## AXIAL FLOW PUMP - Daily Report

Date: 11/28/15

Location: L31 South Station  
 Permit No: \_\_\_\_\_  
 Site Description: Two 36" AAF Pumps pumping West to East  
 Pump Model: FPI AAF 36-30  
 Pump Drive Ratio: 1: 2.88 Motor : Pump  
 Discharge Elevation: 4.1 feet  
 System Loss: See Chart Below

\*Note: Static head is the difference between the upstream staffage reading and the Discharge Elevation, unless the discharge is submerged. If submerged discharge, the static head is the difference between upstream and downstream staffages.

Operator Initials	Pump On Date	Pump On Time	Pump Off Date	Pump Off Time	Pump Run Time Hours	Electric Motor Speed	Pump RPM	Up Stream Staffage Reading	Down Stream Staffage Reading	Static Head Difference*	System Loss for Chart Below	TDH (Static + System Loss)	Flow Rate Using Adjusted Pump Curve (gpm)	Number Pumps Running	Total Flow (gallons)	Notes
	1/15/2015	5:00:00 PM	1/15/2015	6:00:00 PM	1.00	1760	611	0.6	0.25	3.5	14.9	18.4	34,751	2	4,174,920	
K.S.	11/28/15	5:08	11/28	6:00	.52	1760	630	.8	.8	4.3	18.2	41.8	34,939	2	69,878 x .52 = 3,633,656	
K.S.		6:00		7:00	1	1760	630	.7	.7	4.3	18.3	41.8	34,865	2	69,730 x .60 = 4,183,800	
K.S.		7:00		8:00	1	1760	630	.7	.7	4.3	14.9	41.8	34,865	2	69,730 x .60 = 4,183,800	
K.S.		8:00		9:00	1	1760	630	.7	.7	4.3	14.9	41.8	34,865	2	69,730 x .60 = 4,183,800	
K.S.		9:00		10:00	1	1760	630	.7	.7	4.3	14.9	41.8	34,865	2	69,730 x .60 = 4,183,800	
K.S.		10:00		11:00	1	1760	630	.7	.7	4.3	14.9	41.8	34,865	2	69,730 x .60 = 4,183,800	
K.S.		11:00		11:50	.50	1760	630	.7	.7	4.3	14.9	41.8	34,865	2	69,730 x .50 = 3,486,500	
							0			4.1		4.1			0	
							0			4.1		4.1			0	
							0			4.1		4.1			0	
							0			4.1		4.1			0	

Total Flow = 28,103,915.6 gpm  
 Total Pump Time = 6.42 hours

Field Entry Columns


Pump rpm	Q	TDH	Static	System
630	32400	23.5	8.6	14.9
535	25800	18.3	8.6	9.7

Use System Loss Nearest pump speed example- 430 rpm use 9.7 with system

DATA SHEET \* FPI PUMP SPREAD SHEET AND CURVES \* Page 4 of 4

Motor Pump	1800 rpm 625 rpm	1760 rpm 611 rpm	1499 rpm 520 rpm
TDH (ft)	Pump 100% Flow Rate (gpm)	Pump 98% Flow Rate (gpm)	Pump 83% Flow Rate (gpm)
16.9	37225	35874	25734
17	37157	35805	25597
17.1	37080	35736	25459
17.2	37022	35666	25312
17.3	36955	35597	25185
17.4	36887	35528	25048
17.5	36820	35456	24911
17.6	36752	35382	24773
17.7	36684	35308	24632
17.8	36617	35235	24493
17.9	36549	35161	24354
18	36482	35087	24216
18.1	36414	35013	23987
18.2	36347	34939	23828
18.3	36277	34865	23657
18.4	36204	34791	23474
18.5	36132	34718	23292
18.6	36060	34644	23109
18.7	35988	34570	Do Not Operate
18.8	35916	34496	Do Not Operate
18.9	35843	34422	Do Not Operate
19	35771	34346	Do Not Operate
19.1	35699	34269	Do Not Operate
19.2	35627	34179	Do Not Operate
19.3	35555	34095	Do Not Operate
19.4	35482	34011	Do Not Operate
19.5	35410	33927	Do Not Operate
19.6	35338	33844	Do Not Operate
19.7	35266	33760	Do Not Operate
19.8	35194	33676	Do Not Operate
19.9	35117	33592	Do Not Operate
20	35036	33508	Do Not Operate
20.1	34954	33425	Do Not Operate
20.2	34872	33341	Do Not Operate
20.3	34790	33257	Do Not Operate

36" Diameter Adjusted Pump Multi Speed Curve



Company: FPI 36" Diameter  
 Name: Adjusted Multi Speed  
 9/23/2015

FPI  
 Catalog: FPI 60 Vets 1.1  
 Model: FLOW-600

Size: AFSS-30-665  
 Speed: 570 - 625 rpm  
 Line: A (S3)



Flow Control Since 1957

## INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Author:  Date: 11/25/15

Approved:  Date: 11/25/15

Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure

Revision 8: Added requirement for validation CCS level margin prior to starting L31 pumps

Revision 9: A complete re-write of the procedure which includes L31 pump curves and calculation methodology.

North Station Total Pump  
28,406,424 gals

South Station Total Pump  
28,039,156 gals

North Pumping Station  
11/27/15 Pump Run



# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE


## DATA SHEET 2

NORTH PUMPING STATION HOURLY LOG SHEET				Date: Month		Day		Year	
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	HZ/RPM East Pump	HZ/RPM Center Pump	HZ/RPM West Pump	N-Canal Level North of 344 St	S-Canal Level South of 344 St	System Checks Sat (Y/N)
00:00	Flow:	Flow:	Flow:						
00:00	Total:	Total:	Total:						
1:00	Flow:	Flow:	Flow:						
1:00	Total:	Total:	Total:						
2:00	Flow:	Flow:	Flow:						
2:00	Total:	Total:	Total:						
3:00	Flow:	Flow:	Flow:						
3:00	Total:	Total:	Total:						
4:00	Flow:	Flow:	Flow:						
4:00	Total:	Total:	Total:						
5:00 503	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.8	✓
5:00 503	Total:	Total:	Total:						
6:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.8	✓
6:00	Total:	Total:	Total:						
7:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.7	✓
7:00	Total:	Total:	Total:						
8:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.3	.7	✓
8:00	Total:	Total:	Total:						
9:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.0	.7	✓
9:00	Total:	Total:	Total:						
10:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.1	.7	✓
10:00	Total:	Total:	Total:						
11:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.2	.7	✓
11:00	Total:	Total:	Total:						
12:00 11:55	Flow:	Flow:	Flow:	60/576	60/576	60/576	.3	.7	✓
12:00 11:55	Total:	Total:	Total:						

PUMP OPERATOR Andren Cooper  
Date 11/28/15

VERIFIED BY PUMP  
COORDINATOR Kurt Sig Date: 11/28/15

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Author:  Date: 11/25/15  
Approved:  Date: 11/25/15

- Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure
- Revision 8: Added requirement for validation CCS level margin prior to starting L31 pumps
- Revision 9: A complete re-write of the procedure which includes L31 pump curves and calculation methodology.

North Station Total Pump  
28,406,424 gals  
South Station Total Pump  
28,039,156 gals  
South Pumping Station  
11/27/15 Pump Run

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Pump Run 11/27/15

ATTACHMENT 4

Event Log

Date / Time

EVENT LOG BOOK

Page \_ of \_

11/25/15 / 4:45

Checked out pumps and work area! (Pumps good work area no trash)

Checked Area for Wildlife (Ready no wildlife in area)

11/28/15 / 5:08

started pumps (Everything going good contacted north end)

Pumps running at 60 Hz with 630 rpm

Made sure pumps was at 60 Hz & rpm's at 630 during run time

Made sure pump area was free of debris & wildlife during pump run.

Called North station to tell pump operator South pumps going off.

11/28/15 / 11:50

South pumps shut down

11/24/15 / 11:55

All Breakers turned off

11/28/15 / 11:55

Conex box locked up secured

Kenneth Spring

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## DATA SHEET 3

SOUTH PUMP STATION HOURLY LOG SHEET							
		Month	11	Day	28	Year	2015
Time	North Pump (107944)	South Pump (107939)	HZ/RPM No.Pump	HZ/RPM So.Pump	South Canal Level	System Checks Sat	
00:00	Flow:	Flow:					
00:00	Total:	Total:					
1:00	Flow:	Flow:					
1:00	Total:	Total:					
2:00	Flow:	Flow:					
2:00	Total:	Total:					
3:00	Flow:	Flow:					
3:00	Total:	Total:					
4:00	Flow:	Flow:					
4:00	Total:	Total:					
<del>5:00</del> 5:08	Flow:	Flow:	60/630	60/630	.8	✓	
<del>5:00</del> 5:08	Total:	Total:	60/630	60/630	.8	✓	
6:00	Flow:	Flow:	60/630	60/630	.8	✓	
6:00	Total:	Total:	60/630	60/630	.8	✓	
7:00	Flow:	Flow:	60/630	60/630	.7	✓	
7:00	Total:	Total:	60/630	60/630	.7	✓	
8:00	Flow:	Flow:	60/630	60/630	.7	✓	
8:00	Total:	Total:	60/630	60/630	.7	✓	
9:00	Flow:	Flow:	60/630	60/630	.7	✓	
9:00	Total:	Total:	60/630	60/630	.7	✓	
10:00	Flow:	Flow:	60/630	60/630	.7	✓	
10:00	Total:	Total:	60/630	60/630	.7	✓	
11:00	Flow:	Flow:	60/630	60/630	.7	✓	
11:00	Total:	Total:	60/630	60/630	.7	✓	
<del>12:00</del> 11:50	Flow:	Flow:	60/630	60/630	.7	✓	
12:00 11:50	Total:	Total:	60/630	60/630	.7	✓	

PUMP OPERATOR Keith Sping  
Date 11/28/15

VERIFIED BY PUMP COORDINATOR Keith Sping  
11/28/15



11/28 Pump Run

DATA SHEET 1 \*FPI PUMP SPREAD SHEET AND CURVES\* Page 1 of 4

AXIAL FLOW PUMP - Daily Report

Date: 11/29/15

Location: L31 North Station  
 Permit No: \_\_\_\_\_  
 Site Description: Three 30" AAF Pumps pumping North to South  
 Pump Model: FPI AAF 30-26  
 Pump Drive Ratio: 1:3.14 Motor : Pump  
 Discharge Elevation: 3.9 feet  
 System Loss: See Chart Below

\*Note: Static head is the difference between the upstream statichead reading and the Discharge Elevation, unless the discharge is submerged. If submerged discharge, the static head is the difference between upstream and downstream statichead.

Operator Initials	Upstream Staiffage Pump On		Upstream Staiffage Pump Off		Pump Run Time Hours	Electric Motor Speed	Pump RPM	Up Stream Staiffage Reading	Down Stream Staiffage Reading	Static Head Difference*	System Loss for Chart Below	TDH (Static + System Loss)	Flow Rate Using Adjusted Pump Curve (gpm)	Number Pumps Running	Total Flow (gallons)	Notes
	Date	Time	Date	Time												
Sample	1/15/2015	5:00:00 PM	1/15/2015	6:00:00 PM	1.00	1800	573	0.6	0.6	3.3	6.00	9.3	23,403	3	4,212,510	
AC	11/29	5:18	11/29	6:00	.42	1800	576	.74	.7	4.3	6.00	10.3	22,779	3	683,374.12 = 2,870,154	
AC		6:00		7:00	1	1800	576	.74	.7	4.3	6.00	10.3	22,779	3	683,374.12 = 4,100,220	
AC		7:00		8:00	1	1800	576	.74	.7	4.3	6.00	10.3	22,779	3	683,374.12 = 4,100,220	
AC		8:00		9:00	1	1800	576	.73	.7	4.2	6.00	10.3	22,842	3	685,216.12 = 4,111,560	
AC		9:00		10:00	1	1800	576	.71	.7	4.1	6.00	10.3	22,966	3	688,954.12 = 4,133,880	
AC		10:00		11:00	1	1800	576	.70	.7	3.9	6.00	9.9	23,028	3	690,844.12 = 4,145,040	
AC		11:00		11:55	.55	1800	576	.71	.7	3.88	6.00	9.9	23,091	3	692,734.12 = 3,810,015	
							0			3.9		3.9			0	
							0			3.9		3.9			0	
							0			3.9		3.9			0	
							0			3.9		3.9			0	

Total Flow = 27,271,089 gpm  
 Total Pump Time = 6.23 hours

Field Entry Columns


System Loss Based on Field Test Data			
Pump rpm	Q	TDH	Static
578	22700	10.1	4.1
489	18800	8.25	4.1
460	17300	7.6	4.1

Use System Loss Nearest pump speed example: 528 rpm use 4.15 system

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

DATA SHEET\*FPI PUMP SPREAD SHEET AND CURVES\*Page 2 of 4

30" Diameter Adjusted Pump Multi Speed Curve



Company: FPI 30" Diameter  
 Name: Adjusted 1.00 Speed  
 9/22/2015

FPI  
 Catalog: FPI EA Vers 1.1  
 AXIAL FLOW - 600

Size: AF30-25-585  
 Speed: 4.01 - 51.0 rpm  
 Unit: A (80)

The performance is guaranteed for the design point only when pumping clean water at 85 degree F. Consult factory for verified performance curve.






INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

DATA SHEET \* FPI PUMP SPREAD SHEET AND CURVES \* Page 4 of 4

36" Diameter Adjusted Pump Multi Speed Curve



The performance is guaranteed for the design point only when pumping clean water at 68 degrees F. Contact factory for certified performance curve.

Company: FPI-SP Client  
 Name: Adjusted Multi Speed  
 9/23/2016


FR  
 Catalog: FPI L31, Vans 1.1  
 AXIAL FLOW-600

Size: AF36-30-S16  
 Speed: 510 - 625 rpm  
 Line: A (60)



Motor Pump	1800 rpm	1760 rpm	1499 rpm
TDH (ft)	Pump 100% Flow Rate (gpm)	Pump 98% Flow Rate (gpm)	Pump 83% Flow Rate (gpm)
16.9	37225	35674	25734
17	37157	35505	25597
17.1	37090	35736	25459
17.2	37022	35566	25322
17.3	36955	35597	25185
17.4	36887	35528	25048
17.5	36820	35456	24911
17.6	36752	35382	24773
17.7	36684	35308	24632
17.8	36617	35235	24463
17.9	36549	35161	24304
18	36482	35087	24146
18.1	36414	35013	23987
18.2	36347	34939	23828
18.3	36277	34865	23657
18.4	36204	34791	23474
18.5	36132	34718	23292
18.6	36060	34644	23109
18.7	35988	34570	Do Not Operate
18.8	35916	34496	Do Not Operate
18.9	35843	34422	Do Not Operate
19	35771	34346	Do Not Operate
19.1	35699	34269	Do Not Operate
19.2	35627	34179	Do Not Operate
19.3	35555	34095	Do Not Operate
19.4	35482	34011	Do Not Operate
19.5	35410	33927	Do Not Operate
19.6	35338	33844	Do Not Operate
19.7	35266	33760	Do Not Operate
19.8	35194	33676	Do Not Operate
19.9	35117	33592	Do Not Operate
20	35036	33508	Do Not Operate
20.1	34954	33425	Do Not Operate
20.2	34872	33341	Do Not Operate
20.3	34790	33257	Do Not Operate

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Author:  Date: 11/25/15  
Approved:  Date: 11/25/15

- Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure
- Revision 8: Added requirement for validation CCS level margin prior to starting L31 pumps
- Revision 9: A complete re-write of the procedure which includes L31 pump curves and calculation methodology.

North Total Pumped  
27,271,089 gals  
  
South Total Pumped  
26,985,510 gals  
  
North Pumping Station  
Pump Run 11/28/15

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## DATA SHEET 2

NORTH PUMPING STATION HOURLY LOG SHEET				Date: Month    Day    Year			N-Canal	S-Canal	System
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	HZ/RPM East Pump	HZ/RPM Center Pump	HZ/RPM West Pump	Level North of 344 St	Level South of 344 St	Checks Sat (Y/N)
00:00	Flow:	Flow:	Flow:						
00:00	Total:	Total:	Total:						
1:00	Flow:	Flow:	Flow:						
1:00	Total:	Total:	Total:						
2:00	Flow:	Flow:	Flow:						
2:00	Total:	Total:	Total:						
3:00	Flow:	Flow:	Flow:						
3:00	Total:	Total:	Total:						
4:00	Flow:	Flow:	Flow:						
4:00	Total:	Total:	Total:						
5:00 5:18	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.7	✓
5:00 5:18	Total:	Total:	Total:						
6:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.7	✓
6:00	Total:	Total:	Total:						
7:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.7	✓
7:00	Total:	Total:	Total:						
8:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.4	.7	✓
8:00	Total:	Total:	Total:						
9:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.3	.7	✓
9:00	Total:	Total:	Total:						
10:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.1	.7	✓
10:00	Total:	Total:	Total:						
11:00	Flow:	Flow:	Flow:	60/576	60/576	60/576	.0	.7	✓
11:00	Total:	Total:	Total:						
12:00 11:55	Flow:	Flow:	Flow:	60/576	60/576	60/576	.1	.7	✓
12:00 11:55	Total:	Total:	Total:						

PUMP OPERATOR Andrew Cooper  
Date 11/29/15

VERIFIED BY PUMP  
COORDINATOR Keith Siz Date: 11/29/15

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## DATA SHEET 2

NORTH PUMPING STATION HOURLY LOG SHEET			Date: Month	Day	Year				
Time	East Pump (107942)#3	Center Pump (107941)#2	West Pump (107940)#1	HZ/RPM East Pump	HZ/RPM Center Pump	HZ/RPM West Pump	N- Canal Level North of 344 St	S-Canal Level South of 344 St	System Checks Sat (Y/N)
13:00	Flow:	Flow:	Flow:						
13:00	Total:	Total:	Total:						
14:00	Flow:	Flow:	Flow:						
14:00	Total:	Total:	Total:						
15:00	Flow:	Flow:	Flow:						
15:00	Total:	Total:	Total:						
16:00	Flow:	Flow:	Flow:						
16:00	Total:	Total:	Total:						
17:00	Flow:	Flow:	Flow:						
17:00	Total:	Total:	Total:						
18:00	Flow:	Flow:	Flow:						
18:00	Total:	Total:	Total:						
19:00	Flow:	Flow:	Flow:						
19:00	Total:	Total:	Total:						
20:00	Flow:	Flow:	Flow:						
20:00	Total:	Total:	Total:						
21:00	Flow:	Flow:	Flow:						
21:00	Total:	Total:	Total:						
22:00	Flow:	Flow:	Flow:						
22:00	Total:	Total:	Total:						
23:00	Flow:	Flow:	Flow:						
23:00	Total:	Total:	Total:						
24:00	Flow:	Flow:	Flow:						
24:00	Total:	Total:	Total:						

PUMP OPERATOR \_\_\_\_\_  
Date \_\_\_\_\_

VERIFIED BY PUMP COORDINATOR \_\_\_\_\_  
Date: \_\_\_\_\_

11/28 Pump Run

11-29-15 YASIEL MOLINA

Rev 9 10/1/15

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

Author:  Date: 11/25/15  
Approved:  Date: 11/25/15

- Revision 7: Added RPM Columns for North and South Pumping Stations in Procedure
- Revision 8: Added requirement for validation CCS level margin prior to starting L31 pumps
- Revision 9: A complete re-write of the procedure which includes L31 pump curves and calculation methodology.

North Total Pumped  
27,271,089 gals

South Total Pumped  
26,985,510 gals

South Pumping Station  
Pump Run 11/28/15

INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

11/28/15 Pump Run

ATTACHMENT 4

Event Log

Date / Time	EVENT LOG BOOK	Page _ of _
11/29/15:00	Check for wildlife, check for grass and garbage	
/	Turn on switch everything ok ready to start pumps.	
11/29/15:23	START PUMPS check the P Tube where working	
/	good check for vibration everything is ok	
/	60 Hz 630 RPM	
/		
/	checked Area for Wildlife & Floating debris during	
/	Pump run.	
/		
/	All Pumps running good during pump run.	
/		
11/29/15/11:50	South Pump station shut off	
/	Contact North Pump station that south is off.	
/		
/11:53	All main breakers & switches shut off!	
/	Conec box locked up & secured	
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		
/		

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## DATA SHEET 3

SOUTH PUMP STATION HOURLY LOG SHEET						
Month <u>11</u> Day <u>29</u> Year <u>2015</u>						
Time	North Pump (107944)	South Pump (107939)	HZ/RPM No.Pump	HZ/RPM So.Pump	South Canal Level	System Checks Sat
00:00	Flow:	Flow:				
00:00	Total:	Total:				
1:00	Flow:	Flow:				
1:00	Total:	Total:				
2:00	Flow:	Flow:				
2:00	Total:	Total:				
3:00	Flow:	Flow:				
3:00	Total:	Total:				
4:00	Flow:	Flow:				
4:00	Total:	Total:				
<del>5:00</del> <u>5:23</u>	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
5:00	Total:	Total:				
6:00	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
6:00	Total:	Total:				
7:00	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
7:00	Total:	Total:				
8:00	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
8:00	Total:	Total:				
9:00	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
9:00	Total:	Total:				
10:00	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
10:00	Total:	Total:				
11:00	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
11:00	Total:	Total:				
<del>12:00</del> <u>11:50</u>	Flow:	Flow:	<u>60/630</u>	<u>60/630</u>	<u>.7</u>	<input checked="" type="checkbox"/>
<del>12:00</del>	Total:	Total:				

PUMP OPERATOR Kenneth Spiz  
 Date 11/29/15

VERIFIED BY PUMP  
 COORDINATOR Kenneth Spiz  
 Date 11/29/15

# INJECTION OF L31 CANAL WATER INTO THE CANAL COOLING SYSTEM PROCEDURE

## DATA SHEET 3

SOUTH PUMP STATION HOURLY LOG SHEET			Month	Day	Year		
Time	North Pump (107944)	South Pump (107939)	HZ/RPM No.Pump	HZ/RPM So.Pump	South Canal Level	System Checks Sat	
13:00	Flow:	Flow:					
13:00	Total:	Total:					
14:00	Flow:	Flow:					
14:00	Total:	Total:					
15:00	Flow:	Flow:					
15:00	Total:	Total:					
16:00	Flow:	Flow:					
16:00	Total:	Total:					
17:00	Flow:	Flow:					
17:00	Total:	Total:					
18:00	Flow:	Flow:					
18:00	Total:	Total:					
19:00	Flow:	Flow:					
19:00	Total:	Total:					
20:00	Flow:	Flow:					
20:00	Total:	Total:					
21:00	Flow:	Flow:					
21:00	Total:	Total:					
22:00	Flow:	Flow:					
22:00	Total:	Total:					
23:00	Flow:	Flow:					
23:00	Total:	Total:					
24:00	Flow:	Flow:					
24:00	Total:	Total:					

PUMP OPERATOR \_\_\_\_\_  
Date \_\_\_\_\_

VERIFIED BY PUMP  
COORDINATOR \_\_\_\_\_  
Date: \_\_\_\_\_