

# **FLOW RATING ANALYSIS FOR PUMP STATION S650**



**By**

**Sheng Yue & Emile Damisse**

**April 2012**

**SFWMD-HIST-018**

**Hydro Data Management Section**

**Infrastructure Management Bureau**

**South Florida Water Management District**



---

## TABLE OF CONTENTS

---

**TABLE OF CONTENTS ..... I**

**LIST OF FIGURES.....II**

**LIST OF TABLES.....II**

**ACKNOWLEDGEMENT ..... III**

**DEFINITIONS..... IV**

**EXECUTIVE SUMMARY ..... 1**

**1.0 INTRODUCTION.....2**

    1.1 BACKGROUND.....2

    1.2 OBJECTIVES AND SCOPE.....2

**2.0 STATION DESIGN .....3**

    2.1 PUMP PERFORMANCE CURVE FOR S650 .....6

**3.0 RATING ANALYSIS .....8**

**4.0 CONCLUDING REMARKS.....12**

**REFERENCES .....13**

**APEENDIX A: P-321 PUMP CURVE CALCULATION SHEET .....13**

**APEENDIX B: P-322 PUMP CURVE CALCULATION SHEET .....13**

**APEENDIX C: P-323 PUMP CURVE CALCULATION SHEET .....13**



---

## LIST OF FIGURES

---

FIGURE 1. LOCATION MAP FOR PUMP STATION S650.....	2
FIGURE 2. PLAN VIEW OF PUMP STATION S650.....	4
FIGURE 3. PROFILE VIEW OF PUMP OF 100 CFS .....	5
FIGURE 4. PROFILE VIEW OF PUMP OF 75 CFS .....	5
FIGURE 5. PUMP PERFORMANCE CURVE FOR P-321 OF 100 CFS .....	6
FIGURE 6. PUMP PERFORMANCE CURVE FOR P-322 OF 75 CFS .....	7
FIGURE 7. PUMP PERFORMANCE CURVE FOR P-323 OF 75 CFS .....	7
FIGURE 8. FLOW RATING CURVE FOR PUMP OF 100 CFS.....	10
FIGURE 9. FLOW RATING CURVE FOR PUMP OF 75 CFS.....	11

---

## LIST OF TABLES

---

TABLE 1. DESCRIPTION FOR S650 .....	3
TABLE 2. MINOR LOSS COEFFICIENTS .....	8
TABLE 3. TDH, HEAD LOSS, TSH AND DISCHARGE RELATIONS FOR PUMP OF 100 CFS.....	9
TABLE 4. TDH, HEAD LOSS, TSH AND DISCHARGE RELATIONS FOR PUMP OF 75 CFS.....	9
TABLE 5. FLOW RATING COEFFICIENTS FOR THE PUMPS AT S650.....	10
TABLE 6. COMPARISON BETWEEN TESTED AND CALCULATED FLOWS FOR PUMP OF 100 CFS.....	11
TABLE 7. COMPARISON BETWEEN TESTED AND CALCULATED FLOWS FOR PUMP OF 75 CFS.....	12



South Florida Water Management District

FLOW RATING ANALYSIS FOR PUMP STATION S650

---

## ACKNOWLEDGEMENT

The authors wish to express their appreciation to Jiangchang Cai and John Creswell for collecting the pump performance curve and pump design information for this rating analysis.



## DEFINITIONS

### Acronyms

AARE	Average absolute relative error
ARE	Absolute relative error
SFWMD	South Florida Water Management District
STA	Stormwater treatment area
TDH	Total dynamic head
TSH	Total static head



## **EXECUTIVE SUMMARY**

Pump Station S650 houses three electric pumps: one with design capacity of 100 cfs and the other two with design capacity of 75 cfs. This report summarizes a flow rating analysis for each type of the pump at Pump Station S650 based on their corresponding pump performance curves. The developed rating equations will be used to compute flow through the pump station.



## 1.0 INTRODUCTION

### 1.1 Background

Pump Station S650 houses three electric pumps: pump P-321 with design capacity of 100 cfs and P-322 and P-323 with 75 cfs. Pump Station S650 conveys water from the improved L-64 Canal to the Distribution Canal of Lake Ranch Stormwater Treatment Area (STA-N). The station is located near the northwest corner of the STA-N bounded to the north by the improved L-64 Canal, as shown in **Figure 1**. Both manual and remote operations of the pumping units are possible. Remote operation is from the SFWMD's Operations Control Center in West Palm Beach. Telemetry control is also available to the remote operators.




Figure 1. Location map for Pump Station S650

### 1.2 Objectives and Scope

We will conduct a preliminary rating analysis to develop a flow rating equation for each type of the pump at Pump Station S650 to compute flow through the pump station.



## 2.0 STATION DESIGN

Pump Station S650 houses three electric pump units, P-321 with design capacity of 100 cfs and P-322 and P-323 with 75 cfs. Pumps P-322 and P323 are identical. **Table 1** presents more detailed description for S650. **Figure 2** illustrates the plan view of Pump Station S650. **Figure 3** and **Figure 4** show the profile view of the pump of 100 cfs and 75 cfs, respectively.

**Table 1. Description for Pump Station S650**

Pump Type	Item	Description
P-321: 100 cfs	Number of pumps	1
	Design pump capacity	100 cfs
	Engine motor horsepower	200 Hp
	Design pump speed	591 rpm
	Discharge pump diameter	48 in
P-322 & P-323: 75 cfs	Number of pumps	2
	Design pump capacity	75 cfs
	Engine motor horsepower	200 Hp
	Design pump speed	591 rpm
	Discharge pump diameter	42 in
Elevation	Operating Floor Elevation	34.0 ft, NAVD
	Intake Floor Elevation	3.0 ft, NAVD
	Minimum Intake Water Elevation	14.5 ft, NAVD
	Maximum Intake Water Elevation	18.0 ft, NAVD
	Centerline Discharge Pipe Elevation (Pump P-321, Pump P-322 & P-323)	24.76 ft NAVD
	Maximum Discharge Pool Elevation (Pump P-321)	30.26 ft NAVD
	Maximum Discharge Pool Elevation (Pump P-322 & P-323)	30.17 ft NAVD






Figure 3. Profile view of the pump of 100 cfs




Figure 4. Profile view of the pump of 75 cfs



### 2.1. Pump Performance Curves for S650

The manufacturer provides the pump performance curves for P-321 with 100 cfs and P-322 & P-323 with 75 cfs based on the pump tests, as shown in **Figure 5** through **Figure 7**. Appendix A through C present the corresponding calculation sheets for these curves.




Figure 5. Pump performance curve for P-321 (100 cfs)




Figure 6. Pump performance curve for P-322 (75 cfs)




Figure 7. Pump performance curve for P-323 (75 cfs)



### 3.0 RATING ANALYSIS

We will develop a Case 8 flow rating equation for each type of pump at Pump Station SS650, based on the factory pump performance curves obtained from the pump tests. Case 8 rating equation is developed based on dimensional analysis and pump affinity laws. This conventional rating equation represents all the possible cases, as documented in Damisse (2001) and Imru and Wang (2003). Equation below shows the Case 8 flow rating equation.

$$Q = A \left( \frac{N}{No} \right) + BH^C \left( \frac{No}{N} \right)^{2C-1} \tag{1}$$

$$H = \max\{CL, TW\} - HW \tag{2}$$

Where

- Q*: Discharge in cfs;
- H*: Total static head (TSH);
- N*: Pump engine speed in rpm;
- No*: Design pump engine speed in rpm (= 591 rpm);
- A, B and C*: Regression coefficients determined through regression analysis (*A* > 0, *B* < 0, and *C* > 1.0).
- CL*: Discharge pipe outlet centerline elevation;
- TW*: Tailwater elevation;
- HW*: Headwater elevation.

For electric pumps with constant speed,  $N = N_o$ , and Equation (1) becomes

$$Q = A + BH^C \tag{3}$$

The *H* versus *Q* relationship can be estimated by subtracting the total head losses through the intake and discharge works from total dynamic head (TDH) on the pump performance curve. We will then conduct a non-linear regression analysis using SAS NLIN function to determine the coefficients in the above equation.

We computed TSH by subtracting total head loss from TDH. The total head loss includes friction loss and minor losses. Friction head loss was provided by the pump manufacturer as given in Appendix A through C. **Table 2** presents the minor loss coefficients for pump inlet, outlet, and bend (HIE, 1990).

**Table 2. Minor Loss Coefficients**

Minor loss coefficient	Value
Bell Mouth Inlet	0.05
Pipe Exit - Projecting Exit	1.00
90 Degree Elbow	0.195
<b>Total</b>	<b>1.25</b>



Table 3 and Table 4 present TDH, total head loss, and TSH vs.  $Q$  values for the pump of 100 cfs and the pump of 75 cfs, respectively. Table 5 provides the flow rating equation coefficients of Eq. (3) corresponding to each type of the pump, which were estimated by nonlinear regression analysis.

**Table 3. TDH, Head Loss, TSH and Discharge Relations for Pump -100 cfs**

Flow		Pump total head (ft)	Head loss (ft)			Total static head (ft)	Pump speed (rpm)
GPM	CFS		Velocity head loss	Minor loss	Total		
44801.4	99.8	21.8	7.4	1.225	8.625	13.175	590
39495.2	88.0	27.6	5.7	0.952	6.652	20.948	588
39432.1	87.9	27.3	5.7	0.949	6.649	20.651	590
41753.6	93.0	25.1	6.4	1.064	7.464	17.636	590
44736.4	99.7	21.7	7.3	1.221	8.521	13.179	591
48392.9	107.8	17.5	8.6	1.429	10.029	7.471	593
51292.3	114.3	14.2	9.6	1.605	11.205	2.995	593
39600.3	88.2	27.7	5.7	0.957	6.657	21.043	588

**Table 4. TDH, Head Loss, TSH and Discharge Relations for Pump -75 cfs**

Pump #	Flow		Pump Total Head (ft)	Head loss (ft)			Total static head (ft)	Pump Speed (rpm)
	GPM	CFS		Velocity head loss	Minor loss	Total		
P-322	37557.2	83.7	17.7	5.2	1.468	6.668	11.032	591
	31427.2	70.0	25.4	3.6	1.028	4.628	20.772	588
	33254.1	74.1	23.2	4.0	1.151	5.151	18.049	589
	35191.2	78.4	20.7	4.5	1.289	5.789	14.911	590
	37543	83.6	17.7	5.2	1.467	6.667	11.033	590
	40326.4	89.9	13.6	6.0	1.693	7.693	5.907	593
	42877.9	95.5	10.5	6.7	1.914	8.614	1.886	593
	42942.2	95.7	10.4	6.8	1.920	8.720	1.680	594
	30952.7	69.0	25.6	3.5	0.997	4.497	21.103	588
P-323	37306.5	83.1	18.2	5.1	1.449	6.549	11.651	590
	31092.5	69.3	25.8	3.5	1.006	4.506	21.294	588
	33890.2	75.5	22	4.2	1.196	5.396	16.604	590
	35592.5	79.3	20.1	4.6	1.319	5.919	14.181	590
	37483	83.5	17.7	5.1	1.463	6.563	11.137	591
	40110.1	89.4	13.8	5.9	1.675	7.575	6.225	593
	43315.8	96.5	9.8	6.9	1.953	8.853	0.947	593
	29166.8	65.0	27.8	3.1	0.886	3.986	23.814	588



Table 5. Flow Rating Coefficients for the Pumps at S650

Pump Type	Rating Coefficient	Estimate	Approximate Lower 95% Confidence Limit	Approximate Upper 95% Confidence Limit
P-321 of 100 cfs	A	117.6	114.6	120.6
	B	-1.229	-2.162	-0.296
	C	1.040	0.819	1.261
P-322 & P-323 of 75 cfs	A	96.839	96.131	97.546
	B	-0.956	-1.173	-0.740
	C	1.094	1.026	1.163

Figure 8 illustrates the developed rating curve for the pump of 100 cfs, and Figure 9 for the pump of 75 cfs. These diagrams illustrate that the rating curves from the developed rating equation well fits the tested data. Table 6 and Table 7 present the relative errors between tested and calculated flows for the pump of 100 cfs and 75 cfs, respectively. The AARE for the pump of 100 cfs is 0.3% and the pump of 75 cfs is 0.4%. These results indicate that the developed ratings well represent the relationship between total static head and discharge obtained from the manufactory pump tests.




Figure 8. Flow rating curve the pump with design capacity of 100 cfs




Figure 9. Flow rating curve the pump with design capacity of 75 cfs

Table 6. Comparison between Tested and Calculated Flows for Pump of 100 cfs

TSH (ft)	Pump speed at test (rpm)	Discharge from pump test (cfs)	Discharge from New Rating (cfs)	Absolute Relative Error (%)
13.175	590	99.8	99.4	0.4
20.948	588	88.0	87.8	0.3
20.651	590	87.9	88.7	1.0
17.636	590	93.0	93.0	0.0
13.179	591	99.7	99.6	0.0
7.471	593	107.8	108.1	0.2
2.995	593	114.3	114.2	0.1
21.043	588	88.2	87.6	0.7
<b>Average Absolute Relative Error (AARE)</b>				<b>0.3</b>



**Table 7. Comparison between Tested and Calculated Flows for pump of 75 cfs**

<b>TSH (ft)</b>	<b>Pump speed at test (rpm)</b>	<b>Discharge from pump test (cfs)</b>	<b>Discharge from New Rating (cfs)</b>	<b>Absolute Relative Error (%)</b>
11.032	591	83.7	83.6	0.1
20.772	588	70.0	69.8	0.4
18.049	589	74.1	73.8	0.4
14.911	590	78.4	78.3	0.2
11.033	590	83.6	83.4	0.3
5.907	593	89.9	90.5	0.7
1.886	593	95.5	95.3	0.3
1.680	594	95.7	95.7	0.0
21.103	588	69.0	69.3	0.5
11.651	590	83.1	82.6	0.6
21.294	588	69.3	69.0	0.3
16.604	590	75.5	76.0	0.6
14.181	590	79.3	79.2	0.1
11.137	591	83.5	83.5	0.0
6.225	593	89.4	90.1	0.8
0.947	593	96.5	96.3	0.3
23.814	588	65.0	65.5	0.8
<b>Average Absolute Relative Error (AARE)</b>				<b>0.4</b>

#### **4.0 CONCLUDING REMARKS**

We conducted rating analysis for the each type of the pump at Pump Station SS650 based on the pump performance curves. **Table 5** presents the coefficients of the flow rating equations for the pump units at Pump Station S650. The flow rating equations need to be calibrated, and to be potentially improved based on future flow measurements after the pump stations are constructed and operated.



South Florida Water Management District

FLOW RATING ANALYSIS FOR PUMP STATION S650

---

## REFERENCES

Damisse, E. 2001. Flow rating development for G335 Pump Station in STA-2. Hydrologic Data Management Division, South Florida Water Management District, West Palm Beach, Florida.

HIE, 1990. Hydraulic Institute Engineering Data Book, 2<sup>nd</sup> Edition. Hydraulic Institute, Cleveland, Ohio.

Imru, M. and Y. Wang. 2003. Flow Rating Analysis Procedures for Pumps. Technical Publication EMA # 413, South Florida Water Management District, West Palm Beach, Florida.



South Florida Water Management District  
**FLOW RATING ANALYSIS FOR PUMP STATION S650**

**Appendix A: P-321 pump curve calculation sheet**

**Sulzer Pumps (US) Inc.**  
Performance Test: Set up and Test Data Sheet

Test Curve No.: **15684**

Job Number: **10008831-13**

Unit: **A**

Customer: **Southwest Equipment Services**

Pump Category: **Propeller**

Model: **36FD**

Stages: **1**

Test Imp. Dia (in): **2.50**

Calc'd Imp. Dia (in): **-**

TSP / CL: **1.8 / 0**

Imp. Material: **AT40-CFEM**

Bowl Material: **AT40-CFEM**

Bowl ID Coating: **Plastic 7122**

Specific Speed: **-** Ns

Suction Type: **Ball**

Discharge Head: **Lab**

Column Pipe: **Lab**

Pipe ID @ Gauge: **25.000** inches

Water To Floor: **12** inches

Floor To Gauge: **67** inches

Press Tap Location: **Steel**

Pump Driver: **Job**

Water Temp: **89.8** °F

Head Constant: **1.130**

Impeller Adjustment: **1.0**

Acceptance Criteria by: **U.H. 100262010** (see app. check)

Rated RPM: **581**

Flow: **44882.2** GPM

Head: **18.5** FT

Power: **350.0** BHP

Efficiency: **83.3** %

Test Lab Water Sp: **0.898** As Tested

Job Specific Gravity: **1.000**

Fluid: **Water**

Application: **-**

Marking: **FD 25.000**

Tag No: **P-321**

End User: **South Florida Water Management District**

Revision: **0**

Rev Date: **-**

Comment: **-**

DAG Test

Flow Meter: **50" Mag. 0.176,000 GPM - 50" 502**

Power Meter: **200 HP - 50" 513**

Press Meter: **2.1175kg - 50" 286**

Tachometer: **3600RPM - 50" 275**

Temp Meter: **50-140F - 50" 282**

Test Line: **50" Mag.**

Comments: **Witnessed performance and vibration test with job sheet.**

Project Manager: **Scott Hill**

@ Test - Floor to bottom of baseplate: **0.00** in.

Total Pump Length (TFL): **126.00** in.

@ Test - Submergence over Suction Bell: **8.83** ft

Test Point Number	1	2	3	4	5	6	7	8	9
Target Flow (gpm)	44880.0	36000.0	30280.0	41887.0	44880.0	46250.0	51627.0	55000.0	33000.0
Actual Flow Rate (gpm)	44801.4	36184.2	30432.1	41750.6	44751.4	46282.9	51292.2	52185.4	33000.0
Bowl Discharge Pressure (psf)	3.7	6.0	6.7	5.9	7.7	1.4	-0.0	-0.1	8.8
Head (ft)	8.8	15.8	15.6	12.8	8.5	3.2	-1.0	-4.0	18.0
Gage @ Inlet Com. (ft)	8.8	8.8	8.5	8.5	8.5	8.5	8.8	8.8	8.8
Velocity Head Loss (ft)	7.6	6.7	6.7	6.4	7.3	6.6	8.8	13.3	6.7
Total Head (ft)	22.5	25.1	27.6	25.7	22.5	18.4	18.2	12.9	26.3
Wall Head (kW)	231.47	284.75	284.25	258.48	233.98	199.84	178.25	155.01	285.63
Input H.P.	310.3	381.8	381.0	347.8	308.8	267.6	234.9	212.9	386.9
Part (Bar)	488.7	488.3	488.4	488.7	471.2	472.4	475.9	475.9	473.7
Wages (Per)	391.9	493.1	493.0	426.4	366.3	361.5	331.8	320.0	482.1
Job Motor Efficiency	0.919	0.919	0.919	0.919	0.919	0.919	0.919	0.919	0.919
Job Motor Efficiency	233.8	347.4	346.7	316.5	281.7	242.0	212.8	183.7	382.0
Actual Test Speed (gpm)	392	381	391	392	392	391	391	391	392
Rated Speed (gpm)	581	581	581	581	581	581	581	581	581
Rated Flow Rate (gpm)	44726	35886	30432	41887	44681	46250	51023	52878	33003
Rated Total Disch H2 (ft)	22.48	28.08	27.83	25.08	22.42	18.88	18.04	12.81	26.28
Rated B.H.P. @ Lab Sp.	280.08	347.40	346.74	314.92	280.31	241.88	213.98	190.80	352.26
Rated B.H.P. @ Job Sp.	282.08	349.10	348.44	316.47	281.88	242.26	211.58	191.73	351.87
Rated Bowl Efficiency	85.8%	88.2%	79.9%	88.9%	88.8%	81.9%	91.6%	88.2%	82.1%
Calculated Pump Total Head (ft)	21.8	27.8	27.3	25.1	21.7	17.5	14.2	11.0	27.7
Calculated Pump B.H.P. @ Job Sp.	285.92	350.83	350.16	318.18	283.39	243.80	213.06	193.17	353.71
Calculated Pump Efficiency	87.0%	79.7%	76.0%	83.3%	87.0%	87.6%	86.1%	88.4%	79.8%

Tested By: **Isaac Milford**      Witnessed By: **O**      Certified By: **Leonard Horvath**      Date of Test: **01/7/2011**

36FD-1\_46201-13\_A\_TC-15684\_001.xls



South Florida Water Management District  
**FLOW RATING ANALYSIS FOR PUMP STATION S650**

**Appendix B: P-322 pump curve calculation sheet**

**Sulzer Pumps (US) Inc.**  
 Performance Test: Set up and Test Data Sheet

Test Curve No.: **32684**

Job Number: **10094931-02**

Unit: **A**

Customer: **Southwest Equipment Services**

Pump Category: **Propeller**

Model: **36FD**

Stages: **1**

Test Insp. Dia JTC: **4.25 P/In**

Calc'd Insp. Dia JTC: **1.8 / C**

Inp. Material: **316L SS**

Bowl Material: **316L SS**

Bowl ID Coating: **Fluoro 7122**

Specific Speed: **Na**

Suction Type: **Std**

Discharge Head: **Lab**

Column Pipe: **Lab**

Pipe ID @ Gauge: **28.00** inches

Water To Floor: **11** inches

Floor To Gauge: **67** inches

Press Tap Location: **Std**

Pump Driver: **Job**

Water Temp: **88.0** °F

Head Constant: **1.158**

Impeller Adjustment: **1.0**

Acceptance Criteria by: **LH-1028301.0** See app. sheet

Rated RPM: **3600**

Flow: **27118.3** GPM

Head: **16.1** FT

Power: **293.0** BHP

Efficiency: **83.3** %

Test Lab Water Sp: **0.885** As Tested

Job Specific Gravity: **1.805** Job

Fluid: **Water**

Application: **PCD 09 1204**

Marking: **PCD 09 1204**

Tag No: **P-322**

End User: **South Florida Water Management District**

DAQ Test

Flow Meter: **48" Mag D-175,000 GPM-See 320**

Power Meter: **300 HP-See 215**

Pressure Meter: **0.17 MPa-See 295**

Tachometer: **3600RPM-See 209**

Temp Meter: **30-140F-See 292**

Test Line: **48" Mag**

Manual Test: **See app. sheet**

Vib Analyzer: **Data Physics Signal Calc**

Comments: **Revised performance and vibration test with job driver.**

Job Motor Nameplate Data

Motor Mfg:	US Motors	P.P.M.:	360
H.P.:	250	F.L. Amps:	300
Volts:	480	Phase:	3
Cycles:	60	S.F.:	1.15
Type:	3	Frame:	0
% Eff.:	91		

Project Manager: **Scott Hill**

@ Test - Floor to bottom of baseplate: **8.00** ft.

    Total Pump Length (TPL): **125.00** ft.

@ Test - Submergence over Suction Bell: **8.50** ft.

Revision: **1**

Rev Date: **04/11/12**

Comment:

Test Point Number	1	2	3	4	5	6	7	8	9
Target Flow (gpm)	37369.9	31210.5	33293.0	35141.9	37368.8	40360.8	40911.0	40911.0	39068.9
Actual Flow Rate (gpm)	37557.8	31427.3	33264.1	35159.2	37343.9	40326.4	40877.9	42942.7	39262.7
Bowl Discharge Pressure (psi)	3.9	6.7	6.6	4.4	2.8	0.3	-1.5	-1.8	6.5
Head (ft)	6.7	16.4	15.0	15.2	6.7	2.1	-1.7	-1.8	15.9
Static Head (ft)	6.59	6.49	6.50	6.50	6.39	6.59	6.50	6.30	6.50
Velocity Head Loss (ft)	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Total Head (ft)	16.4	35.7	33.5	31.2	15.4	14.9	11.9	11.4	28.9
Water Reading (MM)	198.62	205.34	182.14	176.04	158.15	323.29	116.29	115.81	205.91
Inlet H.P.	214.0	275.3	254.9	234.4	212.3	284.2	193.9	193.2	278.9
Vel. (ft/s)	474.2	474.1	474.1	474.3	474.2	474.4	475.2	475.0	473.9
Angle/ft	398.0	342.4	355.6	315.7	296.9	276.3	296.1	295.5	352.1
Job Motor Efficiency	0.910	0.913	0.916	0.910	0.910	0.913	0.913	0.910	0.910
Lab Motor Efficiency									
B.H.P.	194.7	210.5	201.9	210.3	182.9	167.6	161.8	141.3	200.8
Actual Test Speed (rpm)	361	368	359	360	363	353	352	354	350
Rated Speed (rpm)	361	361	361	361	361	361	361	361	361
Rated Flow Rate (gpm)	37827	31896	33267	35281	37827	40196	42725	42725	31111
Rated Total Head (ft)	18.40	25.83	23.71	21.20	18.40	14.45	11.45	11.33	28.08
Rated B.H.P. @ Lab Test	194.71	210.34	204.20	214.38	193.90	185.90	140.39	130.13	204.47
Rated B.H.P. @ Job Test	195.59	210.94	205.43	215.38	194.82	186.99	141.89	130.79	205.47
Rated Bowl Efficiency	83.2%	80.9%	84.8%	85.1%	85.2%	86.2%	87.4%	87.3%	83.0%
Calculated Pump Total Head (ft)	17.7	35.4	33.2	30.7	17.7	13.8	10.9	10.4	28.4
Calculated Pump B.H.P. @ Job Site	167.25	207.31	207.15	217.04	196.44	188.34	142.84	141.28	207.64
Calculated Pump Efficiency:	0.78	0.79	0.83	0.88	0.86	0.83	0.80	0.80	0.78

Tested By: **WALC HUBBS**

Witnessed By: **0**

Conducted By: **Lawrence Hertzog**

Date of Test: **01/18/2014**



South Florida Water Management District  
**FLOW RATING ANALYSIS FOR PUMP STATION S650**

**Appendix C: P-323 pump curve calculation sheet**

**Sulzer Pumps (US) Inc.**  
 Performance Test: Set up and Test Data Sheet

Test Curve No.: **15682**

Job Number: **15004601-02**  
 Unit: **3**  
 Customer: **South Florida Water Management District**  
 Pump Category: **Pringable**

Model: **3PFO**  
 Stages: **1**  
 Test Imp. Dia (In): **4.80 (125)**  
 Calc'd Imp. Dia (In): **4.80 (125)**  
 TB / CL: **1.6 / C**

Imp. Material: **2145-CF8E**  
 Bowl Material: **2145-CF8E**  
 Bowl ID Coating: **Resin 7102**

Specific Speed: **Na**  
 Suction Type: **Ball**  
 Discharge Head: **Lab**  
 Column Pipe: **Lab**

Pipe ID @ Gauge: **20.000** inches  
 Water To Floor: **11** inches  
 Floor To Gauge: **67** inches  
 Press Tap Location: **Seal**

Pump Driver: **Job**

Water Temp: **89.0** °F

Head Constant: **1.138**

Impeller Adjustment: **1.8**  
 Acceptance Criteria by: **L1 - 155833510** (see app sheet)

Rated RPM: **881**  
 Flow: **37118.8** GPM  
 Head: **18.1** FT  
 Power: **250.0** SHP  
 Efficiency: **83.3** %  
 Test Lab Water Sp: **8.888** lbs Tested  
 Job Specific Gravity: **1.000** Job

Fluid: **Water**  
 Application: **PO, 35-154**  
 Marking: **P-323**  
 Tag No: **P-323**  
 End User: **South Florida Water Management District**

Revision: **0**  
 Rev Date:   
 Comment:

**SULZER**

DAQ Test  
 Flow Meter: **4F Mag 0-175,000 GPM- 08 322**  
 Power Meter: **500 HP- 08 215**  
 Press Meter: **0-17 PSIG- 08 295**  
 Tachometer: **3000RPM 08 293**  
 Temp Meter: **05-148F 08 288**  
 Test Line: **08 16g**

Manual Test  
 Vib Analyzer: **Das Physiks Signal Con**

Comments: **Witnessed performance and vibration test with job owner.**

Job Motor Nameplate Data  
 Motor Mfg: **US Motors**  
 H.P.: **250** R.P.M.: **560**  
 Volts: **480** P.L. Amps: **350**  
 Cycles: **60** Phase: **3**  
 Type: **S** R.F.: **1.15**  
 % Eff.: **91** Frame: **0**

Project Manager: **Scott Hall**

@ Test - Floor to bottom of baseplate: **8.00** ft.  
 Total Pump Length (TPL): **126.00** ft.  
 @ Test - Submergence over Suction Bell: **8.92** ft.

Test Point Number	1	2	3	4	5	6	7	8	9
Target Flow (gpm)	37080.0	31318.0	33050.0	35316.0	37988.0	40950.0	43331.0	46211.0	26000.0
Actual Flow Rate (gpm)	37080.0	31352.0	32840.0	34982.0	37403.0	40116.0	43119.0	44225.4	26000.0
Bowl Discharge Pressure (psi)	7.1	5.0	5.3	4.1	2.9	1.3	2.3	3.0	2.0
Head (ft)	7.2	16.0	11.6	9.5	6.7	2.3	2.5	-4.0	18.3
Gate Rev/Com (ft)	8.80	8.80	6.50	8.80	8.80	6.00	9.50	9.80	6.50
Velocity Head Loss (ft)	5.1	3.8	4.2	4.8	5.1	5.0	6.8	7.2	3.1
Total Head (ft)	16.8	26.1	22.8	20.7	18.4	14.7	10.8	9.7	28.3
Water Reading (kW)	157.24	180.41	178.80	158.08	154.75	134.90	105.82	103.18	204.35
Input H.P.	211.3	262.2	246.6	220.3	207.4	186.9	147.9	139.9	276.8
Wt. (Net)	474.0	472.9	479.4	475.0	474.1	474.8	474.2	473.9	471.4
Rated Power	291.8	333.8	317.1	304.4	289.3	268.7	246.0	241.0	301.3
Job Motor Efficiency	0.910	0.910	0.910	0.910	0.910	0.910	0.910	0.910	0.910
Lab Motor Efficiency	192.9	229.6	219.3	205.6	189.8	164.7	124.0	126.9	261.7
B.H.P.	900	580	550	590	781	583	505	534	580
Actual Test Speed (rpm)	891	891	891	891	891	891	891	891	891
Rated Flow Rate (gpm)	37070	31254	32840	34983	37403	39970	43170	44002	26018
Rated Total Disch Hd (ft)	16.88	26.32	22.82	20.72	18.38	14.61	10.88	9.88	28.24
Rated S.H.P. @ Lab Sp.	183.32	243.28	230.08	226.07	188.77	152.89	122.61	123.08	255.56
Rated S.H.P. @ Job Sp.	184.13	243.43	231.12	227.05	189.87	163.77	133.24	134.57	258.77
Rated Best Efficiency	81.7%	88.3%	87.7%	80.1%	81.7%	85.1%	87.4%	86.8%	81.4%
Calculated Pump Total Head (ft)	18.2	25.8	22.0	20.1	17.7	13.8	9.8	8.8	27.8
Calculated Pump B.H.P. @ Job Sp.	195.75	243.20	232.82	228.72	191.20	165.34	134.71	126.02	256.59
Calculated Pump Efficiency	0.88	0.84	0.85	0.87	0.88	0.88	0.78	0.76	0.82

Titled By: **Isaac mford** Witnessed By: **0** Certified By: **Lorenco Harnock** Date of Test: **8/16/2011**