

# Stormwater Treatment Areas and Related Projects Update Part 1

Quarterly Meeting of the Technical Oversight Committee  
December 15, 2009

Tracey Piccone, P.E., Chief Consulting Engineer  
South Florida Water Management District

# STA Performance Data

Updated December 10, 2009 – Contains Preliminary Data

## *Period of Record*

	<b>STA-1E</b> <i>Sep. 2004 – Nov. 2009</i>	<b>STA-1W</b> <i>Oct. 1993 – Nov. 2009</i>	<b>STA-2</b> <i>June 1999 – Nov. 2009</i>	<b>STA-3/4</b> <i>Oct. 2003 – Nov. 2009</i>	<b>STA-5</b> <i>Oct. 1999 – Nov. 2009</i>	<b>STA-6</b> <i>Oct. 1997 – Nov. 2009</i>
<b>Average Inflow TP (ppb)</b>	<b>180</b>	<b>171</b>	<b>109</b>	<b>116</b>	<b>234</b>	<b>97</b>
<b>Average Outflow TP (ppb)</b>	<b>64</b>	<b>53</b>	<b>23</b>	<b>17</b>	<b>96</b>	<b>33</b>
<b>TP removed (m tons)</b>	<b>75</b>	<b>433</b>	<b>253</b>	<b>347</b>	<b>205</b>	<b>53</b>



# STA Performance Data

Updated December 10, 2009 – Contains Preliminary Data

*Previous Year (December 2008 – November 2009)*

	<b>STA-1E</b>	<b>STA-1W</b>	<b>STA-2</b>	<b>STA-3/4</b>	<b>STA-5</b>	<b>STA-6</b>
<b>Average Inflow TP (ppb)</b>	<b>209</b>	<b>211</b>	<b>116</b>	<b>104</b>	<b>189</b>	<b>123</b>
<b>Average Outflow TP (ppb)</b>	<b>96</b>	<b>35</b>	<b>42</b>	<b>14</b>	<b>36</b>	<b>55</b>

